

May 13, 1996

Mr. Michael B. Sellman
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

SUBJECT: CORRECTION TO AMENDMENT NO. 116 TO FACILITY OPERATING LICENSE NO.
NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M88853)

Dear Mr. Sellman:

On November 17, 1995, the Commission issued Amendment No. 116 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment changed the Appendix A Technical Specifications (TSs) to make them consistent with the revised 10 CFR Part 20, Standards for Protection Against Radiation.

After issuance, it was discovered that TS page 3/4 11-17 contained a typographical error. The number in the second line of the TS should be 8.5×10^4 . We are enclosing a corrected TS page 3/4 11-17. We regret any inconvenience this may have caused you.

Sincerely,

Original signed by C. Patel
Chandu P. Patel, Project Manager Project
Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: TS page 3/4 11-17

cc w/encl: See next page

DISTRIBUTION:

Docket File	WBeckner	CGrimes
PUBLIC	PNoonan	ACRS
PDIV-1 r/f	CPatel	JDyer, RIV
JRoe	OGC	LHurley, RIV
EAdensam (EGA1)	GHill (2)	JKilcrease, RIV r/f
		SKlementowicz

Document Name: WAT88853.LTR

OFC	PDIV-1 <i>DM</i>	PDIV-1 <i>CP</i>
NAME	PNoonan	CPatel:sp
DATE	5/13/96	5/13/96
COPY	(YES/NO)	(YES/NO)

OFFICIAL RECORD COPY

150090

9605140358 960513
PDR ADOCK 05000382
P PDR

DFD1
OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 13, 1996

Mr. Michael B. Sellman
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

SUBJECT: CORRECTION TO AMENDMENT NO. 116 TO FACILITY OPERATING LICENSE NO.
NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M88853)

Dear Mr. Sellman:

On November 17, 1995, the Commission issued Amendment No. 116 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment changed the Appendix A Technical Specifications (TSs) to make them consistent with the revised 10 CFR Part 20, Standards for Protection Against Radiation.

After issuance, it was discovered that TS page 3/4 11-17 contained a typographical error. The number in the second line of the TS should be 8.5×10^4 . We are enclosing a corrected TS page 3/4 11-17. We regret any inconvenience this may have caused you.

Sincerely,

Chandu P. Patel
Chandu P. Patel, Project Manager Project
Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: TS page 3/4 11-17

cc w/encl: See next page

Mr. Michael B. Sellman
Entergy Operations, Inc.

Waterford 3

cc:

Mr. William H. Spell, Administrator
Louisiana Radiation Protection Division
Post Office Box 82135
Baton Rouge, LA 70884-2135

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Mr. Jerrold G. Dewease
Vice President, Operations
Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, LA 70066

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, LA 70057

Mr. James J. Fisicaro, Director
Nuclear Safety
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Mr. Jerry W. Yelverton, Executive Vice-
President and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P.O. Box 651
Jackson, MS 39205

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, LA 70825-1697

Mr. Dan R. Keuter
General Manager Plant Operations
Entergy Operations, Inc.
P.O. Box B
Killona, LA 70066

Mr. Donald W. Vinci, Licensing Manager
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Winston & Strawn
Attn: N. S. Reynolds
1400 L Street, N.W.
Washington, DC 20005-3502

RADIOACTIVE EFFLUENTS

GAS STORAGE TANKS

LIMITING CONDITION OR OPERATION

3.11.2.6 The quantity of radioactivity contained in each gas storage tank shall be limited to less than or equal to 8.5×10^4 curies noble gases (considered as Xe-133 equivalent).

APPLICABILITY: At all times.

ACTION:

- a. With the quantity of radioactive material in any gas storage tanks exceeding the above limit, immediately suspend all additions of radioactive material to the tank. Within 48 hours reduce the tank contents to within the limits and describe the events leading to this condition in the next Radioactive Effluent Release Report, pursuant to Specification 6.9.1.8.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.11.2.6 The quantity of radioactive material contained in each gas storage tank on-service shall be determined to be within the above limit at least once per 7 days until the quantity exceeds 4.25×10^4 curies noble gases (50% of allowed limit) and then at least once per 24 hours when radioactive materials are being added to the tank. Tanks isolated for decay will be sampled to verify above limit is met within 24 hours following removal from service.

Pages 3/4 11-18 and 11-19 have been deleted.