

March 25, 1997

Mr. Charles M. Dugger
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

SUBJECT: CORRECTION TO AMENDMENT NO. 123 (TAC NO. M96365)

Dear Mr. Dugger:

On February 13, 1997, the Commission issued Amendment No. 123 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment changed the Appendix A Technical Specifications (TSs) by modifying TS 3/4.7.4, "Ultimate Heat Sinks," to incorporate more restrictive fan operability requirements and lower the maximum allowed basin temperature.

After issuance, it was discovered that TS page 3/4 7-14 contained a typographical error introduced by the NRC Staff. The 9* under WET COOLING TOWER should be removed.

Also, on TS page B 3/4 7-4 (third paragraph) "ACTION e" should read "ACTION c". This is an editorial change covered by this amendment; however, your application failed to identify and the staff did not detect this error. We are enclosing the corrected TS pages and we regret any inconvenience these may have caused you.

Sincerely,

Original Signed By:
Chandu P. Patel, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: Corrected TS Pages

NRC FILE CENTER COPY

cc w/encl: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f
CHawes	CPatel	ACRS
OGC (15B18)	GHill	JDyer, RIV
CGrimes	JRoe	JKilcrease, RIV f/r
LHurley, RIV	EAdensam(EGA1)	

Document Name: WAT96365.COR *See previous concurrence

OFC	PM/PD4-1	LA/PD4-1	OGC*
NAME	CPatel <i>CP</i>	CHawes <i>cmh</i>	APH
DATE	3/25/97	3/24/97	03/14/97
COPY	(YES)NO	YES/NO	YES/NO

DFel
1/1

OFFICIAL RECORD COPY

9703270195 970325
PDR ADOCK 05000382
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 25, 1997

Mr. Charles M. Dugger
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

SUBJECT: CORRECTION TO AMENDMENT NO. 123 (TAC NO. M96365)

Dear Mr. Dugger:

On February 13, 1997, the Commission issued Amendment No. 123 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment changed the Appendix A Technical Specifications (TSs) by modifying TS 3/4.7.4, "Ultimate Heat Sinks," to incorporate more restrictive fan operability requirements and lower the maximum allowed basin temperature.

After issuance, it was discovered that TS page 3/4 7-14 contained a typographical error introduced by the NRC Staff. The 9* under WET COOLING TOWER should be removed.

Also, on TS page B 3/4 7-4 (third paragraph) "ACTION e" should read "ACTION c". This is an editorial change covered by this amendment; however, your application failed to identify and the staff did not detect this error. We are enclosing the corrected TS pages and we regret any inconvenience these may have caused you.

Sincerely,

Chandu P. Patel

Chandu P. Patel, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: Corrected TS Pages

cc w/encl: See next page

Mr. Charles M. Dugger
Entergy Operations, Inc.

Waterford 3

cc:

Administrator
Louisiana Radiation Protection Division
Post Office Box 82135
Baton Rouge, LA 70884-2135

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Vice President, Operations
Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, LA 70066

Director
Nuclear Safety & Regulatory Affairs
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, LA 70057

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Executive Vice-President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

General Manager Plant Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, LA 70825-1697

Licensing Manager
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

9703280208 970325
PDR ADDCK 05000382
PDR

TABLE 3.7-3

ULTIMATE HEAT SINK MINIMUM FAN REQUIREMENTS PER TRAIN

<u>AMBIENT CONDITION</u>	<u>DRY COOLING TOWER</u>			
	<u>DRY BULB \geq 98°F</u>	<u>< 98°F DRY BULB \geq 91°F</u>	<u>< 91°F DRY BULB \geq 77°F</u>	<u>DRY BULB < 77°F</u>
<u>Fan Requirements⁽¹⁾</u>	15	14*	12*	9*

<u>AMBIENT CONDITION</u>	<u>WET COOLING TOWER</u>		
	<u>WET BULB \geq 75°F</u>	<u>< 75°F WET BULB \geq 70°F</u>	<u>WET BULB < 70°F</u>
<u>Fan Requirements⁽¹⁾</u>	8	7**	4**

(1) With any of the above required UHS fan inoperable comply with ACTION d.

* With a tornado watch in effect, all 9 DCT fans under the missile protected portion of the DCT shall be OPERABLE.

** With any WCT fan(s) out-of-service in any cell, covers must be in place on the out-of-service fan(s) or the entire cell (i.e. 4 fans) must be declared out-of-service. If four fans are out of service in the same cell, the covers do not have to be installed.

PLANT SYSTEMS
BASES

3/4.7.4 ULTIMATE HEAT SINK

The limitations on the ultimate heat sink level, temperature, and number of fans ensure that sufficient cooling capacity is available to either (1) provide normal cooldown of the facility, or (2) to mitigate the effects of accident conditions within acceptable limits.

The UHS consists of two dry cooling towers (DCTs), two wet cooling towers (WCTs), and water stored in WCT basins. Each of two 100 percent capacity loops employs a dry and wet cooling tower.

Each DCT consists of five separate cells. Cooling air for each cell is provided by 3 fans, for a total of 15 per DCT. The cooling coils on three cells of each DCT (i.e. 60%) are protected from tornado missiles by grating located above the coils and capable of withstanding tornado missile impact. With a Tornado Watch in effect and the number of fans OPERABLE within the missile protected area of a DCT less than that required by Table 3.7-3, ACTION c requires the restoration of inoperable fans within 1 hour or plant shutdown as specified. This ACTION is based on FSAR analysis (subsection 9.2.5.3.3) that assumes the worst case single failure as, 1 emergency diesel generator coincident with a loss of offsite power. This failure occurs subsequent to a tornado strike and 60% cooling capacity of a DCT is assumed available.

Each WCT has a basin which is capable of storing sufficient water to bring the plant to safe shutdown under all accident conditions. Item a of LCO 3/4.7.4 requires a minimum water level in each WCT basin of 97% (-9.86 ft MSL). The bases for this elevation is WCT water evaporation and drift loss calculations, which concluded that during a LOCA 168,738 gallons would be consumed from one WCT basin. When the WCT basin water level is maintained at -9.86 ft MSL, each basin has a minimum capacity of 174,000 gallons. Each WCT consists of two cells, each cell is serviced by 4 induced draft fans, for a total of 8 per WCT. There is a concrete partition between the cells that prevents air recirculation between the fans of each cell. Covers are required on fans declared out-of-service to prevent air recirculation between fans within a cell.

Table 3.7-3 specifies increased or decreased fan OPERABILITY requirements based on outside air temperature and humidity. The table provides the cooling tower fan OPERABILITY requirements that may vary with outside ambient conditions. Fan OPERABILITY requirements are specified for each controlling parameter (i.e., dry bulb temperatures for DCT fans and wet bulb temperatures for WCT fans). The calculated temperature values (EC-M95-009) associated with DCT and WCT fan requirements have been rounded in the conservative direction and lowered one full degree to account for minor inaccuracies. Failure to meet the OPERABILITY requirements of Table 3.7-3 requires entry into the applicable action. Because temperature and humidity are subject to change during the day, ACTION d requires periodic temperature readings to verify compliance with Table 3.7-3 when any cooling tower fan is inoperable.

The limitations on minimum water level and maximum temperature are based on providing a 30-day cooling water supply to safety-related equipment without exceeding their design basis temperature and is consistent with the recommendations of Regulatory Guide 1.27, "Ultimate Heat Sink for Nuclear Plants," March 1974.