

April 18, 1995

Mr. C. Lance Terry  
Group Vice President, Nuclear  
TU Electric  
Energy Plaza  
1601 Bryan Street, 12th Floor  
Dallas, TX 75201-3411

SUBJECT: CORRECTION TO AMENDMENTS NOS. 36 AND 22 TO FACILITY OPERATING  
LICENSE NOS. NPF-87 AND NPF-89 - COMANCHE PEAK STEAM ELECTRIC  
STATION, UNITS 1 AND 2 (TAC NOS. M88952 AND M88953)

Dear Mr. Terry:

On April 4, 1995, the Commission issued Amendment Nos. 36 and 22 to Facility  
Operating License Nos. NPF-87 and NPF-89 for the Comanche Peak Steam Electric  
Station, Units 1 and 2. The amendments revised Technical Specification (TS)  
3/4.2.4, "Quadrant Power Tilt Ratio."

Corrections are being made to TS page 3/4 3-5 to delete Table Notations e and  
h and remove the footnote at the bottom of the page. Those items that were  
originally deleted and removed as part of Amendment Nos. 20 and 6 were  
inadvertently reinserted to the page issued on April 4, 1995.

Overleaf TS page 3/4 3-6 is also being reissued for completeness. Please  
accept our apology for any inconvenience these errors may have caused you.

Sincerely,

ORIGINAL SIGNED BY:

Timothy J. Polich, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Revised TS page 3/4 3-5

cc w/encl: See next page

DISTRIBUTION:

Docket File OGC  
PUBLIC GHill (4)  
PDIV-1 R/F CGrimes  
EAdensam ACRS (4)  
WBeckner OPA  
PNoonan OC/LFDCB  
TPolich ABeach, RIV

G:\VWPKN\CP88952.COR

OFC	LA/PD4-1	PM/PD4-1
NAME	PNoonan	TPolich:mk
DATE	4/18/95	4/18/95
COPY	(YES) NO	YES/NO

**NUC FILE CENTER COPY**

9504210229 950418  
PDR ADDCK 05000445  
P PDR

OFFICIAL RECORD COPY

*DF01*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 18, 1995

Mr. C. Lance Terry  
Group Vice President, Nuclear  
TU Electric  
Energy Plaza  
1601 Bryan Street, 12th Floor  
Dallas, TX 75201-3411

SUBJECT: CORRECTION TO AMENDMENTS NOS. 36 AND 22 TO FACILITY OPERATING  
LICENSE NOS. NPF-87 AND NPF-89 - COMANCHE PEAK STEAM ELECTRIC  
STATION, UNITS 1 AND 2 (TAC NOS. M88952 AND M88953)

Dear Mr. Terry:

On April 4, 1995, the Commission issued Amendment Nos. 36 and 22 to Facility Operating License Nos. NPF-87 and NPF-89 for the Comanche Peak Steam Electric Station, Units 1 and 2. The amendments revised Technical Specification (TS) 3/4.2.4, "Quadrant Power Tilt Ratio."

Corrections are being made to TS page 3/4 3-5 to delete Table Notations e and h and remove the footnote at the bottom of the page. Those items that were originally deleted and removed as part of Amendment Nos. 20 and 6 were inadvertently reinserted to the page issued on April 4, 1995.

Overleaf TS page 3/4 3-6 is also being reissued for completeness. Please accept our apology for any inconvenience these errors may have caused you.

Sincerely,

A handwritten signature in cursive script, appearing to read "Timothy J. Polich".

Timothy J. Polich, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Revised TS page 3/4 3-5

cc w/enc1: See next page

Mr. C. Lance Terry  
TU Electric Company

Comanche Peak, Units 1 and 2

cc:  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 1029  
Granbury, TX 76048

Chief, Texas Bureau of Radiation  
Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

Honorable Dale McPherson  
County Judge  
P. O. Box 851  
Glen Rose, TX 76043

Mrs. Juanita Ellis, President  
Citizens Association for Sound Energy  
1426 South Polk  
Dallas, TX 75224

Office of the Governor  
ATTN: Susan Rieff, Director  
Environmental Policy  
P. O. Box 12428  
Austin, TX 78711

Mr. Roger D. Walker, Manager  
Regulatory Affairs for Nuclear  
Engineering Organization  
Texas Utilities Electric Company  
1601 Bryan Street, 12th Floor  
Dallas, TX 75201-3411

Texas Utilities Electric Company  
c/o Bethesda Licensing  
3 Metro Center, Suite 610  
Bethesda, MD 20814

William A. Burchette, Esq.  
Counsel for Tex-La Electric  
Cooperative of Texas  
Jordan, Schulte, & Burchette  
1025 Thomas Jefferson Street, N.W.  
Washington, DC 20007

GDS Associates, Inc.  
Suite 720  
1850 Parkway Place  
Marietta, GA 30067-8237

Jack R. Newman, Esq.  
Newman, Bouknight, & Edgar, P.C.  
1615 L Street, N.W.  
Suite 1000  
Washington, DC 20036

TABLE 3.3-1 (Continued)

TABLE NOTATIONS

<sup>a</sup>Only if the reactor trip breakers happen to be in the closed position and the Control Rod Drive System is capable of rod withdrawal.

<sup>b</sup>Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

<sup>c</sup>Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

<sup>d</sup>Above the P-7 (At Power) Setpoint

<sup>e</sup>Deleted.

<sup>f</sup>Above the P-8 (3-loop flow permissive) Setpoint.

<sup>g</sup>Above the P-7 and below the P-8 Setpoints.

<sup>h</sup>Deleted.

<sup>i</sup>Above the P-9 (Reactor trip on Turbine trip Interlock) Setpoint.

ACTION STATEMENTS

ACTION 1 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in HOT STANDBY within the next 6 hours.

ACTION 2 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours,
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1, and
- c. Either, THERMAL POWER is restricted to less than or equal to 75% of RATED THERMAL POWER and the Power Range Neutron Flux Trip Setpoint is reduced to less than or equal to 85% of RATED THERMAL POWER within 4 hours; or, the QUADRANT POWER TILT RATIO is monitored at least once per 12 hours per Specification 4.2.4.1.

COMANCHE PEAK - UNITS 1 AND 2

3/4 3-5

Unit 1 - Amendment No. ~~10,14,16,20,36~~  
Unit 2 - Amendment No. ~~2,6,22~~

9504240240

9504240240 950418  
PDR ADOCK 05000445  
P PDR