

Mr. C. Lance Terry
TU Electric
Senior Vice President & Principal Nuclear Officer
Attn: Regulatory Affairs Department
P. O. Box 1002
Glen Rose, TX 76043

June 15, 1998

SUBJECT: CORRECTION LETTER TO COMANCHE PEAK STEAM ELECTRIC STATION,
UNITS 1 AND 2 - AMENDMENT NOS. 60 AND 46 TO FACILITY OPERATING
LICENSE NOS. NPF-87 AND NPF-89 (TAC NOS. M92338 AND M92339)
(CORRECTION)

Dear Mr. Terry:

On May 22, 1998, the Commission issued Amendment Nos. 60 and 46 to Facility Operating License Nos. NPF-87 and NPF-89 for the Comanche Peak Steam Electric Station, Units 1 and 2. This amendment consists of changes to the minimum Fuel Storage System volume Technical Specifications (TSs) in response to your application dated May 1, 1995 (TX-95090).

Amendment Nos. 60 and 46 were issued with a typographical error on TS page 3/4 8-10a, that was introduced by the NRC. TS 3.8.1.2 Limiting Condition for Operation d. should have read 65,600 gallons instead of 65,000 gallons. The corrected page is enclosed.

We regret any inconvenience this oversight may have caused. If you have any questions on this action, please call me at 301-415-1038.

Sincerely,
ORIGINAL SIGNED BY:
Timothy J. Polich, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: TS page 3/4 8-10a

cc w/encl: See next page

DISTRIBUTION:

Docket File	OGC	PUBLIC	GHill (4)	ACRS
TPolich (2)	TGwynn, RIV	WBeckner	PDIV-1 r/f	CHawes
LHurley, RIV	JKilcrease, RIV f/r	EAdensam (EGA1)	THarris (TLH3)	DShum
LMarsh	JCalvo	TCollins		

Document Name: CP92338.COR

OFC	PM/PD4-1	LA/PD4-1	OGC <i>AKO</i>	PD/PDIV-1
NAME	TPolich <i>TP</i>	CHawes <i>CMN</i>	<i>M7/Hung</i>	JHannon
DATE	6/11/98	6/11/98	6/12/98	6/15/98
COPY	YES/NO	YES/NO	YES/NO	YES/NO

signed TJP
6/16/98
OFFICIAL RECORD COPY

9806220348 980615
PDR ADOCK 05000445
P PDR

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED

CPI



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 15, 1998

Mr. C. Lance Terry
TU Electric
Senior Vice President & Principal Nuclear Officer
Attn: Regulatory Affairs Department
P. O. Box 1002
Glen Rose, TX 76043

SUBJECT: CORRECTION LETTER TO COMANCHE PEAK STEAM ELECTRIC STATION,
UNITS 1 AND 2 - AMENDMENT NOS. 60 AND 46 TO FACILITY OPERATING
LICENSE NOS. NPF-87 AND NPF-89 (TAC NOS. M92338 AND M92339)
(CORRECTION)

Dear Mr. Terry:

On May 22, 1998, the Commission issued Amendment Nos. 60 and 46 to Facility Operating License Nos. NPF-87 and NPF-89 for the Comanche Peak Steam Electric Station, Units 1 and 2. This amendment consists of changes to the minimum Fuel Storage System volume Technical Specifications (TSs) in response to your application dated May 1, 1995 (TXX-95090).

Amendment Nos. 60 and 46 were issued with a typographical error on TS page 3/4 8-10a, that was introduced by the NRC. TS 3.8.1.2 Limiting Condition for Operation d. should have read 65,600 gallons instead of 65,000 gallons. The corrected page is enclosed.

We regret any inconvenience this oversight may have caused. If you have any questions on this action, please call me at 301-415-1038.

Sincerely,

A handwritten signature in cursive script, reading "Timothy J. Polich", is positioned above the typed name.

Timothy J. Polich, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: TS page 3/4 8-10a

cc w/encl: See next page

Mr. C. Lance Terry
TU Electric Company

Comanche Peak, Units 1 and 2

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2159
Glen Rose, TX 76403-2159

Honorable Dale McPherson
County Judge
P. O. Box 851
Glen Rose, TX 76043

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, TX 75224

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Mr. Roger D. Walker
TU Electric
Regulatory Affairs Manager
P. O. Box 1002
Glen Rose, TX 76043

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 810
Bethesda, MD 20814

George L. Edgar, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

ELECTRICAL POWER SYSTEMS

A.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

- d. With the Fuel Storage System volume less than 75,000 gallons but greater than 65,600 gallons of fuel for the diesel generator, restore the Storage System fuel oil level to a minimum volume of 75,000 gallons within 48 hours or immediately declare the diesel generator inoperable and perform ACTION a.
- e. With the Fuel Storage System volume equal to 65,600 gallons or less, immediately declare the diesel generator inoperable and perform ACTION a.

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the requirements of Specifications 4.8.1.1.1 and 4.8.1.1.2* (except for Specification 4.8.1.1.2a.5).

*The 18 month surveillance test interval is extended to 24 months for Train A, Unit 2, to remain in effect until the completion of the second refueling outage for Unit 2.

COMANCHE PEAK - UNITS 1 & 2

3/4 8-10a

Unit 1 - Amendment No. 43, 60
Unit 2 - Amendment No. 29, 46

9806220362 980615
PDR ADOCK 05000445
P PDR