

Mr. C. Lance Terry
 TU Electric
 Group Vice President, Nuclear
 Attn: Regulatory Affairs Department
 P. O. Box 1002
 Glen Rose, TX 76043

March 23, 1998

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR HEARING - COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. MA1241 AND MA1242)

Dear Mr. Terry:

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing." This notice relates to your application for amendment dated March 12, 1998. The proposed amendment would provide a temporary Technical Specification change for Surveillance Requirements 4.8.1.1.2f.4)b) and 4.8.1.1.2f.6)b) to allow the verification of the auto connected shut-down loads through the load sequencer to be performed at power for fuel cycle 6 on Unit 1 and fuel cycle 4 on Unit 2.

Sincerely,
ORIGINAL SIGNED BY:
 Thomas W. Alexion, Project Manager
 Project Directorate IV-1
 Division of Reactor Projects III/IV
 Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Notice of Consideration

cc w/encl: See next page

DISTRIBUTION:

Docket File	OGC	PUBLIC	GHill (4)
ACRS	TPolich (2)	TGwynn, RIV	PDIV-1 r/f
CHawes	JHannon	EAdensam (EGA1)	

Document Name: CPMA1241.IND

OFC	PM/PD4-1	LA/PD4-1	D/PDIV-1
NAME	TPolich/vw	CHawes	JHannon
DATE	3/23/98	3/23/98	3/23/98
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

9803270300 980323
 PDR ADOCK 05000445
 P PDR

DF 01

THIS IS A COPY

CP-1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 23, 1998

Mr. C. Lance Terry
TU Electric
Group Vice President, Nuclear
Attn: Regulatory Affairs Department
P. O. Box 1002
Glen Rose, TX 76043

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR HEARING - COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. MA1241 AND MA1242)

Dear Mr. Terry:

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing." This notice relates to your application for amendment dated March 12, 1998. The proposed amendment would provide a temporary Technical Specification change for Surveillance Requirements 4.8.1.1.2f.4)b) and 4.8.1.1.2f.6)b) to allow the verification of the auto connected shut-down loads through the load sequencer to be performed at power for fuel cycle 6 on Unit 1 and fuel cycle 4 on Unit 2.

Sincerely,

A handwritten signature in cursive script that reads "Thomas W. Alexion".

Thomas W. Alexion, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Notice of Consideration

cc w/encl: See next page

Mr. C. Lance Terry
TU Electric Company

Comanche Peak, Units 1 and 2

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2159
Glen Rose, TX 76403-2159

Honorable Dale McPherson
County Judge
P. O. Box 851
Glen Rose, TX 76043

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, TX 75224

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Mr. Roger D. Walker
TU Electric
Regulatory Affairs Manager
P. O. Box 1002
Glen Rose, TX 76043

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326

Texas Utilities Electric Company
c/o Bethesda Licensing
3 Metro Center, Suite 810
Bethesda, MD 20814

George L. Edgar, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

UNITED STATES NUCLEAR REGULATORY COMMISSIONTEXAS UTILITIES ELECTRICDOCKET NOS. 50-445 AND 50-446NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License Nos. NPF-87 and NPF-89, issued to Texas Utilities Electric Company, (TU Electric, the licensee), for operation of the Comanche Peak Steam Electric Station, Units 1 and 2, located in Somervell County, Texas.

The proposed amendment would provide a temporary Technical Specification change for Surveillance Requirements (SRs) 4.8.1.1.2f.4)b) and 4.8.1.1.2f.6)b) to allow the verification of the auto connected shut-down loads through the load sequencer to be performed at power for fuel cycle 6 on Unit 1 and fuel cycle 4 on Unit 2. The temporary change is requested as a result of the discovery that some of the safety injection (SI) and blackout (BO) sequencer block contacts had not been tested in accordance with the above SRs. These surveillances were performed during the last refueling outage for each unit as part of the integrative tests. However, it was subsequently discovered that some of the sequencer loads had parallel starting paths such that it could not be determined, based only on the observation that the equipment had successfully started, that the specific contacts required to be tested had in fact operated. In addition, verification of testing of certain contacts was missing. This was reported promptly to the NRC at the time of discovery and prompt action to remedy the situation was taken.

The licensee requested a Notice of Enforcement Discretion (NOED) by letter dated

March 10, 1998. The NRC orally issued the NOED at 9:25 a.m. EST on March 11, 1998, to allow the facility to continue operation while the TS is processed. Pursuant to the NRC's policy regarding exercise of discretion for an operating facility, set out in Section VII.c, of the "General Statement of Policy and Procedures for NRC Enforcement Actions" (Enforcement Policy), NUREG-1600, the letter documenting the issuance of the NOED was dated March 13, 1998. The NOED was to be effective for the period of time it takes the NRC staff to process the proposed change to the TSs on an exigent bases.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

Pursuant to 10 CFR 50.91(a)(6) for amendments to be granted under exigent circumstances, the NRC staff must determine that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Do the proposed changes involve a significant increase in the probability or consequences of an accident previously evaluated?

Crediting the at power performance of the portions of surveillance testing necessary to demonstrate the OPERABILITY of the SI and BO Sequencer block contacts, will not increase the probability or consequences of an accident previously evaluated. The conclusion has been reached that the probability of initiating a perturbation in the A.C. electrical distribution system is not created via the crediting of the tests. As the testing is conducted on only one train per unit at a given time, no increase in consequences, other than those previously postulated, are considered credible.

2. Do the proposed changes create the possibility of a new or different kind of accident from any accident previously evaluated?

Perturbations in the A.C. electrical distribution system have been fully considered within the Final Safety Analysis Report. No new or different kind of perturbation or accident is deemed credible from crediting the performance of the testing.

3. Do the proposed changes involve a significant reduction in a margin of safety?

Crediting the required testing at power does not create any new failure scenarios or A.C. electrical distribution perturbations, no associated margin is expected to be reduced. As such, there is no reduction in any margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 14 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 14-day notice period. However, should circumstances change during the notice period, such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 14-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the FEDERAL REGISTER a notice of issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page

number of this FEDERAL REGISTER notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By April 13, 1998, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the University of Texas at Arlington Library, Government Publications/Maps, 702 College, P.O. Box 19497, Arlington, TX 76019. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the

petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If the amendment is issued before the expiration of the 30-day hearing period, the Commission will make a final determination on the issue of no significant hazards consideration. If a hearing is requested, the final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.


A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to George L. Edgar, Esq., Morgan, Lewis and Bockius, 1800 M Street, N.W., Washington, DC 20036, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated March 12, 1998, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room, located at the University of Texas at Arlington Library, Government Publications/Maps, 702 College, P.O. Box 19497, Arlington, TX 76019.

Dated at Rockville, Maryland, this 23rd day of March 1998.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script that reads "Thomas W. Alexion".

Thomas W. Alexion, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation