(1 Apri⁷ 1, 1995

Mr. C. Lance Terry Group Vice President, Nuclear TU Electric Energy Plaza 1601 Bryan Street, 12th Floor Dallas, TX 75201-3411

SUBJECT: CORRECTION TO AMENDMENT NOS. 49 AND 35 TO FACILITY OPERATING LICENSE NOS. NPF-87 AND NPF-89 - COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. M94167 AND M94204)

Dear Mr. Terry:

On April 1, 1996, the Commission issued Amendment Nos. 49 and 35 to Facility Operating License Nos. NPF-87 and NPF-89 for the Comanche Peak Steam Electric Station, Units 1 and 2. The amendments revised the core safety limit curves and revised N-16 Overtemperature reactor trip setpoints as a result of the reload analyses for CPSES Unit 2, Cycle 3. In addition, the minimum required Reactor Coolant System (RCS) flow was increased and an administrative enhancement was included in the footnotes of the RCS flow-low reactor trip function setpoint for both Units 1 and 2.

After issuance, it was discovered that the amendment numbers where missing from the two signed amendment pages. We are reissuing these two pages, resigned to maintain continuity. In addition, Technical Specification (TS) page 2-9 had a typographical error in that the number of a previous amendment on the bottom of the page was incorrect. A correct TS page 2-9, as well as the overleaf page, are also enclosed. We regret any inconvenience this may have caused you.

Sincerely,

ORIGINAL SIGNED BY:

Timothy J. Polich, Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION:

Document Name:

OFC

NAME

DATE

COPY

Docket File	PUBLIC
GHill (4)	ACRS
CGrimes	JRoe
JWermiel	EAdensam(EGA1)
RJones	HBalukjian

CP94167.COR

OFFICIAL RECORD COPY

PM/PD4-1

4 /10/96

YES/NO

TPolich/vW

PDIV-1 r/f TPolich (2) PNoonan WBeckner

120017

OGC JDyer,RIV LHurley, RIV JKilcrease, RIV

nng file geni

9604120318 960411 PDR ADOCK 05000445 PDR PDR

LA/PD4-J

PNoonan

YES/NO

/96



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 11, 1996

Mr. C. Lance Terry Group Vice President, Nuclear TU Electric Energy Plaza 1601 Bryan Street, 12th Floor Dallas, TX 75201-3411

SUBJECT: CORRECTION TO AMENDMENT NOS. 49 AND 35 TO FACILITY OPERATING LICENSE NOS. NPF-87 AND NPF-89 - COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. M94167 AND M94204)

Dear Mr. Terry:

On April 1, 1996, the Commission issued Amendment Nos. 49 and 35 to Facility Operating License Nos. NPF-87 and NPF-89 for the Comanche Peak Steam Electric Station, Units 1 and 2. The amendments revised the core safety limit curves and revised N-16 Overtemperature reactor trip setpoints as a result of the reload analyses for CPSES Unit 2, Cycle 3. In addition, the minimum required Reactor Coolant System (RCS) flow was increased and an administrative enhancement was included in the footnotes of the RCS flow-low reactor trip function setpoint for both Units 1 and 2.

After issuance, it was discovered that the amendment numbers where missing from the two signed amendment pages. We are reissuing these two pages, resigned to maintain continuity. In addition, Technical Specification (TS) page 2-9 had a typographical error in that the number of a previous amendment on the bottom of the page was incorrect. A correct TS page 2-9, as well as the overleaf page, are also enclosed. We regret any inconvenience this may have caused you.

Sincerely,

Timothy J. Polich, Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosures: As stated

cc w/encls: See next page

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-87 is hereby amended to read as follows:
 - 2. Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 49, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

1 monty & bleet

Timothy J. Polich, Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 1, 1996

9604120322 960411 PDR ADOCK 05000445 P PDR

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-89 is hereby amended to read as follows:
 - (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 35, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Cantof Plut

Timothy J. Polich, Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 1, 1996

Mr. C. Lance Terry TU Electric Company

cc: Senior Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 1029 Granbury, TX 76048

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011

Mrs. Juanita Ellis, President Citizens Association for Sound Energy 1426 South Polk Dallas, TX 75224

Mr. Roger D. Walker, Manager Regulatory Affairs for Nuclear Engineering Organization Texas Utilities Electric Company 1601 Bryan Street, 12th Floor Dallas, TX 75201-3411

Texas Utilities Electric Company c/o Bethesda Licensing 3 Metro Center, Suite 610 Bethesda, MD 20814

George L. Edgar, Esq. Morgan, Lewis & Bockius 1800 M Street, N.W. Washington, DC 20036-5869 Comanche Peak, Units 1 and 2

Honorable Dale McPherson County Judge P. O. Box 851 Glen Rose, TX 76043

Office of the Governor ATTN: Susan Rieff, Director Environmental Policy P. O. Box 12428 Austin, TX 78711

Arthur C. Tate, Director Division of Compliance & Inspection Bureau of Radiation Control Texas Department of Health 1100 West 49th Street Austin, TX 78756-3189

TABLE 2.2-1 (Continued) TABLE NOTATIONS

NOTE 1: Overtemperature N-16

•

$$N = K_1 - K_2 \left[\frac{1 + \tau_1 s}{1 + \tau_2 s} T_c - T_c^{\circ} \right] + K_3 (P - P^1) - f_1 (\Delta q)$$

Where:	N	 Measured N-16 Power by ion chambers,
	Τ _c	= Cold leg temperature, °F,
	T ^o c	= 560.5°F for Unit 1, 560.8°F for Unit 2 - Reference T_c at RATED THERMAL POWER,
	K ₁	= 1.150,
	K ₂	= 0.0134/°F for Unit 1 0.0138/°F for Unit 2
	$\frac{1+\tau_1 s}{1+\tau_2 s}$	 The function generated by the lead-lag controller for T_c dynamic compensation,
	τ ₁ , τ ₂	= Time constants utilized in the lead-lag controller for T_c , $\tau_1 \ge 10$ s, and $\tau_2 \le 3$ s,
	K ₃	= 0.000719/psig for Unit 1 0.000720/psig for Unit 2

COMANCHE PEAK - UNIT 1 AND 2

TABLE 2.2-1 (Continued)

TABLE NOTATIONS (Continued)

NOTE 1: (Continued)

- Pressurizer pressure, psig,
- ≥ 2235 psig (Nominal RCS operating pressure).
- = Laplace transform operator, s⁻¹,

and $f_1(\Delta q)$ is a function of the indicated difference between top and bottom halves of detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant STARTUP tests such that:

For Unit 1

Ρ

P¹

S

- (i) for $q_t q_b$ between -65% and +4%, $f_1(\Delta q) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER,
- (ii) for each percent that the magnitude of $q_t q_b$ exceeds -65%, the N-16 Trip Setpoint shall be automatically reduced by 1.81% of its value at RATED THERMAL POWER, and
- (iii) for each percent that the magnitude of $q_t q_b$ exceeds +4%, the N-16 Trip Setpoint shall be automatically reduced by 2.26% of its value at RATED THERMAL POWER.

COMANCHE PEAK - UNITS 1 AND 2

2-10

Unit 1 - Amendment No. 14, 21 Unit 2 - Amendment No. 7