

March 7, 1995

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: CORRECTION TO AMENDMENT NO. 60 (TAC NOS. M88540 AND M88541)

Dear Mr. Farrar:

By letter dated February 28, 1995, the NRC issued License Amendment No. 60 which, in addition to other subjects, approved the removal of Commonwealth Edison's (ComEd) commitment to demonstrate control room ventilation integrity as it relates to the chlorine intrusion from NUREG-1002, Supplement 3, "Safety Evaluation Report" dated May 1987.

The Safety Evaluation (SE) supporting the amendment indicated that the control room integrity was demonstrated annually; however, NUREG-1002, Supplement 3, had required ComEd to demonstrate containment integrity every 18 months. In order to remove the inconsistency between the interval periods, please replace the word "annually" with "every 18-months" in the February 28, 1995, SE as it relates to demonstration of control room integrity.

Please contact me at (301) 415-1391 if you need additional information.

Sincerely,

original signed by:

Ramin R. Assa, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-456 and STN 50-457

cc: see next page

<u>Distribution:</u>	Docket File	PUBLIC	PDIII-2 r/f
E. Adensam	R. Capra	C. Moore	R. Assa
OGC	G. Hill (4)	C. Grimes	ACRS (10)
OPA	OC/LFDCB	L. Miller RIII	

DOCUMENT NAME: BRAID\BR88540.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2	PM:PDIII-2	C	D:PDIII-2	E			
NAME	CMOORE <i>[Signature]</i>	RASSA:jar <i>[Signature]</i>		RCAPRA <i>[Signature]</i>				
DATE	03/9/95	03/07/95		03/7/95		03/ /95		03/ /95

OFFICIAL RECORD COPY

9503100221 950307  
PDR ADOCK 05000456  
P PDR

*[Handwritten signature]*  
1/0  
OFFICIAL RECORD COPY

March 7, 1995

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: CORRECTION TO AMENDMENT NO. 60 (TAC NOS. M88540 AND M88541)

Dear Mr. Farrar:

By letter dated February 28, 1995, the NRC issued License Amendment No. 60 which, in addition to other subjects, approved the removal of Commonwealth Edison's (ComEd) commitment to demonstrate control room ventilation integrity as it relates to the chlorine intrusion from NUREG-1002, Supplement 3, "Safety Evaluation Report" dated May 1987.

The Safety Evaluation (SE) supporting the amendment indicated that the control room integrity was demonstrated annually; however, NUREG-1002, Supplement 3, had required ComEd to demonstrate containment integrity every 18 months. In order to remove the inconsistency between the interval periods, please replace the word "annually" with "every 18-months" in the February 28, 1995, SE as it relates to demonstration of control room integrity.

Please contact me at (301) 415-1391 if you need additional information.

Sincerely,

original signed by:

Ramin R. Assa, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-456 and STN 50-457

cc: see next page

<u>Distribution:</u>	Docket File	PUBLIC	PDI-2 r/f
E. Adensam	R. Capra	C. Moore	R. Assa
OGC	G. Hill (4)	C. Grimes	ACRS (10)
OPA	OC/LFDCB	L. Miller RIII	

DOCUMENT NAME: BRAID\BR88540.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2	PM:PDIII-2	C	D:PDIII-2	E				
NAME	CMOORE <i>CMOORE</i>	RASSA:jar <i>JA</i>		RCAPRA <i>RC</i>					
DATE	03/7/95	03/07/95		03/7/95		03/ /95		03/ /95	

OFFICIAL RECORD COPY

D. L. Farrar  
Commonwealth Edison Company

Braidwood Station  
Unit Nos. 1 and 2

cc:

Mr. William P. Poirier  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
Post Office Box 355, Bay 236 West  
Pittsburgh, Pennsylvania 15230

Chairman  
Will County Board of Supervisors  
Will County Board Courthouse  
Joliet, Illinois 60434

Joseph Gallo  
Gallo & Ross  
1250 Eye St., N.W., Suite 302  
Washington, DC 20005

Ms. Lorraine Creek  
Rt. 1, Box 182  
Manteno, Illinois 60950

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Attorney General  
500 South Second Street  
Springfield, Illinois 62701

Ms. Bridget Little Rorem  
Appleseed Coordinator  
117 North Linden Street  
Essex, Illinois 60935

Michael Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60690

Howard A. Learner  
Environmental Law and Policy  
Center of the Midwest  
203 North LaSalle Street  
Suite 1390  
Chicago, Illinois 60601

George L. Edgar  
Newman & Holtzinger, P.C.  
1615 L Street, N.W.  
Washington, DC 20036

U.S. Nuclear Regulatory Commission  
Braidwood Resident Inspectors Office  
Rural Route #1, Box 79  
Braceville, Illinois 60407

Illinois Dept. of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Mr. Ron Stephens  
Illinois Emergency Services  
and Disaster Agency  
110 East Adams Street  
Springfield, Illinois 62706

Commonwealth Edison Company  
Braidwood Station Manager  
Rt. 1, Box 84  
Braceville, Illinois 60407

EIS Review Coordinator  
U.S. Environmental Protection Agency  
77 W. Jackson Blvd.  
Chicago, Illinois 60604-3590