

March 15, 1989

Docket No. 50-440

Mr. Alvin Kaplan, Vice President
Nuclear Group
The Cleveland Electric
Illuminating Company
10 Center Road
Perry, Ohio 44081

DISTRIBUTION

Docket File	OGC
NRC & Local PDRs	EJordan
PDIII-3 r/f	BGrimes
GHolahan	ACRS(10)
MVirgilio	GPA/PA
PKreutzer	PDIII-3 Gray File
TColburn	

Dear Mr. Kaplan:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT
IMPACT - TS CHANGE REQUEST - CONTAINMENT ISOLATION VALVE
TESTING WITH PRIMARY CONTAINMENT INTEGRITY-SHUTDOWN
(TAC NO. 71767) PERRY UNIT 1

Enclosed for your information is a copy of an "Environmental Assessment
and Finding of No Significant Impact" relating to your application dated
December 29, 1988 for amendment to Facility Operating Licensee No. NPF-58 for
the Perry Nuclear Power Plant, Unit No. 1. This assessment was forwarded to
the Office of the Federal Register for publication.

Sincerely,

/s/

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure
See next page

Office: LA/PDIII-3
Surname: PKreutzer
Date: 3/16/89

Rec
PM/PDIII-3
TColburn/mr
3/13/89

Rec for
PD/PDIII-3
JHannon
3/13/89

OGC
s H Lewis
3/15/89

*No legal objection if
changes noted are
made.*

*DFol
11*

8903230388 090316
FIR ADOCK 05000440
F PDC

Mr. Alvin Kaplan
The Cleveland Electric
Illuminating Company

cc: Jay E. Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

David E. Burke
The Cleveland Electric
Illuminating Company
P.O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Parmlly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Frank P. Weiss, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

Robert A. Newkirk
Cleveland Electric
Illuminating Company
Perry Nuclear Power Plant
P. O. Box 97 E-210
Perry, Ohio 44081

Perry Nuclear Power Plant
Unit 1

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P. O. Box 825
Columbus, Ohio 43216

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Ohio Environmental Protection
Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Mr. Phillip S. Haskell, Chairman
Perry Township Board of Trustees
Box 65
4171 Main Street
Perry, Ohio 44081

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Michael D. Lyster
Cleveland Electric
Illuminating Company
Perry Nuclear Power Plant
P. O. Box 97 SB306
Perry, Ohio 44081

UNITED STATES NUCLEAR REGULATORY COMMISSION
THE CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.
DOCKET NO. 50-440
ENVIRONMENTAL ASSESSMENT AND FINDING OF
NO SIGNIFICANT IMPACT

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-58, issued to The Cleveland Electric Illuminating Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company and Toledo Edison Company (the licensees), for operation of the Perry Nuclear Power Plant, Unit No. 1, located in Lake County, Ohio.

ENVIRONMENTAL ASSESSMENT

Identification of Proposed Action

The proposed amendment would revise the provisions in the Technical Specifications (TS) relating to the definition of Primary Containment Integrity - Shutdown to provide limited flexibility during performance of 10 CFR Part 50 Appendix J Type C leak rate testing of containment isolation valves to allow one (1) or two (2) 3/4-inch vent and drain lines to be open on those penetrations that would otherwise not be testable when this specification is applicable.

The proposed action is in accordance with the licensees' application for amendment dated December 29, 1988.

The Need for the Proposed Action

The proposed change to the TS is required in order to provide the licensees flexibility to perform Type C local leak rate tests required by 10 CFR Part 50 Appendix J which would otherwise not be able to be performed when Primary Containment Integrity-Shutdown must be maintained. Performance of local leak rate testing activities when this specification is applicable has the potential to reduce outage durations by increasing the time available to perform this potential critical path testing activity and to permit additional time for isolation valve repair and retesting, if required, subsequent to initial testing and surveillance.

Environmental Impacts of the Proposed Action

The Commission has completed its evaluation of the proposed revision to TS and concludes that the calculated offsite doses, assuming a postulated fuel handling accident while the two lines are open and using a 15-day decay time (minimum time between start of the refueling outage and conduct of Type C local leak rate testing) are well within the dose reference values of 10 CFR Part 100 and are within the acceptance criteria given in Standard Review Plan Section 15.7.4. Accordingly, the Commission concludes that this proposed action would result in no significant radiological environmental impact during the first refueling outage. Permanent TS changes using a 24-hour decay time which would be applicable to subsequent outages, will be the subject of future correspondence.

The Notice of Consideration of Issuance of Amendment and Opportunity for Prior Hearing in connection with this action was published in the Federal

Register on January 19, 1989 (54 FR 2246). No request for hearing or petition for leave to intervene was filed following this notice.

With regard to potential nonradiological impacts, the proposed change to the TS involves a change to surveillance and testing requirements, specifically with regard to maintaining containment integrity while moving fuel. It does not affect nonradiological plant effluents and has no other environmental impact. Therefore, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed amendment.

Alternative to the Proposed Action

Since the Commission concluded that there are no significant environmental effects that would result from the proposed action, any alternatives with equal or greater environmental impacts need not be evaluated.

The principal alternative would be to deny the requested amendment. This would not reduce environmental impacts of plant operation and would result in reduced operational flexibility.

Alternative Use of Resources

This action does not involve the use of any resources not previously considered in the Final Environmental Statements Related to Operation of Perry Nuclear Power Plant, Units 1 and 2, dated August 1987.

Agencies and Persons Consulted

The NRC staff reviewed the licensees' request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed license amendment.

Based upon the foregoing environmental assessment, we conclude that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the application - for amendment dated December 29, 1988, which is available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C. and at the Perry Public Library, 3753 Main Street, Perry, Ohio 44081.

Dated at Rockville, Maryland, this 15th day of March 1989.

FOR THE NUCLEAR REGULATORY COMMISSION

Timothy G. Colburn

Timothy G. Colburn, Acting Director
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation