

Docket No. 50-440

DISTRIBUTION:

<u>Docket Files</u>	NRC & Local PDRs
PDIII-3 r/f	KPerkins
PKreutzer	TColburn
GHolahan	OGC-WF1
EJordan	BGrimes
ACRS(10)	PDIII-3 Gray Files

Mr. Alvin Kaplan, Vice President
 Nuclear Group
 The Cleveland Electric Illuminating
 Company
 10 Center Road
 Perry, Ohio 44081

Dear Mr. Kaplan:

Enclosed is a copy of an Environmental Assessment and Finding of No Significant Impact for your information. This assessment relates to your October 2, 1987 application for an amendment to Facility Operating License No. NPF-58, to revise the Environmental Protection Plan in Appendix B relating to surveillance requirements for monitoring of Corbicula at the Perry Nuclear Power Plant, Unit No. 1.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Timothy G. Colburn, Project Manager
 Project Directorate III-3
 Division of Reactor Projects - III,
 IV, V and Special Projects

Enclosure:
 As stated

cc: See next page

Office: LA/PDIII-3
 Surname: PKreutzer
 Date: 6/30/88

TGC
 PM/PDIII-3
 TColburn/tg
 6/30/88

[Signature]
 PD/PDIII-3
 KPerkins
 6/30/88

APH
 OGC
 7/05/88

BB07210339 BB0711
 PDR ADOCK 05000440
 P PNU

*DF01
 /11*



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 11, 1988

Docket No. 50-440

Mr. Alvin Kaplan, Vice President
Nuclear Group
The Cleveland Electric Illuminating
Company
10 Center Road
Perry, Ohio 44081

Dear Mr. Kaplan:

Enclosed is a copy of an Environmental Assessment and Finding of No Significant Impact for your information. This assessment relates to your October 2, 1987 application for an amendment to Facility Operating License No. NPF-58, to revise the Environmental Protection Plan in Appendix B relating to surveillance requirements for monitoring of Corbicula at the Perry Nuclear Power Plant, Unit No. 1.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script that reads "Timothy G. Colburn".

Timothy G. Colburn, Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

Mr. Alvin Kaplan
The Cleveland Electric
Illuminating Company

cc:
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

David E. Burke
The Cleveland Electric
Illuminating Company
P.O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Frank P. Weiss, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

Eileen M. Buzzelli
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Perry Nuclear Power Plant
Unit 1

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P.O. Box 825
Columbus, Ohio 43216

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Ohio Environmental Protection
Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Mr. Phillip S. Haskell, Chairman
Perry Township Board of Trustees
Box 65
4171 Main Street
Perry, Ohio 44081

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Mr. Murray R. Edelman
Centerior Energy
6200 Oaktree Blvd.
Independence, Ohio 44131

UNITED STATES NUCLEAR REGULATORY COMMISSION
THE CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.

DOCKET NO. 50-440

ENVIRONMENTAL ASSESSMENT AND FINDING OF

NO SIGNIFICANT IMPACT

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-58 issued to The Cleveland Electric Illuminating Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company and Toledo Edison Company (the licensees), for operation of the Perry Nuclear Power Plant, Unit No. 1, located in Lake County, Ohio.

ENVIRONMENTAL ASSESSMENT

Identification of Proposed Action

The proposed amendment would revise the Environmental Protection Plan in Appendix B of the Technical Specifications (TS) relating to the surveillance requirements for the monitoring of Corbicula. The principal change is a shift in the sampling area from the off-shore lake bottom adjacent to the Perry intake and discharge structures to sampling of sediments in the Perry raw water systems. The sampling procedures at the Eastlake Power Plant to detect the presence of Corbicula are also revised to use a hand dredge in lieu of SCUBA divers and suction devices.

The proposed action is in accordance with the licensees' application for amendment dated October 2, 1987.

The Need for the Proposed Action

The proposed change to the TS is required in order to take advantage of research conducted within the last few years which should improve the detection capability for the presence of Corbicula over that which currently exists.

Environmental Impacts of the Proposed Action

The Commission has completed its evaluation of the proposed revision to Technical Specifications. The proposed revision would provide a more effective and direct method for detecting the presence of Corbicula. This would reduce the likelihood of blockage of the Emergency Service Water System due to growth of water-borne organisms. Therefore, the proposed change does not increase the probability or consequences of accidents. No changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that this proposed action would result in no significant radiological environmental impact.

With regard to potential nonradiological impacts, the proposed change to the TS involves a change in sampling location from offshore lake bottom to a location within the restricted area as defined in 10 CFR Part 20. This would have less nonradiological impact than the current program. Additionally, use of a hand dredge instead of SCUBA divers with suction devices is proposed at the Eastlake Plant sampling location. The size of the hand dredge is small and the sampling frequency (semi-annually) is such that any additional impacts resulting from this change are considered very minor. It does not affect nonradiological plant effluents and has no other environmental impact. Therefore, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed amendment.

The Notice of Consideration of Issuance of Amendment and Proposed No Significant Hazards Determination in connection with this action was published in the Federal Register on March 9, 1988 (53 FR 7604). No request for hearing or petition for leave to intervene was filed following this notice.

Alternative to the Proposed Action

Since the Commission concluded that there are no significant environmental effects that would result from the proposed action, any alternatives with equal or greater environmental impacts need not be evaluated.

The principal alternative would be to deny the requested amendment. This would not reduce environmental impacts of plant operation and would result in a less effective Corbicula monitoring program than proposed.

Alternative Use of Resources

This action does not involve the use of any resources not previously considered in the Final Environmental Statements for the Perry Nuclear Power Plant, Units 1 and 2, dated August 1982.

Agencies and Persons Consulted

The NRC staff reviewed the licensees' request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed license amendment.

Based upon the foregoing environmental assessment, we conclude that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the application for amendment dated October 2, 1987 which is available for public inspection at the Commission's, Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Perry Public Library, 3753 Main Street, Perry, Ohio 44081.

Dated at Rockville, Maryland, this 8 day of July 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "Kenneth E. Perkins". The signature is written in a cursive style with a long, sweeping underline that extends to the right.

Kenneth E. Perkins, Director
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects