

October 21, 1993

Docket No. 50-440

Mr. Robert A. Stratman
Vice President Nuclear - Perry
Centerior Service Company
P.O. Box 97, S270
Perry, Ohio 44081

Dear Mr. Stratman:

SUBJECT: CORRECTION TO AMENDMENT NO. 51 - PERRY NUCLEAR POWER PLANT
(TAC NO. M83051)

The replacement page for the Perry, Unit 1, Technical Specifications (TSs) transmitted in Amendment No. 51 contained an error. Specifically, on TS page 3/4 3-75, the word "Suction" was inadvertently omitted from the line item "Shutdown Cooling Outboard Suction Isolation Valve," in Table 3.3.7.4-1.

Please replace page 3/4 3-75 (overleaf page 3/4 3-76 is included for your convenience) transmitted in Amendment No. 51 with the enclosed page. I apologize for any inconvenience caused by this oversight.

Sincerely,

Original Signed By:

Robert J. Stransky, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS Page 3/4 3-75

cc w/enclosure:
See next page

DISTRIBUTION

~~Docket File~~

J. Roe
R. Stransky
ACRS(10)
G. Hill (2)
OC/LFDCB

Local & NRC PDRs
J. Zwolinski
M. Rushbrook
E. Greenman, RIII
C. Grimes
M. Razzaque

PDIII-3 r/f
J. Hannon
OGC
A. Kugler
OPA
D. Hagan

OFFICE	LA:PDIII-3	PM:PDIII-3	D:PDIII-3
NAME	MRushbrook	RStransky	JHannon
DATE	10/21/93	10/21/93	10/21/93

OFFICIAL RECORD COPY

FILENAME: G:\PERRY\PER83051.ERR

9310270036 931021
CF ADDCK 05000440
CF

250014

DFX2
NRC FILE CENTER COPY



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**

WASHINGTON, D.C. 20555-0001

October 21, 1993

Docket No. 50-440

Mr. Robert A. Stratman
Vice President Nuclear - Perry
Centerior Service Company
P.O. Box 97, S270
Perry, Ohio 44081

Dear Mr. Stratman:

SUBJECT: CORRECTION TO AMENDMENT NO. 51 - PERRY NUCLEAR POWER PLANT
(TAC NO. M83051)

The replacement page for the Perry, Unit 1, Technical Specifications (TSs) transmitted in Amendment No. 51 contained an error. Specifically, on TS page 3/4 3-75, the word "Suction" was inadvertently omitted from the line item "Shutdown Cooling Outboard Suction Isolation Valve," in Table 3.3.7.4-1.

Please replace page 3/4 3-75 (overleaf page 3/4 3-76 is included for your convenience) transmitted in Amendment No. 51 with the enclosed page. I apologize for any inconvenience caused by this oversight.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Stransky", is written over a horizontal line.

Robert J. Stransky, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS Page 3/4 3-75

cc w/enclosure:
See next page

Mr. Robert A. Stratman
Centerior Service Company

cc:

Jay E. Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Mary E. O'Reilly
Centerior Energy Corporation
300 Madison Avenue
Toledo, Ohio 43652

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Parmlly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Lake County Prosecutor
Lake County Administration Bldg.
105 Main Street
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Memtor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street, Suite 105
Toledo, Ohio 43624

Ashtabula County Prosecutor
25 West Jefferson Street
Jefferson, Ohio 44047

Mr. Kevin P. Donovan
Cleveland Electric Illuminating Company
Perry Nuclear Power Plant
P. O. Box 97, E-210
Perry, Ohio 44081

James R. Williams, Chief of Staff
Ohio Emergency Management Agency
2825 West Granville Road
Worthington, Ohio 43085

Perry Nuclear Power Plant
Unit Nos. 1 and 2

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial Relations
P. O. Box 825
Columbus, Ohio 43216

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program
Ohio Department of Health
Post Office Box 118
Columbus, Ohio 43266-0118

Ohio Environmental Protection Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P. O. Box 1049
Columbus, Ohio 43266-0149

Mr. Thomas Haas, Chairman
Perry Township Board of Trustees
3750 Center Rd., Box 65
Perry, Ohio 44081

State of Ohio
Public Utilities Commission
East Broad Street
Columbus, Ohio 43266-0573

David P. Igyarto, General Manager
Cleveland Electric Illuminating Co.
Perry Nuclear Power Plant
P. O. Box 97, SB306
Perry, Ohio 44081

TABLE 3.3.7.4-1 (Continued)
REMOTE SHUTDOWN SYSTEM CONTROLS

<u>CONTROL</u>	<u>MINIMUM CHANNELS OPERABLE</u>	
	<u>Division 1</u>	<u>Division 2</u>
ESW Pump	1	1
ESW Pump Discharge Valve	1	1
RHR HX's ESW Inlet/Outlet Valves	2 ^(a)	2 ^(a)
RHR HX's Inlet/Outlet/Bypass Valves	3 ^(a)	3 ^(a)
RHR Pump	1	1
RHR to Containment Shutoff Valve	1	1
RHR Pump Suppression Pool Suction Valve	1	1
LPCI Injection Valve	1	1
RHR A Shutdown Cooling Suction Valve	1	NA
RHR Upper Pool Cooling Isolation Valve	1	1
RHR Head Spray Isolation Valve	1	NA
RHR HX's Dump Valve	1	1
Containment Spray First Shutoff	1	1
Shutdown Cooling to Feedwater Shutoff	1	1
RHR Test Valve to Suppression Pool	1	1
Shutdown Cooling Outboard Suction Isolation Valve	1	NA
RHR A to Radwaste Second Isolation Valve	1	NA
Steam Condensing Shutoff Valve to RCIC	1	1
RHR HX's Steam Shutoff Valve	1	1
RHR Pump Minimum Flow Valve	1	1
ECC Pump	1	1
RCIC Turbine Gland Seal Compressor	1	NA
RHR & RCIC Steam Supply Outboard Isolation Valve	1	NA
RCIC Second Test Valve to CST	1	NA
RCIC Turbine Trip	1	NA
RCIC Steam Shutoff Valve	1	NA
RCIC First Test Valve to CST	1	NA
RCIC Pump CST Suction Valve	1	NA
RCIC Injection Valve	1	NA
RCIC Pump Suppression Pool Suction Isolation Valve	1	NA
RCIC Turbine Trip Throttle Valve	1	NA
RCIC Pump Minimum Flow Valve	1	NA
RCIC Turbine Exhaust Shutoff Valve	1	NA
RCIC Exhaust Vacuum Breaker Outboard Isolation Valve	1	NA
RCIC Exhaust Vacuum Breaker Inboard Isolation Valve	NA	1*
RHR B Shutdown Cooling Suction Valve	NA	1*
Shutdown Cooling Inboard Suction Isolation Valve	NA	1*
RHR & RCIC Steam Supply Inboard Isolation Valve	NA	1*
RHR & RCIC Steam Supply Warmup Isolation Valve	NA	1*
Safety Relief Valves	3 ^(a)	3 ^(a)
Control Room to Shutdown Panel Transfer Switches	14	2*
APRM Power Supply Breakers	1** ^(b)	1** ^(b)
Inboard Main Steam Isolation Valve	NA	2 ^{(c)*}
Diesel Generator Room Fan 1A Temperature Controller	1	NA
Suppression Pool Cleanup Isolation Valve	1	NA

(a) 1 per valve

(b) One breaker constitutes one channel for ATWS Division 1 and Division 2.

(c) One switch for Solenoid "A" per 4 valves, one switch for Solenoid "B" per 4 valves.

* These Division 2 controls are physically located on the Division 1 panel.

** These breakers are physically located on ATWS Distribution Panels 1R14-S014 and 1R14-S015.