

February 7, 1995

Mr. Donald C. Shelton
Senior Vice President Nuclear
Centerior Service Company
P. O. Box 97, A200
Perry, OH 44081

SUBJECT: CORRECTIONS TO AMENDMENT NO. 67 AND AMENDMENT NO. 68 TO FACILITY
OPERATING LICENSE NO. NPF-58 - PERRY NUCLEAR POWER PLANT, UNIT NO. 1
(TAC NO. M84057 AND M90428)

Dear Mr. Sheldon:

The Commission issued Amendment No. 67 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit No. 1 on November 22, 1994. The amendment revised the Technical Specifications (TS) in response to your application dated June 29, 1992, as supplemented on February 22, 1994. A correction letter was issued on January 24, 1995. TS page 3/4 3-23 was inadvertently omitted from the letter and is included in the Enclosure.

The Commission issued Amendment No. 68 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit No. 1 on January 20, 1995. The amendment revised the TS in response to your application dated September 19, 1994. A typographical error was made to Table 4.7.4-1, Snubber Visual Inspection Interval. Column C for Reducing Interval should have referenced Notes 5 and 6 rather than Notes 5 and 7. The revised page is included in the Enclosure.

We apologize for the errors, and hope they have not inconvenienced you.

Sincerely,
Original Signed By:
Jon B. Hopkins, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure: TS pages

cc w/encl: See next page

Distribution w/encls:

Docket File E. Greenman, RIII
PUBLIC G. Hill (2)
PDIII-3 Reading R. Schaaf
J. Roe ACRS (4)
OC/LFDCB OPA
C. Grimes, DORS/OTSB
OGC

DOCUMENT NAME: G:\PERRY\PER84057.LTR

*See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PDIII-3	<input checked="" type="checkbox"/> E	PM:PDIII-3	<input checked="" type="checkbox"/> E	PM:PDIII-3	<input checked="" type="checkbox"/> E	D:PDIII-3	<input checked="" type="checkbox"/> N
NAME	MRushbrook		LGundrum:lg		JHopkins		LNorrholm	
DATE	02/7/95		02/7/95		02/7/95		02/7/95	

OFFICIAL RECORD COPY

100000
9502130001 950207
PDR ADOCK 05000440
P PDR

RECEIVED COPY
DFD!

Mr. Donald C. Shelton
Centerior Service Company

cc:

Jay E. Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Mary E. O'Reilly
Centerior Energy Corporation
300 Madison Avenue
Toledo, Ohio 43652

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4531

Lake County Prosecutor
Lake County Administration Bldg.
105 Main Street
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street, Suite 105
Toledo, Ohio 43624

Ashtabula County Prosecutor
25 West Jefferson Street
Jefferson, Ohio 44047

Regulatory Affairs Manager
Cleveland Electric Illuminating
Company
Perry Nuclear Power Plant
P. O. Box 97, E-210
Perry, Ohio 44081

James R. Williams, Chief of Staff
Ohio Emergency Management Agency
2825 West Granville Road
Worthington, Ohio 43085

Perry Nuclear Power Plant
Unit Nos. 1 and 2

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P. O. Box 825
Columbus, Ohio 43216

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program
Ohio Department of Health
Post Office Box 118
Columbus, Ohio 43266-0118

Ohio Environmental Protection
Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P. O. Box 1049
Columbus, Ohio 43266-0149

Mr. Thomas Haas, Chairman
Perry Township Board of Trustees
3750 Center Rd., Box 65
Perry, Ohio 44081

State of Ohio
Public Utilities Commission
East Broad Street
Columbus, Ohio 43266-0573

Richard Brandt, Plant Manager
Cleveland Electric Illuminating
Company
Perry Nuclear Power Plant
P. O. Box 97, SB306
Perry, Ohio 44081

ATTACHMENT TO CORRECTION LETTER FOR AMENDMENT NOS. 67 AND 68

FACILITY OPERATING LICENSE NO. NPF-58

DOCKET NO. 50-440

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages.

Remove

3/4 3-23
3/4 7-12a

Insert

3/4 3-23
3/4 7-12a

9502130002 950207
PDR ADDCK 05000440
PDR

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>	
1. <u>PRIMARY CONTAINMENT ISOLATION</u>					
a. Reactor Vessel Water Level - Low, Level 2	S	Q	R ^(b)	1, 2, 3 and #	
b. Drywell Pressure - High ##	S	Q	R ^(b)	1, 2, 3	
c. Containment and Drywell Purge Exhaust Plenum Radiation - High	S	Q	R	1, 2, 3 and *	
d. Reactor Vessel Water Level - Low, Level 1	S	Q	R ^(b)	1, 2, 3 and #	
e. Manual Initiation	NA	R	NA	1, 2, 3 and *	
2. <u>MAIN STEAM LINE ISOLATION</u>					
a. Reactor Vessel Water Level - Low, Level 1	S	Q	R ^(b)	1, 2, 3	
b. Main Steam Line Radiation - High	S	Q	R	***	
c. Main Steam Line Pressure - Low	S	Q	R ^(b)	1	
d. Main Steam Line Flow - High	S	Q	R ^(b)	1, 2, 3	
e. Condenser Vacuum - Low	S	Q	R ^(b)	1, 2**, 3**	
f. Main Steam Line Tunnel Temperature - High	S	Q	R	1, 2, 3	
g. Main Steam Line Tunnel Δ Temperature - High	S	Q	R	1, 2, 3	
h. Turbine Building Main Steam Line Temperature - High	S	Q	R	1, 2, 3	
i. Manual Initiation	NA	R	NA	1, 2, 3	

**TABLE 4.7.4-1
SNUBBER VISUAL INSPECTION INTERVAL**

Population or Category (Notes 1 and 2)	NUMBER OF UNACCEPTABLE SNUBBERS		
	Column A Extend Interval (Notes 3 and 6)	Column B Repeat Interval (Notes 4 and 6)	Column C Reduce Interval (Notes 5 and 6)
1	0	0	1
80	0	0	2
100	0	1	4
150	0	3	8
200	2	5	13
300	5	12	25
400	8	18	36
500	12	24	48
750	20	40	78
1000 or greater	29	56	109

Note 1: The next visual inspection interval for a snubber population or category size shall be determined based upon the previous inspection interval and the number of unacceptable snubbers found during that interval. Snubbers may be categorized, based upon their accessibility during power operation, as accessible or inaccessible. These categories may be examined separately or jointly. However, PNPP must make and document that decision before any inspection and shall use that decision as the basis upon which to determine the next inspection interval for that category.

Note 2: Interpolation between population or category sizes and the number of unacceptable snubbers is permissible. Use the next lower integer for the value of the limit for Columns A, B, or C if that integer includes a fractional value of unacceptable snubbers as determined by interpolation.