

November 22, 1994

Mr. Robert A. Stratman
Vice President Nuclear - Perry
Centerior Service Company
P. O. Box 97, A200
Perry, OH 44081

*See Proposed
Change to Tech
Specs*

SUBJECT: AMENDMENT NO. 67 TO FACILITY OPERATING LICENSE NO. NPF-58 - PERRY
NUCLEAR POWER PLANT, UNIT NO. 1 (TAC NO. M84057)

Dear Mr. Stratman:

The Commission has issued the enclosed Amendment No. 67 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit No. 1. This amendment revises the Technical Specifications in response to your application dated June 29, 1992 as supplemented on February 22, 1994.

The amendment revises TS Sections 3/4.3, "Instrumentation," 3/4.4.2, "Safety/Relief Valves," and their associated Bases to increase the surveillance test intervals and allowable out-of-service times. The changes to TS 3/4.3 affect actuation instrumentation for the following: Reactor Protection System, Emergency Core Cooling System, Control Rod Block System, Containment and Reactor Vessel Isolation System, Recirculation Pump Trip, Reactor Core Isolation Cooling Systems, and Plant Systems. In addition, several minor changes were required to correct apparent typographical errors included in the proposed TS. These changes are discussed in the Safety Evaluation and were agreed to by your staff.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original signed by:
Jon B. Hopkins, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosures: 1. Amendment No. 67
to License No. NPF-58
2. Safety Evaluation

Distribution w/encs:

Docket File E. Greenman, RIII
PUBLIC G. Hill, (2)
PDIII-3 Reading R. Schaaf
J. Roe ACRS (4)
OC/LFDCB OPA
C. Grimes, DORS/OTSB

cc w/encs: See next page

DOCUMENT NAME: G:\PERRY\PER84057.SER

*See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PDIII-3	<input checked="" type="checkbox"/>	APM:\PDIII-3	<input checked="" type="checkbox"/>	PM:PDIII-3	<input checked="" type="checkbox"/>	*C:HICB	<input type="checkbox"/>	*OGC	<input type="checkbox"/>
NAME	MRushbrook		LGundrum		JHopkins		MChiramel		GHoller	
TE	11/22/94		11/22/94		11/22/94		10/25/94		10/26/94	

OFFICE	D:PDIII-3	<input type="checkbox"/>
NAME	LNorholm	
DATE	11/22/94	

OFFICIAL RECORD COPY

9412010212 941122
PDR ADOCK 05000440
P PDR

200124

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 22, 1994

Mr. Robert A. Stratman
Vice President Nuclear - Perry
Centerior Service Company
P. O. Box 97, A200
Perry, OH 44081

SUBJECT: AMENDMENT NO. 67 TO FACILITY OPERATING LICENSE NO. NPF-58 - PERRY
NUCLEAR POWER PLANT, UNIT NO. 1 (TAC NO. M84057)

Dear Mr. Stratman:

The Commission has issued the enclosed Amendment No. 67 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit No. 1. This amendment revises the Technical Specifications in response to your application dated June 29, 1992 as supplemented on February 22, 1994.

The amendment revises TS Sections 3/4.3, "Instrumentation," 3/4.4.2, "Safety/Relief Valves," and their associated Bases to increase the surveillance test intervals and allowable out-of-service times. The changes to TS 3/4.3 affect actuation instrumentation for the following: Reactor Protection System, Emergency Core Cooling System, Control Rod Block System, Containment and Reactor Vessel Isolation System, Recirculation Pump Trip, Reactor Core Isolation Cooling Systems, and Plant Systems. In addition, several minor changes were required to correct apparent typographical errors included in the proposed TS. These changes are discussed in the Safety Evaluation and were agreed to by your staff.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, reading "Jon B. Hopkins", is written over the typed name.

Jon B. Hopkins, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosures: 1. Amendment No. 67
to License No. NPF-58
2. Safety Evaluation

cc w/encls: See next page

Mr. Robert A. Stratman
Centerior Service Company

cc:

Jay E. Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Mary E. O'Reilly
Centerior Energy Corporation
300 Madison Avenue
Toledo, Ohio 43652

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmlly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4531

Lake County Prosecutor
Lake County Administration Bldg.
105 Main Street
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street, Suite 105
Toledo, Ohio 43624

Ashtabula County Prosecutor
25 West Jefferson Street
Jefferson, Ohio 44047

Regulatory Affairs Manager
Cleveland Electric Illuminating
Company
Perry Nuclear Power Plant
P. O. Box 97, E-210
Perry, Ohio 44081

James R. Williams, Chief of Staff
Ohio Emergency Management Agency
2825 West Granville Road
Worthington, Ohio 43085

Perry Nuclear Power Plant
Unit Nos. 1 and 2

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P. O. Box 825
Columbus, Ohio 43216

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program
Ohio Department of Health
Post Office Box 118
Columbus, Ohio 43266-0118

Ohio Environmental Protection
Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P. O. Box 1049
Columbus, Ohio 43266-0149

Mr. Thomas Haas, Chairman
Perry Township Board of Trustees
3750 Center Rd., Box 65
Perry, Ohio 44081

State of Ohio
Public Utilities Commission
East Broad Street
Columbus, Ohio 43266-0573

David P. Igyarto, Plant Manager
Cleveland Electric Illuminating
Company
Perry Nuclear Power Plant
P. O. Box 97, SB306
Perry, Ohio 44081