

PRELIMINARY DRAFT FOR COPY

Dockets Nos. 50-266
and 50-301

OCTOBER 24 1980

Distribution:

Docket

NRC PDR
Local PDR
ORB#3 Reading
NRR Reading
H. R. Denton
E. G. Case
R. Hartfield, MPA
G. Bennington, MPA
D. Eisenhut
R. Purple
T. Novak
R. Tedesco
G. Lainas

Murphy

J. Roe
PMKreutzer (3)
M. Williams
OELD
OI&E (3)
B. Jones (4)
ACRS (16)
OPA (Clare Miles)
NSIC
TERA
Secretariat (SECY)
R. Diggs
J. Heltemes, AEOD
Project Manager
RAClark

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (SO-CLI-21)
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for the Point Beach Nuclear Plant, Unit Nos. 1 and 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Original Signed By

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Order

cc w/enclosure: See Next Page

8011070562

60

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	ORB#2:DL	D:DL
SURNAME	PMKreutzer/JL PM		RAClark	M. Williams	DEisenhut
DATE	10/ /80	10/ /80	10/ /80	10/ /80	10/ /80



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 24, 1980

Dockets Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:


SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for the Point Beach Nuclear Plant, Unit Nos. 1 and 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,


Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Order

cc w/enclosure: See Next Page

Mr. Sol Burstein
Wisconsin Electric Power Company - 2 -

October 24, 1980

cc: Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Mr. William Guldemon
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
302 E. Washington Avenue
Madison, Wisconsin 53703

Director, Technical Assessment Division
Office of Radiation Programs (AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hill Farms State Office Building
Madison, Wisconsin 53702

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
WISCONSIN ELECTRIC POWER COMPANY)	Docket Nos. 50-266
(Point Beach Nuclear Plant)	and 50-301
Unit Nos. 1 and 2))	

ORDER FOR MODIFICATION OF LICENSES

I.

Wisconsin Electric Power Company (licensee) is the holder of License Nos. DPR-24 and DPR-27 which authorize the operation of the Point Beach Nuclear Plant, Unit Nos. 1 and 2 at steady state reactor power levels not in excess of 1518 megawatts thermal (rated power). The facilities consist of two Pressurized Water Reactors located at the licensee's site at Two Creeks, Wisconsin.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 (copies attached) "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualifications of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B¹ and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588."

¹

Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed that, "In order to leave no room for doubt on this issue, the staff is to prepare additional Technical Specifications for all operating plants which codify the documentation requirement paragraph of the Guidelines (paragraph 8.0)." The staff was directed to add these documentation requirements to each license after they were approved by the Commission.

The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

III.

The Commission has approved the Technical Specification provisions set forth in Section IV below which specify documentation requirements and which specifically impose on the licensee the requirement of the Commission's May 23, 1980 Memorandum and Order that by no later than June 30, 1982 all safety-related electrical equipment shall be qualified to the DOR Guidelines or NUREG-0588.

The information developed during the Commission review of the UCS Petition emphasizes the importance of prompt completion of the upgrading of

environmental qualification of safety-related electrical equipment to conform to the DOR Guidelines or NUREG-0588 and of adequate documentation of equipment qualifications. The deadlines set forth in the Commission's Memorandum and Order dated May 23, 1980, assure that such upgrading will be accomplished promptly. In order to assure prompt completion of necessary qualification work or replacement of unqualified components, if necessary, in conformance with the requirements of the Commission's Memorandum and Order dated May 23, 1980, and to provide complete and adequate documentation as promptly as possible, such upgrading and documentation work must commence immediately. Therefore, I have concluded that the public health, safety and interest require this Order for Modification of License to be effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating License Nos. DPR-24 and DPR-27 are hereby amended to add the following provisions to the Appendix A Technical Specifications.

- (a) "By no later than June 30, 1982, all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588, "Interim Staff Position on Environmental

Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-24 and DPR-27 dated October 24, 1980.

- (b) "By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified."

To effectuate the foregoing, appropriate pages for incorporation into the Technical Specifications are attached to this Order.

V.

The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Bruce Churchill, Esq., Shaw, Pittman, Potts and Trowbridge, 1800 M Street, N. W., Washington, D. C. 20036, attorney for the licensee.


- 6 -

If a hearing is held concerning this Order, the issues to be considered at the hearing shall be:

- a. whether the licensee should be required to have the environmental qualification records referred to in Section IV, above, available at a central location by no later than December 1, 1980; and
- b. whether all safety-related electrical equipment should be qualified as required in Section IV, above, by no later than June 30, 1982.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhower, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Effective Date: October 24, 1980
Bethesda, Maryland

Attachments:

1. Technical Specification Pages
2. Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors
3. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment.

- M. Test results, in units of microcuries, for leak test performed pursuant to Specification 15.4.12.
- N. Record of annual physical inventory verifying accountability of sources subject to Specification 15.4.12.
- O. *Records of training and qualification for current plant NRC licensed staff and key personnel.
- P. *Records of in-service inspections performed pursuant to these technical specifications.
- Q. *Records of Quality Assurance activities required by the QA Manual.
- R. *Records of reviews performed pursuant to 10 CFR 50.59.
- S. *Records of meetings of the Manager's Supervisory Staff and the Off-Site Review Committee.
- T. *Records of Environmental Qualification which are covered under the provisions of paragraph 15.6.12.

15.6.12 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-24 and DPR-27 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.

- M. Test results, in units of microcuries, for leak test performed pursuant to Specification 15.4.12.
- N. Record of annual physical inventory verifying accountability of sources subject to Specification 15.4.12.
- O. *Records of training and qualification for current plant NRC licensed staff and key personnel.
- P. *Records of in-service inspections performed pursuant to these technical specifications.
- Q. *Records of Quality Assurance activities required by the QA Manual.
- R. *Records of reviews performed pursuant to 10 CFR 50.59.
- S. *Records of meetings of the Manager's Supervisory Staff and the Off-Site Review Committee.
- T. *Records of Environmental Qualification which are covered under the provisions of paragraph 15.6.12.

15.6.12 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-24 and DPR-27 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.