

PRIORITY Normal

DISPOSITION OF THE ORIGINAL DOCUMENT WILL BE TO THE TRANSMITTAL SIGNATURE UNLESS RECIPIENT IS OTHERWISE IDENTIFIED BELOW

- 1) 02049 NGO PRA MANAGER EC08I
- 2) 02188 NPA MANAGER EC05N
- 3) 02467 ELECT. LICENSING LIBRARY EC050
- 4) 02532 MCG NRC INSP MG-ADMIN MAIL RM
- 5) 02546 WC LIBRARY - MG01WC
- 6) 03044 MCG DOC CNTRL MISC MAN MGO5DM
- 7) 03102 H L MASSEY OPS PROC GP MG03OT
- 8) 03379 D E CALDWELL MG01MM
- 9) 03447 HARRY J SLOAN MG01RP
- 10) 03614 MCG OPS PROCEDURE GP MG01OP
- 11) 03744 OPS TRNG MGR. MG03OT
- 12) 03759 U S NUCLEAR REG WASH, DC
- 13) 04771 E E HITE EC09E
- 14) 04809 MCG PLANT ENG. LIBR. MG05SE
- 15) 05160 P T VU MG01RC

Duke Power Company DOCUMENT TRANSMITTAL FORM

REFERENCE

MCGUIRE NUCLEAR STATION
SELECTED LICENSEE COMMITMENTS
MANUAL (SLC)

Page 2 of 3

Date: 06/20/02

Document Transmittal #: DUK021710003

QA CONDITION Yes No

OTHER ACKNOWLEDGEMENT REQUIRED Yes

IF QA OR OTHER ACKNOWLEDGEMENT REQUIRED, PLEASE ACKNOWLEDGE RECEIPT BY RETURNING THIS FORM TO:

Duke Power Company
P.O. Box 12700
Document Management MG01S2
Hagers Ferry Road
Huntersville, N.C. 28078

Rec'd By _____

Date _____

DOCUMENT NO	QA COND	REV #/ DATE	DISTR CODE	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	TOTAL
SELECTED LICENSEE COMMITMENT MANUAL	NA	024 06/13/02	MADM-03A	V1	V1	V1	V1	V1	V1	V1	V1	V1	V1	V2	V8	V1	V2	V1	56
MEMORANDUM	NA	024 06/13/02																	
SLC - TABLE OF CONTENTS	NA	027 06/13/02																	
LOEP	NA	024 06/13/02																	
SLC 16.6.4	NA	027 06/13/02																	
SLC 16.7.8	NA	026 06/13/02																	
SLC 16.8.3	NA	026 06/13/02																	

REMARKS: PLEASE UPDATE YOUR MANUAL ACCORDINGLY

H B BARRON, JR.
VICE PRESIDENT
MCGUIRE NUCLEAR STATION

BY:
P T VU MG01RC PTV/CMK

1001

EB

June 13, 2002

MEMORANDUM

To: All McGuire Nuclear Station Selected Licensee Commitments (SLC) Manual Holders

Subject: McGuire SLC Manual Update

Please revise your copy of the manual as follows:

REMOVE

INSERT

List of Effective Sections

List of Effective Sections Revision 24

Table of Contents

Table of Contents Revision 27

Entire SLC 16.6.4 Revision 27 (This is a new SLC)

Entire SLC 16.7.8

Entire SLC 16.7.8 Revision 26

Entire SLC 16.8.3

Entire SLC 16.8.3 Revision 26

Revisions may skip numbers due to Regulatory Compliance Filing System.

Please call me if you have questions.

PT Vu
Bonnie Beaver
Regulatory Compliance

SLC LIST OF EFFECTIVE SECTIONS

SECTION	REVISION NUMBER	DATE
16.1	REVISION 0	12/14/99
16.2	REVISION 0	12/14/99
16.3	REVISION 0	12/14/99
16.4	Not Issued	
16.5.1	REVISION 0	12/14/99
16.5.2	REVISION 0	12/14/99
16.5.3	REVISION 0	12/14/99
16.5.4	REVISION 7	09/14/00
16.5.5	REVISION 0	12/14/99
16.5.6	REVISION 0	12/14/99
16.5.7	REVISION 0	12/14/99
16.5.8	REVISION 0	12/14/99
16.5.9	REVISION 0	12/14/99
16.5.10	REVISION 0	12/14/99
16.6.1	REVISION 0	12/14/99
16.6.2	REVISION 0	12/14/99
16.6.3	REVISION 17	04/08/02
16.6.4	REVISION 27	06/12/02
16.7.1	REVISION 0	12/14/99
16.7.2	REVISION 24	4/29/02
16.7.3	REVISION 0	12/14/99
16.7.4	REVISION 1	4/11/00
16.7.5	REVISION 0	12/14/99
16.7.6	REVISION 0	12/14/99
16.7.7	REVISION 0	12/14/99
16.7.8	REVISION 26	6/3/02
16.7.9	REVISION 0	12/14/99
16.7.10	REVISION 0	12/14/99
16.8.1	REVISION 2	4/11/00
16.8.2	REVISION 0	12/14/99
16.8.3	REVISION 26	6/3/02
16.9.1	REVISION 18	12/4/01
16.9.2	REVISION 5	5/24/00
16.9.3	REVISION 0	12/14/99
16.9.4	REVISION 1	03/02/00
16.9.5	REVISION 0	12/14/99
16.9.6	REVISION 0	12/14/99
16.9.7	REVISION 25	5/14/02
16.9.8	REVISION 0	12/14/99
16.9.9	REVISION 13	2/26/01
16.9.10	REVISION 13	2/26/01
16.9.11	REVISION 22	2/25/02
16.9.12	REVISION 13	2/26/01
16.9.13	REVISION 13	2/26/01
16.9.14	REVISION 22	2/25/02
16.9.15	REVISION 25	5/14/02
16.9.16	REVISION 19	12/03/01

SLC LIST OF EFFECTIVE SECTIONS

SECTION	REVISION NUMBER	DATE
16.9.17	REVISION 0	12/14/99
16.9.18	REVISION 0	12/14/99
16.9.19	REVISION 0	12/14/99
16.9.20	REVISION 8	11/30/00
16.9.21	REVISION 0	12/14/99
16.9.22	REVISION 0	12/14/99
16.9.23	Not Issued	
16.9.24	REVISION 20	1/17/02
16.10.1	REVISION 0	12/14/99
16.11.1	REVISION 9	2/1/01
16.11.2	REVISION 23	4/4/02
16.11.3	REVISION 0	12/14/99
16.11.4	REVISION 0	12/14/99
16.11.5	REVISION 0	12/14/99
16.11.6	REVISION 0	12/14/99
16.11.7	REVISION 12	3/14/01
16.11.8	REVISION 0	12/14/99
16.11.9	REVISION 0	12/14/99
16.11.10	REVISION 0	12/14/99
16.11.11	REVISION 0	12/14/99
16.11.12	REVISION 0	12/14/99
16.11.13	REVISION 0	12/14/99
16.11.14	REVISION 21	1/17/02
16.11.15	REVISION 21	1/17/02
16.11.16	REVISION 1	4/11/00
16.11.17	REVISION 1	4/11/00
16.11.18	REVISION 0	12/14/99
16.11.19	REVISION 0	12/14/99
16.11.20	REVISION 0	12/14/99
16.12.1	REVISION 0	12/14/99
16.12.2	REVISION 0	12/14/99
16.13.1	REVISION 0	12/14/99
16.13.2	REVISION 24	4/29/02
16.13.3	REVISION 24	4/29/02
16.14.1	REVISION 0	12/14/99

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
16.1	INTRODUCTION	16.1-1
16.2	APPLICABILITY	16.2-1
16.3	DEFINITIONS	16.3-1
16.4	COMMITMENTS RELATED TO REACTOR COMPONENTS	
16.5	COMMITMENTS RELATED TO REACTOR COOLANT SYSTEM	
16.5.1	Inventory Control – Reduced Inventory Operation	16.5.1-1
16.5.2	Power Systems and Decay Heat Removal - Reduced Inventory Operation	16.5.2-1
16.5.3	Reactivity Control - Reduced Inventory Operation	16.5.3-1
16.5.4	NCS Instrumentation – Reduced Inventory Operation	16.5.4-1
16.5.5	Containment Closure - Reduced Inventory Operation	16.5.5-1
16.5.6	Safety Valves – Shutdown	16.5.6-1
16.5.7	Chemistry	16.5.7-1
16.5.8	Pressurizer	16.5.8-1
16.5.9	Structural Integrity	16.5.9-1
16.5.10	Reactor Vessel Head Vent System	16.5.10-1
16.6	COMMITMENTS RELATED TO ENGINEERED SAFETY FEATURES	
16.6.1	Containment Sump	16.6.1-1
16.6.2	Ice Bed Temperature Monitoring System	16.6.2-1
16.6.3	Inlet Door Position Monitoring System	16.6.3-1
16.6.4	Safety Injection System Nozzles	16.6.4-1
16.7	COMMITMENTS RELATED TO INSTRUMENTATION	
16.7.1	ATWS/AMSAC	16.7.1-1
16.7.2	Seismic Instrumentation	16.7.2-1
16.7.3	Meteorological Instrumentation	16.7.3-1

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
16.7.4	Loose-Part Detection Instrumentation	16.7.4-1
16.7.5	Turbine Overspeed Protection	16.7.5-1
16.7.6	Radiation Monitoring for Plant Operations	16.7.6-1
16.7.7	Movable Incore Detectors	16.7.7-1
16.7.8	Explosive Gas Monitoring Instrumentation	16.7.8-1
16.7.9	Rod Position Indication System – Shutdown	16.7.9-1
16.7.10	Rod Position Indication System – Test Exception	16.7.10-1
16.8	COMMITMENTS RELATED TO ELECTRICAL POWER SYSTEMS	
16.8.1	Containment Penetration Overcurrent Protective Devices	16.8.1-1
16.8.2	Switchyard Activities	16.8.2-1
16.8.3	DG Supplemental Testing Requirements	16.8.3-1
16.9	COMMITMENTS RELATED TO AUXILIARY SYSTEMS	
16.9.1	Fire Suppression Water System	16.9.1-1
16.9.2	Spray and/or Sprinkler Systems	16.9.2-1
16.9.3	Halon Systems	16.9.3-1
16.9.4	Fire Hose Stations	16.9.4-1
16.9.5	Fire Rated Assemblies	16.9.5-1
16.9.6	Fire Detection Instrumentation	16.9.6-1
16.9.7	Standby Shutdown System	16.9.7-1
16.9.8	Groundwater Level Monitoring System	16.9.8-1
16.9.9	Boration Systems – Flow Path (Operating)	16.9.9-1
16.9.10	Boration Systems – Charging Pumps (Operating)	16.9.10-1
16.9.11	Borated Water Sources (Operating)	16.9.11-1
16.9.12	Boration Systems – Flow Path (Shutdown)	16.9.12-1
16.9.13	Boration Systems – Charging Pumps (Shutdown)	16.9.13-1
McGuire Units 1 and 2	ii	Revision 27

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
16.9.14	Borated Water Sources (Shutdown)	16.9.14-1
16.9.15	Snubbers	16.9.15-1
16.9.16	Area Temperature Monitoring	16.9.16-1
16.9.17	Refueling Operations – Decay Time	16.9.17-1
16.9.18	Refueling Operations – Communications	16.9.18-1
16.9.19	Refueling Operations – Manipulator Crane	16.9.19-1
16.9.20	Crane Travel – Spent Fuel Pool Storage Building	16.9.20-1
16.9.21	Water Level – Spent Fuel Storage Pool	16.9.21-1
16.9.22	Control Area Ventilation System	16.9.22-1
16.9.24	Spent Fuel Pool Storage Rack Poison Material	16.9.24-1
16.10	COMMITMENTS RELATED TO STEAM AND POWER CONVERSION SYSTEMS	
16.10.1	Steam Generator Pressure/Temperature Limitation	16.10.1-1
16.11	COMMITMENTS RELATED TO RADIOACTIVE WASTE MANAGEMENT AND RADIOLOGICAL EFFLUENT CONTROL	
16.11.1	Liquid Effluents - Concentration	16.11.1-1
16.11.2	Radioactive Liquid Effluent Monitoring Instrumentation	16.11.2-1
16.11.3	Dose - Liquid Effluents	16.11.3-1
16.11.4	Liquid Radwaste Treatment System	16.11.4-1
16.11.5	Chemical Treatment Ponds	16.11.5-1
16.11.6	Dose Rate - Gaseous Effluents	16.11.6-1
16.11.7	Radioactive Gaseous Effluent Monitoring Instrumentation	16.11.7-1
16.11.8	Noble Gases	16.11.8-1
16.11.9	Dose – Iodine-131 and 133, Tritium and Radioactive Materials in Particulate Form	16.11.9-1
16.11.10	Gaseous Radwaste Treatment System	16.11.10-1
McGuire Units 1 and 2	iii	Revision 27

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
16.11.11	Solid Radioactive Waste	16.11.11-1
16.11.12	Total Dose	16.11.12-1
16.11.13	Radiological Environmental Monitoring Program	16.11.13-1
16.11.14	Land Use Census	16.11.14-1
16.11.15	Interlaboratory Comparison Program	16.11.15-1
16.11.16	Annual Radiological Environmental Operating Report	16.11.16-1
16.11.17	Radioactive Effluent Release Reports	16.11.17-1
16.11.18	Liquid Holdup Tanks	16.11.18-1
16.11.19	Explosive Gas Mixture	16.11.19-1
16.11.20	Gas Storage Tanks	16.11.20-1
16.12	COMMITMENTS RELATED TO RADIATION PROTECTION	
16.12.1	In-Plant Iodine Monitoring	16.12.1-1
16.12.2	Sealed Source Contamination	16.12.2-1
16.13	COMMITMENTS RELATED TO CONDUCT OF OPERATIONS	
16.13.1	Fire Brigade	16.13.1-1
16.13.2	Technical Review and Control	16.13.2-1
16.13.3	Plant Operations Review Committee	16.13.3-1
16.14	COMMITMENTS RELATED TO TESTING	
16.14.1	Startup Reports	16.14.1-1

16.6. ENGINEERED SAFETY FEATURES

16.6.4 Safety Injection System Nozzles

COMMITMENT: Reporting of ECCS Injections and Nozzle Usage Factors

APPLICABILITY: MODES 1, 2, and 3.

REMEDIAL ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
The ECCS is actuated and injects water into the Reactor Coolant System and the current value of the usage factor for an affected safety injection nozzle exceeds 0.70.	A Special Report shall be prepared and submitted to the NRC describing the circumstances of the actuation and the total accumulated actuation cycles to date. The current value of the usage factor for each affected Safety Injection nozzle shall be provided.	90 days

TESTING REQUIREMENTS

None

BASES

Duke letter, "Justification for Continued Operation with Seven Thermal Sleeves Removed," dated December 14, 1983, provided the results of evaluations performed by Westinghouse and Duke as a basis for continued operation of McGuire Units 1 and 2 without thermal sleeves installed in the reactor coolant system nozzles. The NRC's letter and safety evaluation (SER) dated December 30, 1986, concluded that continued operation was acceptable and that the requirements of License Condition (LC) 2.C.(4) had been completed. The NRC staff's acceptance recognized that McGuire's Technical Specification 3/4.5.2 required reporting of the usage factor of each nozzle if the value exceeded 0.70 and the ECCS actuated and injected water into the reactor coolant system. During implementation of Improved Technical Specifications, this reporting requirement was inadvertently removed.

By letter dated June 13, 2000, as supplemented on August 20, 2001 and September 10, 2001, McGuire submitted a proposed License Amendment Request (LAR). This purpose of this LAR was to delete LCs that had previously been completed. In the September 10, 2001 letter, McGuire committed to ensure proper notification is accomplished in the event the usage factor of affected safety injection nozzles exceeds the 0.70 value following an ECCS actuation and injection of water into the reactor coolant system. The NRC issued approved License Amendment 200/181 by letter dated December 5, 2001.

REFERENCES

- 1, McGuire License Amendment Request dated June 13, 2000, as supplemented by letters August 30, 2001 and September 10, 2001.
2. NRC letter dated December 5, 2001, McGuire Nuclear Station, Units 1 and 2 Issuance of Amendments RE: License Conditions (TAC NOS. MA9297 and MA9298)

16.7 INSTRUMENTATION

16.7.8 Explosive Gas Monitoring Instrumentation

COMMITMENT One hydrogen monitor and two oxygen monitors for the in-service hydrogen recombiner train shall be **OPERABLE** with their Alarm/Trip Setpoints set to ensure that the limits of Technical Specification 5.5.12 are not exceeded.

APPLICABILITY During WASTE GAS HOLDUP SYSTEM operation.

REMEDIAL ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required hydrogen monitor inoperable.	A.1 Suspend oxygen supply to the recombiner.	Immediately
B. One required oxygen monitor inoperable.	B.1 Restore the required oxygen monitor to OPERABLE status.	14 days
C. Two required oxygen monitors inoperable.	C.1 Be in MODE 3 .	6 hours
D. Required Action and associated Completion Time not met.	D.1 Prepare and submit a Special Report to the NRC explaining why the inoperability was not corrected in the time specified.	30 days

TESTING REQUIREMENTS

TEST	FREQUENCY
TR 16.7.8.1 Perform CHANNEL CHECK.	12 hours
TR 16.7.8.2 Perform CHANNEL OPERATIONAL TEST.	31 days
TR 16.7.8.3 -----NOTES----- 1. The CHANNEL CALIBRATION of the hydrogen monitor shall include the use of standard gas samples corresponding to alarm setpoints in accordance with the manufacturer's recommendations. 2. The CHANNEL CALIBRATION of the oxygen monitor shall include the use of standard gas samples in accordance with the manufacturer's recommendations. 3. A standard gas sample of nominal 4 volume percent oxygen, balance nitrogen, shall be used in the calibration to check linearity of the oxygen monitor. ----- Perform a CHANNEL CALIBRATION.	92 days

BASES

The gas instrumentation is provided for monitoring and controlling the concentrations of potentially explosive gas mixtures in the WASTE GAS HOLDUP SYSTEM.

SLC 16.7.8 requires that one hydrogen and two oxygen monitors per train be OPERABLE in the Waste Gas (WG) System to ensure that explosive gas mixtures are not allowed in the WG System.

Only one recombiner train is in service at a time. Therefore, the requirement for one hydrogen and two oxygen monitors shall apply only to the train in service.

The requirement for oxygen monitors may be satisfied for Train "A" by using two of the following three monitors:

OWGMT5790 OWGMT6210 OWGMT6211

The requirement for hydrogen monitors may be satisfied for Train "A" by using OWGMT5590.

The requirement for oxygen monitors may be satisfied for Train "B" by using two of the following three monitors:

OWGMT5780 OWGMT6210 OWGMT6211

The requirement for hydrogen monitors may be satisfied for Train "B" by using OWGMT5580.

Loops OWGMT5580 and OWGMT5590 have both hydrogen and oxygen monitoring capability. The oxygen monitoring portion of these two loops shall not be used to satisfy the oxygen monitor requirements of either train because these oxygen monitors measure the oxygen concentration at the recombiner inlet after the addition of bulk oxygen. This is not representative of the Waste Gas System as defined in SLC 16.11.19. These oxygen monitors will be used for the operation of the hydrogen recombiners but will not be used to satisfy the requirements of SLC 16.7.8.

REFERENCES

1. UFSAR, Section 11.3
2. System Description
3. Catalytic Hydrogen Recombiner Operational Manual, MCM-1201.04-0174.

16.8 ELECTRICAL POWER SYSTEMS

16.8.3 Diesel Generator (DG) Supplemental Testing Requirements

COMMITMENT The DG supplemental testing requirements specified below shall be met.

APPLICABILITY: MODES 1, 2, 3, 4, 5, and 6

-----NOTE-----
The testing requirements for the DG batteries are not required in MODES 5 and 6.

REMEDIAL ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Commitment not met.	A.1 Declare DG inoperable.	Immediately

TESTING REQUIREMENTS

TEST	FREQUENCY
TR 16.8.3.1 Verify the electrolyte level of each DG battery is above the plates.	7 days
TR 16.8.3.2 Verify overall DG battery voltage is \geq 125 volts under a float charge.	7 days
TR 16.8.3.3 Verify DG batteries and battery racks show no visual indication of physical damage or abnormal deterioration.	18 months

(continued)

TESTING REQUIREMENTS (continued)

TEST	FREQUENCY
TR 16.8.3.4 Verify DG battery-to-battery and terminal connections are clean, tight, free of corrosion and coated with anti-corrosion material.	18 months
TR 16.8.3.5 Perform DG battery service test	18 months
TR 16.8.3.6 Remove accumulated water from DG day tank.	After each run of ≥1 hour
TR 16.8.3.7 Perform DG inspection, during shutdown, in accordance with manufacturer's recommendations for this class of standby service.	18 months
TR 16.8.3.8 Verify that the fuel oil transfer pump transfers fuel from each fuel storage tank to the day tank of each DG via the installed cross-connection lines.	18 months
<p>TR 16.8.3.9 -----NOTE----- This Testing Requirement may be performed in conjunction with periodic pre-planned preventative maintenance activity that causes the DG to be inoperable provided that performance of the Testing Requirement does not increase the time the DG would be inoperable for the maintenance activity alone.</p> <p>----- Verify, during shutdown, that the turning gear engaged or emergency stop features prevent DG starting only when required.</p>	18 months
TR 16.8.3.10 Perform a pressure test of those portions of the diesel fuel oil system designed to ASME Section III, subsection ND in accordance with applicable NRC-approved ASME code requirements.	10 years

BASES

The Testing Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides and Generic Letters referenced below.

TR 16.8.3.9 is modified with a note. This TR specifies that it is to be performed during shutdown. This note allows the TR to be performed during preplanned Preventative Maintenance (PM) activities that would result in the diesel generator being inoperable. This TR can be performed at that time as long as it does not increase the time the diesel generator is inoperable for the PM activity that is being performed. The note is only applicable at that time. The provision of the note shall not be utilized for operational convenience.

Since the McGuire emergency diesel generator manufacturer (Nordberg) is no longer in business, McGuire engineering is the designer of record. Therefore, in the absence of manufacturer recommendations, McGuire engineering will determine the appropriate actions required for nuclear class diesel service taking into account McGuire diesel generator maintenance and operating history and industry experience where applicable.

REFERENCES

1. Regulatory Guide 1.9, Selection of Diesel Generator Set Capacity for Standby Power Supplies, March 10, 1971.
2. Regulatory Guide 1.108, Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants, Revision 1, August 1977.
3. Regulatory Guide 1.137, Fuel-Oil Systems for Standby Diesel Generators, Revision 1, October 1979.
4. Generic Letter 84-15, which modified the testing frequencies specified in Regulatory Guide 1.108.
5. Generic Letter 93-05, which reduced the surveillance requirements for testing of Diesel Generators during power operation.
6. Generic Letter 94-01, which removed the accelerated testing and special reporting requirements for Emergency Diesel Generators.