



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 1
P.O. Box 249
Buchanan, NY 10511-0249

June 27, 2002

Re: Indian Point Unit Nos. 1 and 2
Docket Nos. 50-3 and 50-247
NL-02-090

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station O-P1-17
Washington, D.C. 20555-0001

Subject: Additional Page - 2000 Annual Effluent and Waste
Disposal Report

Reference: Con Edison Letter to USNRC dated May 1, 2001

Dear Sir:

The purpose of this letter is to provide additional information pertaining to the 2000 Annual Effluent and Waste Disposal Report for Indian Point Units 1 and 2, previously submitted by Consolidated Edison in accordance with Regulatory Guide 1.21. Entergy Nuclear Operations, Inc. (ENO) has determined that a tabulation of estimated nuclide composition data for solid waste Class C shipments made during the reporting period, was inadvertently omitted from the report. The omission of this data does not affect the previously reported total curie quantity for Class C solid waste. Page D-1a (attached) supplements Section D Solid Waste of the subject report.

No new regulatory commitments are being made by ENO in this correspondence.

Should you have any questions regarding this matter, please contact Mr. John McCann, Manager, Nuclear Safety and Licensing at (914) 734-5074.

Sincerely,

A handwritten signature in black ink, appearing to read "Fred Dacimo".

Fred Dacimo
Vice President - Operations
Indian Point 2

Attachment

IE48

cc: Mr. Hubert J. Miller
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Patrick D. Milano, Senior Project Manager
Project Directorate I
Division of Licensing Project Management
U.S. Nuclear Regulatory Commission
Mail Stop O-8-C2
Washington, D.C. 20555

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Attn. Chief, Compliance Section
New York State DEC
Division of Water
50 Wolf Road
Albany, NY 12233

Attn. Regional Water Engineer
New York State DEC
200 White Plains Road
Tarrytown, NY 10591-5805

ATTACHMENT TO NL-02-090

ADDITIONAL PAGE D-1a
FOR
ANNUAL EFFLUENT AND WASTE DISPOSAL REPORT

Entergy Nuclear Operations Inc.
Indian Point Unit Nos. 1 & 2
Docket Nos. 50-03 & 50-247
June 2002

Waste Class C

| <u>Nuclide Name</u> | <u>Percent Abundance</u> | <u>Curies</u> |
|---------------------|--------------------------|---------------|
| H-3 | 0.415 | 3.04E-1 |
| C-14 | 0.238 | 1.74E-1 |
| Mn-54 | 0.0 | 1.11E-4 |
| Fe-55 | 18.993 | 1.39E+1 |
| Co-58 | 0.0 | 1.29E-4 |
| Co-60 | 44.272 | 3.24E+1 |
| Ni-59 | 0.836 | 6.12E-1 |
| Ni-63 | 12.598 | 9.22E+0 |
| Sr-90 | 0.022 | 1.60E-2 |
| Zr-95 | 0.0 | 2.29E-5 |
| Nb-94 | 0.001 | 5.58E-4 |
| Tc-99 | 0.068 | 4.99E-2 |
| Cs-137 | 22.546 | 1.65E+1 |
| Pu-238 | 0.001 | 5.55E-4 |
| Pu-239 | 0.001 | 4.35E-4 |
| Pu-240 | 0.0 | 1.03E-4 |
| Pu-241 | 0.004 | 2.99E-3 |
| Am-241 | 0.002 | 1.70E-3 |
| Cm-242 | 0.001 | 5.90E-4 |
| Cm-244 | 0.001 | 4.82E-4 |