

PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 14, 1993

Docket No. 50-331

*See Proposed
Change to T/S*

Mr. Lee Liu
Chairman of the Board and
Chief Executive Officer
Iowa Electric Light and Power Company
Post Office Box 351
Cedar Rapids, Iowa 52406

Dear Mr. Liu:

SUBJECT: AMENDMENT NO. 193 TO FACILITY OPERATING LICENSE NO. DPR-49
(TAC NO. M82328)

The Commission has issued the enclosed Amendment No. 193 to Facility Operating License No. DPR-49 for the Duane Arnold Energy Center. This amendment consists of changes to the Technical Specifications in response to your application dated December 19, 1991 and supplemented by additional information dated August 25, October 8, and November 24, 1992, and March 8, 1993.

The amendment revises the Technical Specifications by incorporating extended allowable out-of-service times and surveillance test intervals for reactor protection system, isolation actuation system, emergency core cooling system and control rod block function instrumentation. Additional editorial changes for clarity and consistency were also made.

A copy of the Safety Evaluation is also enclosed. Notice of issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Robert M. Pulsifer, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 193 to License No. DPR-49
- 2. Safety Evaluation

cc w/enclosures:
See next page

9309090264 930814
PDR ADDCK 05000331
P PDR

DFOI
CP-1
dir

Mr. Lee Liu
Iowa Electric Light and Power Company

Duane Arnold Energy Center

cc:

Jack Newman, Esquire
Kathleen H. Shea, Esquire
Newman and Holtzinger
1615 L Street, N.W.
Washington, D.C. 20036

Chairman, Linn County
Board of Supervisors
Cedar Rapids, Iowa 52406

Iowa Electric Light and Power Company
ATTN: David L. Wilson
Plant Superintendent, Nuclear
3277 DAEC Road
Palo, Iowa 52324

Mr. John F. Franz, Jr.
Vice President, Nuclear
Duane Arnold Energy Center
3277 DAEC Road
Palo, Iowa 52324

Mr. Keith Young
Manager, Nuclear Licensing
Duane Arnold Energy Center
3277 DAEC Road
Palo, Iowa 52324

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
Rural Route #1
Palo, Iowa 52324

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Stephen N. Brown
Utilities Division
Iowa Department of Commerce
Lucas Office Building, 5th Floor
Des Moines, Iowa 50319