

Do not file

Docket No. 50-~~301~~²⁶⁶

NOV 17 1970

Wisconsin Electric Power Company
Wisconsin Michigan Power Company
ATTN: Mr. John G. Quale
President
231 West Michigan Street
Milwaukee, Wisconsin 53201

Change No. 1
License No. DPR-24

Gentlemen:

This is in response to your letter dated October 5, 1970, requesting the following change in the operating license for Point Beach Unit No. 1: The Licensee has volunteered to effect such changes in its equipment and/or operations as will reduce radiation exposures and releases of radioactive materials to unrestricted areas as far below the limits specified in 10 CFR Part 20 as the state of the art in the reduction of such emissions will allow, and to propose, on or before June 1, 1971, for incorporation herein, appropriate provisions to effectuate the foregoing. We have designated this as Change No. 1 to the Technical Specifications for Point Beach Nuclear Plant, Unit 1.

We have concluded that the proposed change does not involve significant hazard considerations not described or implicit in the Final Facility Description and Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered.

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specification change outlined in your letter dated October 5, 1970, is hereby authorized. To effect this change, replace pages 15.3.9-1 and 15.3.9-2 of the Technical Specifications of Facility Operating License No. DPR-24 with the revised pages 15.3.9-1 (Change No. 1) and 15.3.9-2 (Change No. 1) enclosed.

OFFICE ▶							
SURNAME ▶							<i>d</i>
DATE ▶							

Wisconsin Electric Power Company -2-
 Wisconsin Michigan Power Company

In addition, certain numerical values in the Basis of Specification 15.3.1(D) are noted to be inconsistent with values in Specification 15.3.1(C). You are hereby authorized to change the value of the specific energy of the reactor coolant activity on page 15.3.1-12a from 193 to 162 Mev Ci/dis m³ and the value of the yearly whole body dose at the site boundary on pages 15.3.1-12a and 15.3.1-13 from 0.29 to 0.24 R/yr. These values would then correspond to the correct value of the specific energy stated in Specification 15.3.1(c). To effect this change, replace pages 15.3.1-12a and 15.3.1-13 with the revised pages 15.3.1-12a (Change No. 1) and 15.3.1-13 (Change No. 1) enclosed.

Sincerely,

J. Schroeder

for Peter A. Morris, Director
 Division of Reactor Licensing

Enclosure:
 Revised pages

cc: Robert H. Gorske, General Counsel
 Wisconsin Electric Power Company &
 Wisconsin Michigan Power Company
 231 West Michigan Street
 Milwaukee, Wisconsin 53201

John K. Babbitt, Vice President & General Manager
 Wisconsin Michigan Power Company
 807 South Oneida Street
 Appleton, Wisconsin 54911

Distribution:

AEC Pub. Doc. Room
 Docket File
 DR Reading
 DRL Reading
 PWR-1 Reading
 C. K. Beck
 M. M. Mann
 S. H. Hanauer
 F. Schroeder

R. C. DeYoung
 R. S. Boyd
 D. J. Skovholt
 T. R. Wilson
 E. G. Case
 R. Maccary
 R. W. Klecker
 H. K. Shapar
 OGC
 DRS/DRL BC's
 N. Brown
 M. McCoy
 K. Kniel

OFFICE ▶	RL:PWR-1	RL:PWR-1	AD/PWR	RL	RL	OGC
SURNAME ▶	Kniel:lm <i>KK</i>	<i>K. Kniel for</i> Muller	<i>DeYoung</i>	<i>Schroeder</i>	<i>Morris</i>	<i>Shapar</i>
DATE ▶	11/4/70	11/4/70	11/4/70	11/17/70	11/17/70	1/17/70

Wisconsin Electric Power Company
Wisconsin Michigan Power Company
ATTN: Mr. John G. Quale
President
231 West Michigan Street
Milwaukee, Wisconsin 53201

Change No. 1
License No. DPR-24

Gentlemen:

This is in response to your letter dated October 5, 1970, requesting a change in the operating license for Point Beach Unit No. 1 related to equipment and/or operations that would reduce releases of radioactive materials to unrestricted areas. We have designated this as Change No. 1 to the Technical Specifications for Point Beach Nuclear Plant, Unit 1.

Your proposed change incorporates a commitment that on or before June 1, 1971, you will request authorization of the Atomic Energy Commission to effect changes in your facility which would reduce radiation exposures and releases of radioactive materials to the environs in accordance with the then current state of the art. This is an administrative change which in no way at this time alters the design and operating procedures of Unit 1. On this basis, we have concluded that the proposed change does not involve significant hazard considerations not described or implicit in the Final Facility Description and Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered.

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specification change outlined in your letter dated October 5, 1970, is hereby authorized. To effect this change, replace pages 15.3.9-1 and 15.3.9-2 of the Technical Specifications of Facility Operating License No. DPR-24 with the revised pages 15.3.9-1 (Change No. 1) and 15.3.9-2 (Change No. 1) enclosed.

OFFICE ▶						
SURNAME ▶						
DATE ▶						