

DMB-MJ-016


JUL 06 1981

DISTRIBUTION:

- ~~Docket File~~
- NRC PDR
- L PDR
- NSIC
- TERA
- ORB#3 Rdg
- DEisenhut
- RAClark
- PMKreutzer-3
- TColburn
- OELD
- I&E-4
- GDeegan- 4
- JWetmore
- ACRS-10
- Gray Files

Docket Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201



Dear Mr. Burstein:

On June 24, 1981, the Commission issued Amendment Nos. 50 and 54 to Facility Operating License Nos. DPR-24 and DPR-27 for the Point Beach Nuclear Plant, Unit Nos. 1 and 2. The amendments consisted of a revised definition of operability and several new specifications addressing the limiting conditions for operation. They also addressed inoperability of safety-related systems due solely to loss of their normal emergency power supplies.

Page 15.6.11-1 which was transmitted with Amendments 50 and 54 contained a typographical error. Please replace that page with the enclosed corrected page 15.6.11-1.

Please accept our appologies for any inconvenience this error may have caused you.

Sincerely,

Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Corrected page 15.6.11-1

cc: See next page

REGULATORY DOCKET FILE COPY

8107140180 810706
PDR ADCK 05000266
P PDR

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL				
SURNAME	PMKreutzer	TColburn/pn	RAClark				
DATE	7/6/81	7/7/81	7/7/81				



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 06 1981

Docket Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

On June 24, 1981, the Commission issued Amendment Nos. 50 and 54 to Facility Operating License Nos. DPR-24 and DPR-27 for the Point Beach Nuclear Plant, Unit Nos. 1 and 2. The amendments consisted of a revised definition of operability and several new specifications addressing the limiting conditions for operation. They also addressed inoperability of safety-related systems due solely to loss of their normal emergency power supplies.

Page 15.6.11-1 which was transmitted with Amendments 50 and 54 contained a typographical error. Please replace that page with the enclosed corrected page 15.6.11-1.

Please accept our apologies for any inconvenience this error may have caused you.

Sincerely,

A handwritten signature in cursive script that reads "Robert A. Clark".

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Corrected page 15.6.11-1

cc: See next page

15.6.11 RADIATION PROTECTION PROGRAM

Specification

Radiological control procedures shall be written and made available to all station personnel, and shall state permissible radiation exposure levels. The radiation protection program shall meet the requirements of 10 CFR 20, with the exception of the following:

Paragraph 20.203 - Caution signs, labels and signals

In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mRem/hr but less than 1000 mRem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit* as described in Point Beach Nuclear Plant Health Physics Administrative Control Policies and Procedures Manual, Section 2.7. Any individual or group of individuals permitted to enter such areas shall be provided with at least one of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of these conditions.
- c. Coverage by an individual qualified in radiation protection procedures who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance as specified by the facility Health Physics Supervisor on the Radiation Work Permit.

The requirements above shall also apply to each high radiation area in which the intensity of radiation is greater than 1000 mRem/hr. In addition, locked doors shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Duty Shift Supervisor and the plant Health Physicist.

*Health Physics qualified personnel or personnel escorted by Health Physics personnel shall be exempt from the Radiation Work Permit issuance requirement during the performance of their assigned radiation protection duties, provided they comply with approved radiation protection procedures as they relate to entry into high radiation areas.

Wisconsin Electric Power Company

cc:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. William Guldmond
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
302 E. Washington Avenue
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702