

November 13, 1996

Distribution w/encls:

Mr. Robert E. Link, Vice President  
Nuclear Power Department  
Wisconsin Electric Power Company  
231 West Michigan Street, Room P379  
Milwaukee, WI 53201

Docket File GH11(4)  
PUBLIC JCaldwell, RIII  
PD3-1 Reading CGrimes  
JRoe ACRS  
JMcCormick-Barger, RIII  
OGC EAdensam (EGA1)

SUBJECT: POINT BEACH NUCLEAR PLANT, UNIT NOS. 1 AND 2 - CORRECTION TO  
AMENDMENT NOS. 169 AND 173 RE: INCORPORATION OF APPENDIX J OPTION B  
(TAC NOS. M95668 AND M95669)

Dear Mr. Link:

On October 9, 1996, the Commission issued Amendment Nos. 169 and 173 to Facility Operating License Nos. DPR-24 and DPR-27 for the Point Beach Nuclear Plant, Unit Nos. 1 and 2, respectively. The amendments revised the technical specifications to incorporate the provisions of 10 CFR Part 50, Appendix J, Option B.

The amendments for both Units 1 and 2 were inadvertently issued with an incorrect version of TS page 15.6.12-1. Copies of the corrected TS page 15.6.12-1 for Units Nos. 1 and 2 are enclosed.

We regret any inconvenience this oversight may have caused. If you have any questions on this action, please call me at 301/415-1380.

Sincerely,

Original signed by

Linda L. Gundrum, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-266  
and 50-301

Enclosure: Corrected TS Page 15.6.12-1

cc w/encl: See next page

DOCUMENT NAME: G:\WPDOCS\PTBEACH\PTB95668.COR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PD31-PM	E	PD31-LA	E	PD31-D
NAME	LGundrum		CJamerson		JHannon
DATE	11/13/96		11/13/96		11/13/96

OFFICIAL RECORD COPY

9611180082 961113  
PDR ADOCK 05000266  
P PDR

**NRC FILE CENTER COPY**

DF01/1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

November 13, 1996

Mr. Robert E. Link, Vice President  
Nuclear Power Department  
Wisconsin Electric Power Company  
231 West Michigan Street, Room P379  
Milwaukee, WI 53201

SUBJECT: POINT BEACH NUCLEAR PLANT, UNIT NOS. 1 AND 2 - CORRECTION TO  
AMENDMENT NOS. 169 AND 173 RE: INCORPORATION OF APPENDIX J OPTION B  
(TAC NOS. M95668 AND M95669)

Dear Mr. Link:

On October 9, 1996, the Commission issued Amendment Nos. 169 and 173 to Facility Operating License Nos. DPR-24 and DPR-27 for the Point Beach Nuclear Plant, Unit Nos. 1 and 2, respectively. The amendments revised the technical specifications to incorporate the provisions of 10 CFR Part 50, Appendix J, Option B.

The amendments for both Units 1 and 2 were inadvertently issued with an incorrect version of TS page 15.6.12-1. Copies of the corrected TS page 15.6.12-1 for Units Nos. 1 and 2 are enclosed.

We regret any inconvenience this oversight may have caused. If you have any questions on this action, please call me at 301/415-1380.

Sincerely,

A handwritten signature in cursive script, reading "Linda L. Gundrum".

Linda L. Gundrum, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-266  
and 50-301

Enclosure: Corrected TS Page 15.6.12-1

cc w/encl: See next page

Mr. Robert E. Link, Vice President  
Wisconsin Electric Power Company

Point Beach Nuclear Plant  
Unit Nos. 1 and 2

cc:

Ernest L. Blake, Jr.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, N.W.  
Washington, DC 20037

Mr. Scott A. Patulski, General Manager  
Point Beach Nuclear Plant  
Wisconsin Electric Power Company  
6610 Nuclear Road  
Two Rivers, Wisconsin 54241

Mr. Ken Duveneck  
Town Chairman  
Town of Two Creeks  
13017 State Highway 42  
Mishicot, Wisconsin 54228

Chairman  
Public Service Commission  
of Wisconsin  
P.O. Box 7854  
Madison, Wisconsin 53707-7854

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
6612 Nuclear Road  
Two Rivers, Wisconsin 54241

Ms. Sarah Jenkins  
Electric Division  
Public Service Commission of Wisconsin  
P.O. Box 7854  
Madison, Wisconsin 53707-7854

#### 15.6.12 CONTAINMENT LEAKAGE RATE TESTING PROGRAM

- A. A program shall be established to implement the leakage rate testing of the containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in Regulatory Guide 1.163, "Performance-Based Containment Leak-Test Program," dated September, 1995, as modified by the following exceptions"
  - 1. The interval between the 1992 Unit 2 Type A test and the next Unit 2 Type A test shall be 60 months.
- B. The peak design containment internal accident pressure,  $P_a$  is 60 psig.
- C. The maximum allowable primary containment leakage rate,  $L_a$  at  $P_a$ , shall be 0.4% of containment air weight per day.
- D. Leakage rate acceptance criteria are:
  - 1. The containment leakage rate acceptance criterion is  $\leq 1.0 L_a$ .
  - 2. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are  $\leq 0.6 L_a$  for the combined Type B and Type C tests and  $\leq 0.75 L_a$  for Type A tests.
- E. The provisions of Specification 15.4.0.2 do not apply to the test frequencies specified in the Containment Leakage Rate Testing Program.
- F. The provisions of Specification 15.4.0.3 are applicable to the Containment Leakage Rate Testing Program.

9611180088 961113  
PDR ADOCK 05000266  
P PDR

Unit 1 - Amendment No. 169  
Unit 2 - Amendment No. 173

15.6.12-1

Corrected November 13, 1996

#### 15.6.12 CONTAINMENT LEAKAGE RATE TESTING PROGRAM

- A. A program shall be established to implement the leakage rate testing of the containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in Regulatory Guide 1.163, "Performance-Based Containment Leak-Test Program," dated September, 1995, as modified by the following exceptions"
  - 1. The interval between the 1992 Unit 2 Type A test and the next Unit 2 Type A test shall be 60 months.
- B. The peak design containment internal accident pressure,  $P_a$  is 60 psig.
- C. The maximum allowable primary containment leakage rate,  $L_a$  at  $P_a$ , shall be 0.4% of containment air weight per day.
- D. Leakage rate acceptance criteria are:
  - 1. The containment leakage rate acceptance criterion is  $\leq 1.0 L_a$ .
  - 2. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are  $\leq 0.6 L_a$  for the combined Type B and Type C tests and  $\leq 0.75 L_a$  for Type A tests.
- E. The provisions of Specification 15.4.0.2 do not apply to the test frequencies specified in the Containment Leakage Rate Testing Program.
- F. The provisions of Specification 15.4.0.3 are applicable to the Containment Leakage Rate Testing Program.