

July 16, 2002

Mr. John L. Skolds, President  
Exelon Nuclear  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Dear Mr. Skolds:

This letter confirms the discussion between members of our staffs to discuss the contested Cited Violation contained in NRC Inspection Report 50-456/010-11; 50-457/010-11 for the Braidwood Station, Units 1 and 2. The Cited Violation involved an inadequate procedure which could allow the essential service water average temperature to exceed the Design Basis and Technical Specification Section 3.7.9 maximum temperature of 100 degrees Fahrenheit. The meeting will be held Thursday, July 18, 2002, from 1:00 p.m. to 2:00 p.m. at the NRC Region III office in Lisle, Illinois. This meeting is open to the public.

We will gladly discuss any questions you may have concerning this matter.

Sincerely,

*/RA/*

Ann Marie Stone, Chief  
Branch 3  
Division of Reactor Projects

Docket Nos. 50-456; 50-457  
License Nos. NPF-72; NPF-77

See Attached Distribution

DOCUMENT NAME: G:\brai\ML021970668.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RIII			RIII		RIII	
NAME	AStone/trn						
DATE	07/16/02						

**OFFICIAL RECORD COPY**

cc w/encl: Site Vice President - Braidwood  
Braidwood Station Plant Manager  
Regulatory Assurance Manager - Braidwood  
Chief Operating Officer  
Senior Vice President - Nuclear Services  
Senior Vice President - Mid-West Regional  
Operating Group  
Vice President - Mid-West Operations Support  
Vice President - Licensing and Regulatory Affairs  
Director Licensing - Mid-West Regional  
Operating Group  
Manager Licensing - Braidwood and Byron  
Senior Counsel, Nuclear, Mid-West Regional  
Operating Group  
Document Control Desk - Licensing  
M. Aguilar, Assistant Attorney General  
Illinois Department of Nuclear Safety  
State Liaison Officer  
Chairman, Illinois Commerce Commission

ADAMS Distribution:

AJM

DFT

MLC

RidsNrrDipmlipb

GEG

HBC

SPR

C. Ariano (hard copy)

DRPIII

DRSIII

PLB1

JRK1