



James E. McGreevey
Governor

State of New Jersey
Department of Environmental Protection

Bradley M. Campbell
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Bureau of Nuclear Engineering
P.O.Box - 415
Trenton, NJ 08625-0415

June 14, 2002

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
Amendment to Facility Operating License
License Change Request H02-05

The subject request was submitted to the NRC by PSE&G letter dated April 3, 2002. The request proposes to relocate the contents of Technical Specification 3/4.4.4 Reactor Coolant System Chemistry, to the UFSAR. The Utility also plans a noble metal injection program to commence at the beginning of the next refueling outage. Having the chemistry specifications located in the UFSAR will enable them to make necessary adjustments without having to submit additional License Change Requests.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10CFR50.91 (b). The State of New Jersey has no comment.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

1A001

c: Distribution

J. Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

R. Bores
NRC Region I State Liaison Officer

J. Shoppy
NRC Sr. Resident Inspector

G. Wunder
NRC Project Manager

G. Salamon
PSE&G