

October 18, 1988

Docket Nos. 50-361 and 50-362

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Company
101 Ash Street
P.O. Box 1831
San Diego, California 92112

Gentlemen:

SUBJECT: ISSUANCE OF AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. NPF-10 AND AMENDMENT NO. 37 TO FACILITY OPERATING LICENSE NO. NPF-15 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 (TAC NOS. 69329 AND 69330)

The Commission has issued the enclosed amendments to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. The amendment consist of changes to the Technical Specifications in response to your application dated September 13, 1988.

The amendments delete the onsite and offsite organization charts and revise the reporting responsibility of both the Independent Safety Engineering Group and the Nuclear Safety Group.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

original signed by

Donald E. Hickman, Project Manager
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosures:

1. Amendment No. 68 to License No. NPF-10
2. Amendment No. 37 to License No. NPF-15
3. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION

Docket File	BGrimes
NRC & LPDRs	TBarnhart (8)
PD5 Plant File	EButcher
MVirgilio	ACRS (10)
JLee	GPA/PA
OGC-WF	ARM/LFMB
DHagan	WJones
EJordan	DHickman

DRSP/PD5
JLee
10/4/88

DRSP/PD5
DHickman:
10/19/88

OGC
CPW
10/6/88

DRSP/PD5
GWK/gwkon
10/18/88

m.m.
WFO
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
October 18, 1988

Docket Nos. 50-361 and 50-362

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Company
101 Ash Street
P.O. Box 1831
San Diego, California 92112

Gentlemen:

SUBJECT: ISSUANCE OF AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. NPF-10 AND AMENDMENT NO. 37 TO FACILITY OPERATING LICENSE NO. NPF-15 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 (TAC NOS. 69329 AND 69330)

The Commission has issued the enclosed amendments to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. The amendments consist of changes to the Technical Specifications in response to your application dated September 13, 1988.

The amendments delete the onsite and offsite organization charts and revise the reporting responsibility of both the Independent Safety Engineering Group and the Nuclear Safety Group.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Donald E. Hickman".

Donald E. Hickman, Project Manager
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosures:

1. Amendment No. 68 to License No. NPF-10
2. Amendment No. 37 to License No. NPF-15
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. Kenneth P. Baskin
Southern California Edison Company

San Onofre Nuclear Generating
Station, Units 2 and 3

cc:

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Mr. Hans Kaspar, Executive Director
Marine Review Committee, Inc.
531 Encinitas Boulevard, Suite 105
Encinitas, California 92024

Charles R. Kocher, Esq.
James A. Beoletto, Esq.
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. Mark Medford
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Orrick, Herrington & Sutcliffe
ATTN: David R. Pigott, Esq.
600 Montgomery Street
San Francisco, California 94111

Mr. Robert G. Lacy
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Alan R. Watts, Esq.
Rourke & Woodruff
701 S. Parker St. No. 7000
Orange, California 92668-4702

Richard J. Wharton, Esq.
University of San Diego School of
Law
Environmental Law Clinic
San Diego, California 92110

Mr. S. McClusky
Bechtel Power Corporation
P. O. Box 60860, Terminal Annex
Los Angeles, California 90060

Charles E. McClung, Jr., Esq.
Attorney at Law
24012 Calle de la Plaza/Suite 330
Laguna Hills, California 92653

Mr. C. B. Brinkman
Combustion Engineering, Inc.
7910 Woodmont Avenue, Suite 1310
Bethesda, Maryland 20814

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane/Suite 210
Walnut Creek, California 94596

Mr. Dennis F. Kirsh
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Resident Inspector, San Onofre NPS
c/o U. S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, California 92672

Mr. Dennis M. Smith, Chief
Radiological Programs Division
Governor's Office of Emergency Services
2800 Meadowview Road
Sacramento, California 95832

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City of Riverside
City Hall
3900 Main Street
Riverside, California 92522



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 68
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the license for San Onofre Nuclear Generating Station, Unit 2 (the facility) filed by Southern California Edison Company (SCE) on behalf of itself and San Diego Gas and Electric Company, the City of Riverside, California and the City of Anaheim, California (licensees) dated September 13, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8810260147 881018
PDR ADOCK 05000361
P PDC


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 68, are hereby incorporated in the license. SCE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 18, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 68

FACILITY OPERATING LICENSE NO. NPF-10

DOCKET NO. 50-361

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change. Also enclosed are the following overleaf pages to the amended pages.

<u>AMENDMENT PAGE</u>	<u>OVERLEAF PAGE</u>
6-1	-
6-1a	-
6-2	-
6-3	6-4
6-5	6-6
6-12	6-11

ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

6.1.1 The Station Manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.

6.1.2 The Shift Supervisor (or during his absence from the Control Room Area, a designated individual) shall be responsible for the Control Room command function. A management directive to this effect, signed by the Vice-President of Nuclear Operations shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

OFFSITE

6.2.1 Onsite and offsite organizations shall be established for unit operation and corporate management, respectively. The onsite and offsite organizations shall include the positions for activities affecting the safety of the nuclear power plant.

- a. Lines of authority, responsibility, and communication shall be established and defined for the highest management levels through intermediate levels to and including all operating organization positions. These relationships shall be documented and updated, as appropriate, in the form of organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements shall be documented in the FSAR.
- b. The Station Manager shall be responsible for overall unit safe operation and shall have control over those onsite activities necessary for safe operation and maintenance of the plant.
- c. The Vice President, Nuclear Engineering, Safety, and Licensing and the Vice President and Site Manager shall have corporate responsibility for overall plant nuclear safety. The Vice President and Site Manager shall take any measures needed to ensure acceptable performance of the staff in operating and maintaining the plant to ensure nuclear safety. The Vice President, Nuclear Engineering, Safety and Licensing shall take any measures needed to ensure acceptable performance of the staff in providing technical support to the plant to ensure nuclear safety.
- d. The individuals who train the operating staff and those who carry out health physics and quality assurance functions may report to the appropriate onsite manager; however, they shall have sufficient organizational freedom to ensure their independence from operating pressures.

ADMINISTRATIVE CONTROLS

UNIT STAFF

- 6.2.2 a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the Control Room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3 or 4, at least one licensed Senior Reactor Operator shall be in the Control Room area identified as such on Table 6.2-1.
- c. A health physics technician[#] shall be on site when fuel is in the reactor.
- d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- e. A site Fire Brigade of at least 5 members shall be maintained onsite at all times.[#] The Fire Brigade shall not include the Shift Supervisor and the 2 other members of the minimum shift crew necessary for safe shutdown of the unit and any personnel required for other essential functions during a fire emergency.
- f. Reserved.
- g. The Plant Superintendent (at time of appointment), Shift Superintendents and Control Room Supervisors shall hold a senior reactor operator license. The Control Operators and Assistant Control Operators shall hold a reactor operator license.

[#]The health physics technician and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.

(This page intentionally blank)

(This page intentionally blank)

Table 6.2-1

MINIMUM SHIFT CREW COMPOSITION

WITH UNIT 3 IN MODE 5 OR 6 OR DE-FUELED		
POSITION	NUMBER OF INDIVIDUALS REQUIRED TO FILL POSITION	
	MODES 1, 2, 3 & 4	MODES 5 & 6
SS	1 ^a	1 ^a
SRO	1	None
RO	2	1 ^b
AO	2	2 ^b
STA	1	None

WITH UNIT 3 IN MODE 1, 2, 3 or 4		
POSITION	NUMBER OF INDIVIDUALS REQUIRED TO FILL POSITION	
	MODES 1, 2, 3 & 4	MODES 5 & 6
SS	1 ^a	1 ^a
SRO	1 ^a	None
RO	2 ^b	1
AO	2 ^b	1
STA	1 ^a	None

^aIndividual may fill the same position on Unit 3

^bOne of the two required individuals may fill the same position on Unit 3

- SS - Shift Supervisor with a Senior Reactor Operators License on Units 2 and 3
- SRO - Individual with a Senior Reactor Operators License on Units 2 and 3
- RO - Individual with a Reactor Operators License on Units 2 and 3
- AO - Auxiliary Operator
- STA - Shift Technical Advisor

Except for the Shift Supervisor, the Shift Crew Composition may be one less than the minimum requirements of Table 6.2-1 for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the Shift Crew Composition to within the minimum requirements of Table 6.2-1. This provision does not permit any shift crew position to be unmanned upon shift change due to an oncoming shift crewman being late or absent.

During any absence of the Shift Supervisor from the Control Room Area shown in Figure 6.2-3 while the unit is in MODE 1, 2, 3 or 4, an individual (other than the Shift Technical Advisor) with a valid SRO license shall be designated to assume the Control Room command function. During any absence of the Shift Supervisor from the Control Room Area shown in Figure 6.2-3 while the unit is in MODE 5 or 6, an individual with a valid SRO or RO license shall be designated to assume the Control Room command function.

ADMINISTRATIVE CONTROLS

6.2.3 INDEPENDENT SAFETY ENGINEERING GROUP (ISEG)

FUNCTION

6.2.3.1 The ISEG shall function to examine plant operating characteristics, NRC issuances, industry advisories, Licensee Event Reports and other sources of plant design and operating experience information which may indicate areas for improving plant safety.

COMPOSITION

6.2.3.2 The ISEG shall be composed of at least five dedicated full-time engineers. Each shall have a Bachelor's Degree in Engineering or Physical Science or equivalent and at least two years professional level experience in his field. Off-duty qualified Shift Technical Advisors may be used to fulfill this requirement.

RESPONSIBILITIES

6.2.3.3 The ISEG shall be responsible for maintaining surveillance of plant activities to provide independent verification* that these activities are performed correctly and that human errors are reduced as much as practical.

AUTHORITY

6.2.3.4 The ISEG shall make detailed recommendations for revised procedures, equipment modifications, maintenance activities, operations activities or other means of improving plant safety to offsite organization management.

RECORDS

6.2.3.5 Records of activities performed by the ISEG shall be prepared, maintained, and forwarded each calendar month to offsite organization management.

6.2.4 SHIFT TECHNICAL ADVISOR

The Shift Technical Advisor shall provide technical support to the Shift Supervisor in the areas of thermal hydraulics, reactor engineering and plant analysis with regard to the safe operation of the unit. The Shift Technical Advisor shall have a Bachelor's Degree or equivalent in a scientific or engineering discipline with specific training in plant design and in the response and analysis of the plant for transients and accidents.

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for the Health Physics Manager who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975.

* Not responsible for sign-off function.

ADMINISTRATIVE CONTROLS

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall be maintained under the direction of the Manager, Nuclear Training and shall meet or exceed the requirements and recommendations of Sections 5.5 of ANSI N18.1-1971 and Appendix "A" of 10 CFR Part 55 and the supplemental requirements specified in Section A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, and shall include familiarization with relevant industry operational experience identified by the ISEG.

6.5 REVIEW AND AUDIT

6.5.1 ONSITE REVIEW COMMITTEE (OSRC)

FUNCTION

6.5.1.1 The Onsite Review Committee shall function to advise the Station Manager on all matters related to nuclear safety.

COMPOSITION

6.5.1.2 The Onsite Review Committee shall be composed of the:

Chairman:	Station Manager
Member:	Deputy Station Manager
Member:	Manager, Operations
Member:	Manager, Technical
Member:	Plant Superintendent SONGS Unit 2 & 3
Member:	Supervisor of I&C
Member:	Manager, Health Physics
Member:	Supervisor of Chemistry
Member:	Manager, Maintenance
Member:	Supervising Engineer (NSSS, NSSS Support, Computer, or STA)
Member:	San Diego Gas & Electric Representative, Senior Engineer ⁽¹⁾

ALTERNATES

6.5.1.3 All alternate members shall be appointed in writing by the OSRC Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in OSRC activities at any one time.

⁽¹⁾ BS degree in Engineering or Physical Science plus at least four years professional level experience in his field. At least one of the four years experience shall be nuclear power plant experience.

ADMINISTRATIVE CONTROLS

- d. Proposed changes to Technical Specifications or this Operating License.
- e. Violations of codes, regulations, orders, Technical Specifications, license requirements, or of internal procedures or instructions having nuclear safety significance.
- f. Significant operating abnormalities or deviations from normal and expected performance of unit equipment that affect nuclear safety.
- g. Events requiring 24 hour written notification to the Commission.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meetings minutes of the Onsite Review Committee.

AUDITS

6.5.3.5 Audits of unit activities shall be performed under the cognizance of the NSG. These audits shall encompass:

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. Any other area of unit operation considered appropriate by the Nuclear Safety Group or Manager of Nuclear Operations.
- f. The Fire Protection Program and implementing procedures at least once per 24 months.
- g. An independent fire protection and loss prevention inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- h. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

ADMINISTRATIVE CONTROLS

AUTHORITY

6.5.3.6 The NSG shall report to and advise the offsite organization management on those areas of responsibility specified in Sections 6.5.3.4 and 6.5.3.5.

RECORDS

6.5.3.7 Records of NSG activities shall be prepared and maintained. Report of reviews and audits shall be distributed monthly to the Station Manager and to the management positions responsible for the areas audited.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 37
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the license for San Onofre Nuclear Generating Station, Unit 2 (the facility) filed by Southern California Edison Company (SCE) on behalf of itself and San Diego Gas and Electric Company, the City of Riverside, California and the City of Anaheim, California (licensees) dated September 13, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 37, are hereby incorporated in the license. SCE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 18, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 37

FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change. Also enclosed are the following overleaf pages to the amended pages.

<u>AMENDMENT PAGE</u>	<u>OVERLEAF PAGE</u>
6-1	-
6-1a	-
6-2	-
6-3	-
6-4	-
6-7	6-8
6-13	6-14

Pages 6-9 and 6-10 are reissued without change.

ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

6.1.1 The Station Manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.

6.1.2 The Shift Supervisor (or during his absence from the Control Room Area, a designated individual) shall be responsible for the Control Room command function. A management directive to this effect, signed by the Vice-President of Nuclear Operations shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

OFFSITE

6.2.1 Onsite and offsite organizations shall be established for unit operation and corporate management, respectively. The onsite and offsite organizations shall include the positions for activities affecting the safety of the nuclear power plant.

- a. Lines of authority, responsibility, and communication shall be established and defined for the highest management levels through intermediate levels to and including all operating organization positions. These relationships shall be documented and updated, as appropriate, in the form of organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements shall be documented in the FSAR.
- b. The Station Manager shall be responsible for overall unit safe operation and shall have control over those onsite activities necessary for safe operation and maintenance of the plant.
- c. The Vice President, Nuclear Engineering, Safety, and Licensing and the Vice President and Site Manager shall have corporate responsibility for overall plant nuclear safety. The Vice President and Site Manager shall take any measures needed to ensure acceptable performance of the staff in operating and maintaining the plant to ensure nuclear safety. The Vice President, Nuclear Engineering, Safety and Licensing shall take any measures needed to ensure acceptable performance of the staff in providing technical support to the plant to ensure nuclear safety.
- d. The individuals who train the operating staff and those who carry out health physics and quality assurance functions may report to the appropriate onsite manager; however, they shall have sufficient organizational freedom to ensure their independence from operating pressures.

ADMINISTRATIVE CONTROLS

UNIT STAFF

6.2.2 The Unit organization shall be as shown in Figure 6.2-2 and:

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the Control Room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3 or 4, at least one licensed Senior Reactor Operator shall be in the Control Room area identified as such on Table 6.2-1.
- c. A health physics technician[#] shall be on site when fuel is in the reactor.
- d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- e. A site Fire Brigade of at least 5 members shall be maintained onsite at all times.[#] The Fire Brigade shall not include the Shift Supervisor and the 2 other members of the minimum shift crew necessary for safe shutdown of the unit and any personnel required for other essential functions during a fire emergency.

[#]The health physics technician and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.

ADMINISTRATIVE CONTROLS

UNIT STAFF (Continued)

- f. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions; e.g., senior reactor operators, reactor operators, health physicists, auxiliary operators, and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the plant is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shut-down for refueling, major maintenance or major plant modifications, on a temporary basis, the following guidelines shall be followed:

- 1) An individual should not be permitted to work more than 16 hours straight, excluding shift turnover time.
- 2) An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period, all excluding shift turnover time.
- 3) A break of at least eight hours should be allowed between work periods, including shift turnover time.
- 4) Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the Station Manager, his deputy, the Manager, Operations or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Station Manager or his designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

- g. The Plant Superintendent (at time of appointment), Shift Superintendents and Control Room Supervisors shall hold a senior reactor operator license. The Control Operators and Assistant Control Operators shall hold a reactor operator license.

(This page intentionally blank)

(This page intentionally blank)

ADMINISTRATIVE CONTROLS

6.2.3 INDEPENDENT SAFETY ENGINEERING GROUP (ISEG)

FUNCTION

6.2.3.1 The ISEG shall function to examine plant operating characteristics, NRC issuances, industry advisories, Licensee Event Reports and other sources of plant design and operating experience information which may indicate areas for improving plant safety.

COMPOSITION

6.2.3.2 The ISEG shall be composed of at least five dedicated full-time engineers. Each shall have a Bachelor's Degree in Engineering or Physical Science or equivalent and at least two years professional level experience in his field. Off-duty qualified Shift Technical Advisors may be used to fulfill this requirement.

RESPONSIBILITIES

6.2.3.3 The ISEG shall be responsible for maintaining surveillance of plant activities to provide independent verification* that these activities are performed correctly and that human errors are reduced as much as practical.

AUTHORITY

6.2.3.4 The ISEG shall make detailed recommendations for revised procedures, equipment modifications, maintenance activities, operations activities or other means of improving plant safety to offsite organization management.

RECORDS

6.2.3.5 Records of activities performed by the ISEG shall be prepared, maintained, and forwarded each calendar month to offsite organization management.

6.2.4 SHIFT TECHNICAL ADVISOR

The Shift Technical Advisor shall provide technical support to the Shift Supervisor in the areas of thermal hydraulics, reactor engineering and plant analysis with regard to the safe operation of the unit. The Shift Technical Advisor shall have a Bachelor's Degree or equivalent in a scientific or engineering discipline with specific training in plant design and in the response and analysis of the plant for transients and accidents.

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for the Health Physics Manager who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975.

*_____

Not responsible for sign-off function.

ADMINISTRATIVE CONTROLS

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall be maintained under the direction of the Manager, Nuclear Training and shall meet or exceed the requirements and recommendations of Sections 5.5 of ANSI N18.1-1971 and Appendix "A" of 10 CFR Part 55 and the supplemental requirements specified in Section A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, and shall include familiarization with relevant industry operational experience identified by the ISEG.

6.5 REVIEW AND AUDIT

6.5.1 ONSITE REVIEW COMMITTEE (OSRC)

FUNCTION

6.5.1.1 The Onsite Review Committee shall function to advise the Station Manager on all matters related to nuclear safety.

COMPOSITION

6.5.1.2 The Onsite Review Committee shall be composed of the:

Chairman:	Station Manager
Member:	Deputy Station Manager
Member:	Manager, Operations
Member:	Manager, Technical
Member:	Plant Superintendent SONGS Units 2 and 3
Member:	Supervisor of I&C
Member:	Manager, Health Physics
Member:	Supervisor of Chemistry
Member:	Manager, Maintenance
Member:	Supervising Engineer (NSSS, NSSS Support, Computer, or STA)
Member:	San Diego Gas & Electric Representative, Senior Engineer ⁽¹⁾

ALTERNATES

6.5.1.3 All alternate members shall be appointed in writing by the OSRC Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in OSRC activities at any one time.

⁽¹⁾ BS degree in Engineering or Physical Science plus at least four years professional level experience in his field. At least one of the four years experience shall be nuclear power plant experience.

ADMINISTRATIVE CONTROLS

MEETING FREQUENCY

6.5.1.4 The OSRC shall meet at least once per calendar month and as convened by the OSRC Chairman or his designated alternate.

QUORUM

6.5.1.5 The minimum quorum of the OSRC necessary for the performance of the OSRC responsibility and authority provisions of these Technical Specifications shall consist of the Chairman or his designated alternate and four members including alternates.

RESPONSIBILITIES

6.5.1.6 The Onsite Review Committee shall be responsible for:

- a. Investigation of all violations of the Technical Specifications including the preparation and forwarding of reports covering evaluation and recommendations to prevent recurrence to the Nuclear Safety Group (NSG).
- b. Review of events requiring 24-hour written notification to the Commission.
- c. Review of unit operations to detect potential nuclear safety hazards.
- d. Performance of special reviews, investigations or analyses and reports thereon as requested by the Station Manager or the NSG.
- e. Review and documentation of judgment concerning prolonged operation in bypass, channel trip, and/or repair of defective protection channels of process variables placed in bypass since the last OSRC meeting.

AUTHORITY

6.5.1.7 The Onsite Review Committee (OSRC) shall:

- a. Render determinations in writing with regard to whether or not items considered under 6.5.1.6(a) above constitute unreviewed safety questions.
- b. Provide written notification within 24 hours to the Manager of Nuclear Operations and NSG of disagreement between the OSRC and the Station Manager; however, the Station Manager shall have responsibility for resolution of such disagreements pursuant to 6.1.1 above.

ADMINISTRATIVE CONTROLS

RECORDS

6.5.1.8 The Onsite Review Committee shall maintain written minutes of each OSRC meeting that, at a minimum, document the results of all OSRC activities performed under the responsibility and authority provisions of these technical specifications. Copies shall be provided to the Nuclear Safety Group.

6.5.2 TECHNICAL REVIEW AND CONTROL

ACTIVITIES

6.5.2.1 The Station Manager shall assure that each procedure and program required by Specification 6.8 and other procedures which affect nuclear safety, and changes thereto, is prepared by a qualified individual/organization. Each such procedure, and changes thereto, shall be reviewed by an individual/group other than the individual/group which prepared the procedure, or changes thereto, but who may be from the same organization as the individual/group which prepared the procedure, or changes thereto.

6.5.2.2 Proposed changes to the Appendix "A" Technical Specifications shall be prepared by a qualified individual/organization. The preparation of each proposed Technical Specifications change shall be reviewed by an individual/group other than the individual/group which prepared the proposed change, but who may be from the same organization as the individual/group which prepared the proposed change. Proposed changes to the Technical Specifications shall be approved by the Station Manager.

6.5.2.3 Proposed modifications to unit nuclear safety-related structures, systems and components shall be designed by a qualified individual/organization. Each such modification shall be reviewed by an individual/group other than the individual/group which designed the modification, but who may be from the same organization as the individual/group which designed the modification. Proposed modifications to nuclear safety-related structures, systems and components shall be approved prior to implementation by the Station Manager; or by the Manager, Technical as previously designated by the Station Manager.

6.5.2.4 Individuals responsible for reviews performed in accordance with 6.5.2.1, 6.5.2.2 and 6.5.2.3 shall be members of the station supervisory staff, previously designated by the Station Manager to perform such reviews. Each such review shall include a determination of whether or not additional, cross-disciplinary, review is necessary. If deemed necessary, such review shall be performed by the appropriate designated review personnel.

6.5.2.5 Proposed tests and experiments which affect station nuclear safety and are not addressed in the FSAR or Technical Specifications shall be reviewed by the Station Manager, the Manager, Technical, the Manager, Operations, the Manager, Maintenance, the Deputy Station Manager or the Manager, Health Physics as previously designated by the Station Manager.

6.5.2.6 The station security program, and implementing procedures, shall be reviewed at least once per 12 months. Recommended changes shall be approved by the Station Manager and transmitted to the Manager of Nuclear Operations and to the NSG.

ADMINISTRATIVE CONTROLS

AUDITS

- 6.5.3.5 Audits of unit activities shall be performed under the cognizance of the NSG. These audits shall encompass:
- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
 - b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
 - c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
 - d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
 - e. Any other area of unit operation considered appropriate by the Nuclear Safety Group or Manager of Nuclear Operations.
 - f. The Fire Protection Program and implementing procedures at least once per 24 months.
 - g. An independent fire protection and loss prevention inspection and audit shall be performed annually utilizing either qualified off-site licensee personnel or an outside fire protection firm.
 - h. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

AUTHORITY

6.5.3.6 The NSG shall report to and advise offsite organization management on those areas of responsibility specified in Sections 6.5.3.4 and 6.5.3.5.

RECORDS

6.5.3.7 Records of NSG activities shall be prepared and maintained. Report of reviews and audits shall be distributed monthly to the Station Manager and to the management positions responsible for the areas audited.

ADMINISTRATIVE CONTROLS

6.6 REPORTABLE OCCURRENCE ACTION

6.6.1 The following actions shall be taken for REPORTABLE OCCURRENCES:

- a. The Commission shall be notified and/or a report submitted pursuant to the requirements of Specification 6.9.
- b. Each REPORTABLE OCCURRENCE requiring 24 hour notification to the Commission shall be reviewed by the OSRC and submitted to the NSG and the Manager of Nuclear Operations.

6.7 SAFETY LIMIT VIOLATION

6.7.1 The following actions shall be taken in the event a Safety Limit is violated:

- a. The NRC Operations Center shall be notified by telephone as soon as possible and in all cases within one hour. The Manager of Nuclear Operations and the NSG Chairman shall be notified within 24 hours.
- b. A Safety Limit Violation Report shall be prepared. The report shall be reviewed by the OSRC. This report shall describe (1) applicable circumstances preceding the violation, (2) effects of the violation upon facility components, systems or structures, and (3) corrective action taken to prevent recurrence.
- c. The Safety Limit Violation Report shall be submitted to the Commission, the Manager of Nuclear Operations and the NSG within 14 days of the violation.
- d. Critical operation of the unit shall not be resumed until authorized by the Commission.

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:

- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Revision 2, February 1978.
- b. Refueling operations.
- c. Surveillance and test activities of safety related equipment.
- d. Security Plan implementation.
- e. Emergency Plan implementation.
- f. Fire Protection Program implementation.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO.110 TO PROVISIONAL OPERATING LICENSE NO. DPR-13,
AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. NPF-10, AND
AMENDMENT NO. 37 TO FACILITY OPERATING LICNESE NO. NPF-15
SOUTHERN CALIFORNIA EDISON COMPANY, ET AL
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS NO. 1, 2 AND 3
DOCKET NOS. 50-206, 50-361 AND 50-362

1.0 INTRODUCTION

By letter dated September 13, 1988, Southern California Edison Company (SCE or the licensee) requested changes to the Technical Specifications appended to Provisional Operating License No. DPR-13 for operation of San Onofre Nuclear Generating Station (SONGS), Unit No. 1, Facility Operating License No. NPF-10 for operation of SONGS Unit No. 2, and Facility Operating License No. NPF-15 for operation of SONGS Unit No. 3 in San Diego County, California. The proposed changes would delete both the onsite and offsite organization charts and revise the reporting requirement for the offsite Nuclear Safety Group for all three units, and would revise the reporting requirement for the Independent Safety Engineering Group for Units 2 and 3.

2.0 EVALUATION

The proposal to remove the organization charts from the Technical Specifications is consistent with the staff recommendation in the Generic Letter 88-06. In the generic letter the staff examined the regulatory requirements of 10 CFR 50.36 for the administrative controls to be included in Technical Specifications. The regulation states that administrative controls are the provisions relating to organization and management necessary to ensure operation of the facility in a safe manner. It has been the staff's experience that organization charts by themselves have been of little help in ensuring that the objectives of administrative control requirements are met. Specific operational requirements are included elsewhere in the Technical Specification that bear more directly on operational safety than organization charts. As examples, the organizational element responsible for the control room command function is identified separately in Technical Specifications, as are the requirements for minimum staffing under various operating conditions. The organizational management functions for independent reviews and audits, unit review, independent safety engineering groups, and shift technical advisors are also specified in other Technical Specifications.

In summary, many of the details shown on the onsite and offsite organization charts are not essential to the safe operation of the facility. Over the years, the staff experience with changes in the details of operating organizations has shown that organization charts can be modified in many ways while maintaining adequate operational safety. This experience has enabled the staff to identify those organizational characteristics that are important to safety. The staff finds that the only aspects of organization charts that are important to safety and not covered by other specifications (thus must remain in the Technical Specifications) are those conditions listed below:

- (1) Lines of authority, responsibility, and communication shall be established and defined from the highest management levels through intermediate levels to and including all operating organization positions. Those relationships shall be documented and updated, as appropriate, in the form of organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation.
- (2) Designation of an executive position that has corporate responsibility for overall plant nuclear safety and authority to take such measures as may be needed to ensure acceptable performance of staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety.
- (3) Designation of a management position in the onsite organization that is responsible for overall unit operation and has control over those onsite activities necessary for safe operation and maintenance of the plant.
- (4) Designation of those positions in the onsite organization that require a senior reactor operator (SRO) or reactor operator (RO) license.
- (5) Provisions of sufficient organizational freedom to be independent of operational pressures to those individuals who perform the function of health physics, quality assurance and training of the operating staff.

Since the proposed amendments included the above conditions in the Technical Specifications, removal of the organization charts represents no reduction in current safety requirements. These changes will simply allow the licensee to implement changes in its organization structure without obtaining NRC approval. The revisions to the reporting requirements for the Nuclear Safety Group (for all three units) and for the Independent Safety Engineering Group (for Units 2 and 3) are consistent with this goal to allow flexibility, and are also acceptable.

The proposed amendments require that the licensee must ensure that the organizational information described in (1) above is incorporated in the Final Safety Analysis Report.

The qualifications for certain positions are currently designated by organization charts as requiring a SRO or RO license. These requirements are added to the Technical Specifications by the amendments.

3.0 ENVIRONMENTAL CONSIDERATION

The amendments involve changes to administrative procedures and reporting requirements. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

4.0 BASIS FOR EXPEDITED ACTION

The licensee stated that the changes in its organization which necessitate the amendments are scheduled to be placed in effect on October 3, 1988 and requested that NRC review the proposed changes on an exigent basis. Most of the changes in the licensee's organization affect the off-site organization and design functions and as such have minimal impact on the Technical Specifications. Nevertheless, Technical Specification changes are needed in order to place the reorganization plan into effect. The amendment request conforms to the NRC guidance contained in Generic Letter 88-06 which stated that such amendments would be reviewed and approved quickly. In consideration of this, the minimal safety significance of the amendments, and the fact that undue delay of an announced reorganization would be needlessly disruptive, the NRC staff has decided to expedite its issuance as requested by the licensee.

5.0 NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (53 FR 36681) on September 15, 1988. The staff consulted with the State of California. No public comments were received, and the State of California did not have any comments. Because the proposed amendments involve only administrative matters (organizational charts and reporting) as described above, the proposed amendments do not involve changes in the probability or consequences of accidents previously evaluated or create the possibility of a new or different kind of accident or involve a significant reduction in a margin of safety. Therefore, we have concluded that the proposed amendments do not involve a significant hazards consideration.

6.0 CONCLUSION

We have concluded, based on the considerations discussed above, that:
(1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and
(2) such activities will be conducted in compliance with the Commission's regulations and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: C. Trammell and D. Hickman

Dated: October 18, 1988