

February 16, 1989

Docket Nos.: 50-361 and 50-362

Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas and Electric Company  
101 Ash Street  
Post Office Box 1831  
San Diego, California 92112

Gentlemen:

SUBJECT: ISSUANCE OF NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
(TAC NOS. 68003 AND 68004)

Enclosed for your information is a Notice of Consideration of Issuance of Amendments to Facility Operating Licenses and Opportunity for Hearing. The notice relates to your request of April 26, 1988 to revise Technical Specification 3/4.3.1, "Reactor Protective Instrumentation," and Technical Specification 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation." This request was designated by you as PCN-251.

The Notice has been sent to the Office of the Federal Register for publication.

Sincerely,

original signed by  
Donald E. Hickman, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
Notice

cc w/enclosure:  
See next page

DISTRIBUTION

Docket File  
NRC & LPDRs  
PDV Reading  
GMHolahan  
JLee  
OGC

DHagan  
ACRS (10)  
GPA/PA  
MVirgilio  
DHickman

DRSP/LA:PDV  
JLee  
2/16/88

DRSP/PM:PDV  
DHickman:jn  
2/16/88

DRSP/PM:PDV  
GKKnighton  
1/16/88

DFOL  
1/11

~~8902270502~~

3 pp.

OH  
OH



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 16, 1989

Docket Nos.: 50-361 and 50-362

Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas and Electric Company  
101 Ash Street  
Post Office Box 1831  
San Diego, California 92112

Gentlemen:

SUBJECT: ISSUANCE OF NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
(TAC NOS. 68003 AND 68004)

Enclosed for your information is a Notice of Consideration of Issuance of Amendments to Facility Operating Licenses and Opportunity for Hearing. The notice relates to your request of April 26, 1988 to revise Technical Specification 3/4.3.1, "Reactor Protective Instrumentation," and Technical Specification 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation." This request was designated by you as PCN-251.

The Notice has been sent to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "Donald E. Hickman".

Donald E. Hickman, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
Notice

cc w/enclosure:  
See next page

Mr. Kenneth P. Baskin  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Units 2 and 3

cc:

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas & Electric Company  
101 Ash Street  
Post Office Box 1831  
San Diego, California 92112

Mr. Hans Kaspar, Executive Director  
Marine Review Committee, Inc.  
531 Encinitas Boulevard, Suite 105  
Encinitas, California 92024

Charles R. Kocher, Esq.  
James A. Beoletto, Esq.  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Mr. Mark Medford  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Orrick, Herrington & Sutcliffe  
ATTN: David R. Pigott, Esq.  
600 Montgomery Street  
San Francisco, California 94111

Mr. Robert G. Lacy  
Manager, Nuclear Department  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Alan R. Watts, Esq.  
Rourke & Woodruff  
701 S. Parker St. No. 7000  
Orange, California 92668-4702

Richard J. Wharton, Esq.  
University of San Diego School of  
Law  
Environmental Law Clinic  
San Diego, California 92110

Mr. S. McClusky  
Bechtel Power Corporation  
P. O. Box 60860, Terminal Annex  
Los Angeles, California 90060

Charles E. McClung, Jr., Esq.  
Attorney at Law  
24012 Calle de la Plaza/Suite 330  
Laguna Hills, California 92653

Mr. C. B. Brinkman  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane/Suite 210  
Walnut Creek, California 94596

Mr. Dennis F. Kirsh  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Resident Inspector, San Onofre NPS  
c/o U. S. Nuclear Regulatory Commission  
Post Office Box 4329  
San Clemente, California 92672

Mr. Sherwin Harris  
Resource Project Manager  
Public Utilities Department  
City of Riverside  
City Hall  
3900 Main Street  
Riverside, California 92522

UNITED STATES NUCLEAR REGULATORY COMMISSIONSOUTHERN CALIFORNIA EDISON COMPANY, ET AL.DOCKET NOS. 50-361 AND 50-362NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS TO  
FACILITY OPERATING LICENSES AND OPPORTUNITY FOR HEARING

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License Nos. NPF-10 and NPF-15 issued to Southern California Edison Company (SCE), San Diego Gas and Electric Company, the City of Riverside, California and the City of Anaheim, California (the licensees), for operation of San Onofre Nuclear Generating Station, Units 2 and 3 located in San Diego County, California. The request for amendments was submitted by letter dated April 26, 1988 and identified as Proposed Change PCN-251.

The proposed change would revise Technical Specification (TS) 3/4.3.1, "Reactor Protective Instrumentation," and Technical Specification 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation." TS 3/4.3.1 requires operability of the reactor protective instrumentation channels and bypasses with specified response times. Similarly, TS 3/4.3.2 requires operability of the Engineered Safety Features Actuation System (ESFAS) instrumentation channels and bypasses with trip setpoints consistent with the values specified in the TS. The operability of the reactor protective and ESFAS instrumentation and bypasses ensure that 1) the associated ESFAS action and/or reactor trip will be initiated when the parameter monitored by each

~~890727051~~

5pp.

channel or combination thereof reaches its setpoint, 2) the specified coincidence logic is maintained, 3) sufficient redundancy is maintained to permit a channel to be out of service for testing or maintenance, and 4) sufficient system functional capability is available from diverse parameters. The operability of these systems is required to provide the overall reliability, redundancy and diversity assumed available in the facility design for the protection and mitigation of accident and transient conditions; and so that the integrated operation of these systems is consistent with the assumptions used in the accident analyses.

Technical Specifications 4.3.1.3 and 4.3.2.3 require that the response times of one of the four channels of instrumentation in the Reactor Protection System (RPS) and ESFAS, respectively, be measured every 18 months and that the results meet specified values. The proposed change would revise the interval for these surveillances from the current 18 months to an interval of at least once per refueling.

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By Marcy 27, 1989 the licensees may file a request for a hearing with respect to issuance of the amendments to the subject facility operating licenses, and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for hearing and petition for leave to intervene. Requests for a

hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board Panel designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel will rule on the request and/or petition, and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first pre-hearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first pre-hearing conference scheduled in the proceeding, a petitioner shall file a supplement to the

petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendments under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 2120 L Street, NW, Washington, DC, by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly inform the Commission by a toll-free telephone call to Western Union at 1-(800)325-6000 (in Missouri 1-(800)342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to George W. Knighton: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to Mr. Charles R. Kocher, Esq., Southern California Edison Company, 2244 Walnut Grove Avenue, P.O. Box 800, Rosemead,

California 91770 and Orrick, Herrington and Sutcliffe, Attention: David R. Pigott, Esq., 600 Montgomery Street, San Francisco, California 94111, attorneys for the licensees.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in the 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendments which is available for public inspection at the Commission's public Document Room, 2120 L Street NW, Washington, DC, and at the General Library, University of California at Irvine, Irvine, California 92713.

Dated at Rockville, Maryland, this 16th day of February, 1989.

FOR THE NUCLEAR REGULATORY COMMISSION

  
George W. Knighton, Director  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects