



**Duke Power Company**  
*A Duke Energy Company*  
Energy Center  
P.O. Box 1006  
Charlotte, NC 28201-1006

July 11, 2002


U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Duke Energy Corporation  
Catawba Nuclear Station, Units 1, and 2  
Docket Numbers 50-413 and 50-414  
Monthly Performance and Operation Status-June, 2002

Please find attached information concerning the performance and operation status of the Catawba Nuclear Station for the month of June, 2002.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,



Terry Dimmery, Manager  
Nuclear Business Support

Attachment  
XC:

L. A. Reyes, Regional Administrator  
USNRC, Region II

Chandu Patel, Project Manager  
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin  
Nuclear Assurance Corporation

Dottie Sherman, ANI Library  
American Nuclear Insurers

Darrell Roberts, Senior Resident Inspector

IE24

Document Control Desk  
U.S. NRC - Catawba

bxc:

Gary Gilbert (CN01RC)  
K. E. Nicholson (CN01RC)  
RGC Site Licensing File  
ELL (EC050)

# Operating Data Report

Docket No. 50-413  
Date July 11, 2002  
Completed By Roger Williams  
Telephone 704-382-5346

## Operating Status

1. Unit Name: Catawba 1  
2. Reporting Period: June 1, 2002 - June 30, 2002  
3. Licensed Thermal Power (MWt): 3411  
4. Nameplate Rating (Gross MWe): 1305 \*  
5. Design Electrical Rating (Net MWe): 1145  
6. Maximum Dependable Capacity (Gross MWe): 1192  
7. Maximum Dependable Capacity(Net MWe): 1129  
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: \*Nameplate  
Rating (GrossMWe)  
calculated as 1450.000  
MVA \* .90 power  
factor per Page iii,  
NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	4343.0	149064.0
12. Number of Hours Reactor was Critical	720.0	3854.4	122688.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	3834.5	121178.6
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2454449	70513845	457398747
17. Gross Electrical Energy Generated (MWH)	871794	4626575	141878670
18. Net Electrical Energy Generated (MWH)	827594	4388214	133804292
19. Unit Service Factor	100.0	88.3	81.3
20. Unit Availability Factor	100.0	88.3	81.3
21. Unit Capacity Factor (Using MDC Net)	101.8	89.5	79.3
22. Unit Capacity Factor (Using DER Net)	100.4	88.2	78.4
23. Unit Forced Outage Rate	0.0	0.0	5.7
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

## UNIT SHUTDOWNS

DOCKET NO. 50-413UNIT NAME: Catawba 1DATE: July 11, 2002COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: June, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		
Summary:							

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 1
2. Scheduled next refueling shutdown: November 2003
3. Scheduled restart following refueling: December 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)     in the core: 193  
   (b)     in the spent fuel pool: 944
8. Present licensed fuel pool capacity: 1418  
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:  
November 2009

DUKE POWER COMPANY

DATE: July 11, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

# Operating Data Report

Docket No. 50-414  
 Date July 11, 2002  
 Completed By Roger Williams  
 Telephone 704-382-5346

## Operating Status

1. Unit Name: Catawba 2
2. Reporting Period: June 1, 2002 - June 30, 2002
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 \*
5. Design Electrical Rating (Net MWe): 1145
6. Maximum Dependable Capacity (Gross MWe): 1192
7. Maximum Dependable Capacity (Net MWe): 1129
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: \*Nameplate Rating (Gross MWe) calculated as 1450.000 MVA \* .90 power factor per Page iii, NUREG-0020.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	4343.0	139080.0
12. Number of Hours Reactor was Critical	720.0	4343.0	115387.9
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	4343.0	113963.8
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2451605	85301973	444513293
17. Gross Electrical Energy Generated (MWH)	875708	5328988	133271959
18. Net Electrical Energy Generated (MWH)	831573	5063660	125876172
19. Unit Service Factor	100.0	100.0	81.9
20. Unit Availability Factor	100.0	100.0	81.9
21. Unit Capacity Factor (Using MDC Net)	102.3	103.3	80.1
22. Unit Capacity Factor (Using DER Net)	100.9	101.8	79.0
23. Unit Forced Outage Rate	0.0	0.0	7.1
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

## UNIT SHUTDOWNS

DOCKET NO. 50-414UNIT NAME: Catawba 2DATE: July 11, 2002COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: June, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		
Summary:							

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 2
2. Scheduled next refueling shutdown: March 2003
3. Scheduled restart following refueling: March 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)       in the core: 193  
   (b)       in the spent fuel pool: 836
8. Present licensed fuel pool capacity: 1418  
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:  
May 2012

DUKE POWER COMPANY

DATE: July 11, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346



CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

MAY 2002

1. Personnel Exposure -

The total station liquid release for MAY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for MAY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.