



Nuclear Regulatory Commission
Mail Stop T-8F-5
Washington D.C. 20555-001

Attention Seung Lee

RE: Device Registration NR-0668-D-101-E Amendment Request

In response to your e-mail dated 4-18-2002 this letter will address those questions in that letter.

Question # 1. You will find enclosed with this letter a copy of our ISO 9001 Certificate issued to us on August 20, 1999.

Question # 2. Kidde-Fenwal does not purchase sealed sources from Amersham. We have named Amersham in our licenses, certificates and other documents as a alternative to NRD. We would only purchase sealed sources from Amersham if NRD was unable to supply us. We have confirmed that the model numbers are still valid from both suppliers. NRD supplies us with model NRD A-001, and Amersham (now known as AEA Technologies) still supplies Nohmi with model AMMD -1001H. This is a sealed source mounted in a holder.

Question # 3. Kidde-Fenwal purchases these devices already assembled in there holders (sealed sources). The only assembly done here is mounting of the holder into the smoke chamber.

Question # 4. The letter dated November 27, 1991 describes in summary the quality guidelines for these detector assemblies. The procedures that are described in the letter are Kidde-Fenwal's procedures Nohmi Bosai Ltd also employs these procedures in their manufacturing process. We manufacture model CPD7052, and Nohmi manufactures model CPD7051. Each lot received from Nohmi is accompanied by quality conformance documentation, and Kidde-Fenwal performs their own quality conformance test procedures prior to distribution of these detectors in the U.S.

Question # 5. This question is answered in question # 4.

Question # 6. Kidde-Fenwal has been using LTPD of 5% and C=0 for all of the smoke detectors that we manufacture and distribute. One reject would fail the entire lot. Please note that we have been using the table in 10 CFR 32.110 (b)(6) but as stated in the original amendment request, one reject will fail the entire lot no matter what the sample size. The table in 10 CFR allows 1 failure on a sample size of 2,001 to 100,000 pieces. The sampling sizes listed in this table are identical to the table found in NRC's regulatory guide 6.9, page C-6. Kidde-Fenwal will be referencing and following the guidelines in Regulatory Guide 6.9 as well as NUREG 1556 vol.3.

Question # 7. Quality records as they pertain to radioactive materials and radiation safety at Kidde-Fenwal are kept for many years. Records are kept in the office of the Radiation Safety Officer, and date back to the early 80's. Section 4.16 of the Quality manual will be revised.

Sincerely,
William E. Sawyer R.S.O.

A handwritten signature in black ink, appearing to read "William E. Sawyer", written over the typed name.

Enclosures: Kidde-Fenwal's ISO 9001 Certificate
Blue Print for Model NRD A-001

UNDERWRITERS LABORATORIES INC.
CERTIFICATE OF REGISTRATION

KIDDE-FENWAL, INC.

400 Main Street
Ashland, MA 01721

Underwriters Laboratories Inc.® (UL) issues this certificate to the Firm named above, after assessing the Firm's quality system and finding it in compliance with

ISO 9001:1994

EN ISO 9001:1994; BS EN ISO 9001:1994; ANSI/ASQC Q9001:1994

for the following scope of registration

3829 (US) : Measuring and Controlling Devices, Not Elsewhere Classified

The design, production and distribution of fire detection and fire alarm systems and components, gas ignition systems, process control equipment, controlling devices, and fire prevention equipment including the design and manufacture of gaseous fixed fire fighting components.

This quality system registration is included in UL's Directory of Registered Firms and applies to the provision of goods and/or services as specified in the scope of registration from the address(es) shown above. By issuance of this certificate the firm represents that it will maintain its registration in accordance with the applicable requirements. This certificate is not transferable and remains the property of Underwriters Laboratories Inc. ®.


File Number: A8303

Volume: 1

Issue Date: August 20, 1999

Revision Date: August 1, 2001

Renewal Date: August 20, 2003



S. Joe Bhatia
Executive Vice President and
Chief Operating Officer - International



Accredited by
Raad voor
Accreditatie



Loss Prevention Certification Board



CERTIFICATE OF QUALITY SYSTEM REGISTRATION

This is to certify

NOHMI BOSAI LIMITED.
5058 Menuma, Menuma-Machi, Osata-Gun,
Saitama Prefecture, 360-02, Japan.

has complied with the requirements identified in

ISO 9001 : 1994

and is authorised to use the LPCB mark on stationery and
publications related to the following products and/or services


Design and manufacture of point type smoke detectors.

Certificate No. 073 Issue 6

Issued 30 November 2000

Valid Until 8 January 2004

Signed on behalf of the LPCB



C JUDGE

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel 01923 664100 Fax 01923 664603 www.brecertification.co.uk

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

To check the authenticity of this certificate, please visit our website or contact us.

