

Docket Nos. 50-361  
and 50-362

December 28, 1990

Mr. Harold B. Ray  
Senior Vice President  
Southern California Edison Company  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas & Electric Co.  
101 Ash Street  
San Diego, California 92112

Gentlemen:

SUBJECT: ISSUANCE OF AMENDMENT NOS. 91 AND 81 TO FACILITY OPERATING  
LICENSE NOS. NPF-10 AND NPF-15 FOR THE SAN ONOFRE NUCLEAR  
GENERATING STATION, UNIT NOS. 2 AND 3 (TAC NOS. 77997 AND 77998)

The Commission has issued the enclosed Amendment Nos. 91 and 81 to Facility  
Operating License Nos. NPF-10 and NPF-15 for San Onofre Nuclear Generating  
Station, Unit Nos. 2 and 3. The amendments consist of changes to the Technical  
Specifications (TS) in response to your application dated November 8, 1990,  
designated by you as PCN-342.

These amendments revise Technical Specification 3/4.7.1.1, "Safety Valves," TS  
Table 3.7-1, "Steam Line Safety Valves Per Loop," TS Table 3.7-2, "Maximum  
Allowable Linear Power Level-High Trip Setpoint With Inoperable Steam Line  
Safety Valves During Operation With Both Steam Generators," and the  
corresponding Bases section.

A copy of our related Safety Evaluation is also enclosed. The notice of  
issuance will be included in the Commission's next regular biweekly Federal  
Register notice.

Sincerely,  
Original signed by Patricia L. Eng for  
Lawrence E. Kokajko, Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 91 to NPF-10
- 2. Amendment No. 81 to NPF-15
- 3. Safety Evaluation

cc w/enclosures:

See next page  
Distribution

Docket Files	NRC & LPDRs	PDV Reading	PDV Plant	RZimmerman, RV (4)
BBoger	MVirgilio	DFoster	LKokajko	Wanda Jones
DHagan	EJordan	GHill (8)	JCalvo	ACRS (10)
OGC	GPA/PA	OC/LFMB	AHon	CCaldwell
SRichards	PJohnson	GHubbard	CMcCracken	

\*See previous concurrence *12/13/90*

OFC	:LA:PDV:DRP345	:PM:PDV:DRP345	:OGC *	:SPLB:NRR *	:BC:SPLB:NRR *
NAME	:DFoster	:LKokajko:pm	:	:GHubbard	:CMcCracken
DATE	:12/13/90	:12/13/90	:12/10/90	:11/30/90	:11/30/90

OFC	:(A)D:PDV:DRP345
NAME	:JDyer <i>JM</i>
DATE	:12/14/90 <i>12/22/90</i>

*QFOI*

OFFICIAL RECORD COPY

Document Name: SO 2/3 TAC NOS. 77997 & 77998

9101070136 901228  
PDR ADOCK 05000361  
PDR

Messrs. Ray and Cotton  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Unit Nos. 2 and 3

cc:

James A. Beoletto, Esq.  
Southern California Edison Company  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Mr. Richard J. Kosiba, Project Manager  
Bechtel Power Corporation  
12440 E. Imperial Highway  
Norwalk, California 90650

David R. Pigott, Esq.  
Orrick, Herrington & Sutcliffe  
600 Montgomery Street  
San Francisco, California 94111

Mr. John Hickman  
Senior Health Physicist  
Environmental Radioactive Mgmt. Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Alan R. Watts, Esq.  
Rourke & Woodruff  
701 S. Parker St. No. 7000  
Orange, California 92668-4702

Resident Inspector, San Onofre NPS  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 4329  
San Clemente, California 92672

Mr. Sherwin Harris  
Resource Project Manager  
Public Utilities Department  
City of Riverside  
3900 Main Street  
Riverside, California 92522

Mayor  
City of San Clemente  
100 Avenida Presidio  
San Clemente, California 92672

Mr. Charles B. Brinkman  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. Phil Johnson  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Chairman, Board of Supervisors  
County of San Diego  
1600 Pacific Highway, Room 335  
San Diego, California 92101

Mr. Don J. Womeldorf  
Chief, Environmental Management Branch  
California Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Mr. Robert G. Lacy  
Manager, Nuclear Department  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

THRO

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 91  
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Southern California Edison Company, San Diego Gas and Electric Company, the City of Riverside, California, and the City of Anaheim, California (the licensee) dated November 8, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 91, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James E. Dyer, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 28, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 91

FACILITY OPERATING LICENSE NO. NPF-10

DOCKET NO. 50-361

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the areas of change.

REMOVE

XIX  
3/4 7-1  
3/4 7-2  
3/4 7-3  
B 3/4 7-1

INSERT

XIX  
3/4 7-1  
3/4 7-2  
3/4 7-3  
B 3/4 7-1

INDEX

LIST OF TABLES

<u>TABLE</u>		<u>PAGE</u>
3.3-10	ACCIDENT MONITORING INSTRUMENTATION.....	3/4 3-52
4.3-7	ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS.....	3/4 3-54
3.3-11	FIRE DETECTION INSTRUMENTS - MINIMUM INSTRUMENTS OPERABLE	3/4 3-57
3.3-12	RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION -- DELETED	
4.3-8	RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS -- DELETED	
3.3-13	RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION..	3/4 3-65
4.3-9	RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS.....	3/4 3-67
4.4-1	MINIMUM NUMBER OF STEAM GENERATORS TO BE INSPECTED DURING INSERVICE INSPECTION.....	3/4 4-14
4.4-2	STEAM GENERATOR TUBE INSPECTION.....	3/4 4-15
3.4-1	REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES.....	3/4 4-19
3.4-2	REACTOR COOLANT SYSTEM CHEMISTRY.....	3/4 4-21
3.4-3	LOW TEMPERATURE RCS OVERPRESSURE PROTECTION RANGE.....	3/4 4-30a
4.4-3	REACTOR COOLANT SYSTEM CHEMISTRY LIMITS SURVEILLANCE REQUIREMENTS.....	3/4 4-22
4.4-4	PRIMARY COOLANT SPECIFIC ACTIVITY SAMPLE AND ANALYSIS PROGRAM.....	3/4 4-25
4.4-5	REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM - WITHDRAWAL SCHEDULE.....	3/4 4-28
4.6-1	TENDON SURVEILLANCE.....	3/4 6-12
4.6-2	TENDON LIFT-OFF FORCE.....	3/4 6-12a
3.6-1	CONTAINMENT ISOLATION VALVES.....	3/4 6-20
3.7-1	MAIN STEAM SAFETY VALVES.....	3/4 7-2
3.7-2	MAXIMUM ALLOWABLE VALUE LINEAR POWER LEVEL-HIGH TRIP WITH INOPERABLE MAIN STEAM SAFETY VALVES DURING OPERATION WITH BOTH STEAM GENERATORS.....	3/4 7-3

INDEX

LIST OF TABLES

---

---

<u>TABLE</u>		<u>PAGE</u>
4.7-1	SECONDARY COOLANT SYSTEM SPECIFIC ACTIVITY SAMPLE AND ANALYSIS PROGRAM.....	3/4 7-8
3.7-5	SAFETY-RELATED SPRAY AND/OR SPRINKLER SYSTEMS.....	3/4 7-31
3.7-6	FIRE HOSE STATIONS.....	3/4 7-33
4.8-1	DIESEL GENERATOR TEST SCHEDULE.....	3/4 8-7
4.8-2	BATTERY SURVEILLANCE REQUIREMENTS.....	3/4 8-11
3.8-1	CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES.....	3/4 8-18
3.8-2	MOTOR OPERATED VALVES, THERMAL OVERLOAD PROTECTION BYPASS DEVICES.....	3/4 8-32
3.10-1	RADIATION MONITORING/SAMPLING EXCEPTION -- DELETED	
4.11-1	RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM -- DELETED	
4.11-2	RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM -- DELETED	
3.12-1	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM -- DELETED	
3.12-2	REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES -- DELETED	
4.12-1	MAXIMUM VALUES FOR THE LOWER LIMITS OF DETECTION (LLD) -- DELETED	
B 3/4.4-1	REACTOR VESSEL TOUGHNESS.....	B 3/4 4-8
5.7-1	COMPONENT CYCLIC OR TRANSIENT LIMITS.....	5-8
6.2-1	MINIMUM SHIFT CREW COMPOSITION.....	6-4

### 3/4.7 PLANT SYSTEMS

#### 3/4.7.1 TURBINE CYCLE

##### SAFETY VALVES

##### LIMITING CONDITION FOR OPERATION

---

---

3.7.1.1 All main steam safety valves shall be OPERABLE with lift settings as specified in Table 3.7-1.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With both reactor coolant loops and associated steam generators in operation and with one or more main steam safety valves inoperable, operation in MODES 1, 2 and 3 may proceed provided, that within 4 hours, either the inoperable valve is restored to OPERABLE status or the Power Level-High trip setpoint is reduced per Table 3.7-2; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. The provisions of Specification 3.0.4 are not applicable.

##### SURVEILLANCE REQUIREMENTS

---

---

4.7.1.1 No additional Surveillance Requirements other than those required by Specification 4.0.5.



TABLE 3.7-1  
MAIN STEAM SAFETY VALVES

	<u>VALVE NUMBER</u>		<u>LIFT SETTING (<math>\pm 1\%</math>)*</u>	<u>ORIFICE SIZE</u>
	<u>Line No. 1</u>	<u>Line No. 2</u>		
a.	2PSV-8401	2PSV-8410	1100 psia	16 in <sup>2</sup>
b.	2PSV-8402	2PSV-8411	1107 psia	16 in <sup>2</sup>
c.	2PSV-8403	2PSV-8412	1114 psia	16 in <sup>2</sup>
d.	2PSV-8404	2PSV-8413	1121 psia	16 in <sup>2</sup>
e.	2PSV-8405	2PSV-8414	1128 psia	16 in <sup>2</sup>
f.	2PSV-8406	2PSV-8415	1135 psia	16 in <sup>2</sup>
g.	2PSV-8407	2PSV-8416	1142 psia	16 in <sup>2</sup>
h.	2PSV-8408	2PSV-8417	1149 psia	16 in <sup>2</sup>
i.	2PSV-8409	2PSV-8418	1155 psia	16 in <sup>2</sup>

\* The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

TABLE 3.7-2

MAXIMUM ALLOWABLE VALUE LINEAR POWER LEVEL-HIGH TRIP WITH INOPERABLE  
MAIN STEAM SAFETY VALVES DURING OPERATION WITH BOTH STEAM GENERATORS

<u>Maximum Number of Inoperable Safety Valves on Any Operating Steam Generator</u>	<u>Maximum Allowable Value Linear Power Level-High Trip (Percent of RATED THERMAL POWER)</u>
1	98.6
2	86.3
3	74.0
4	61.6

### 3/4.7 PLANT SYSTEMS

#### BASES

---

#### 3/4.7.1 TURBINE CYCLE

##### 3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam safety valves (MSSVs) ensures that the secondary system pressure will not exceed 110% (1210 psia) of its design pressure of 1100 psia during the most severe anticipated system operational transient. The total relief capacity available is greater than the maximum steam flow required after a turbine trip from 102% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink.

The MSSV lift setpoints are staggered, as shown in Table 3.7-1, such that only those valves needed for pressure relief will actuate. The MSSV lift settings and relieving capacities meet the requirements of Section III of the ASME Boiler and Pressure Vessel Code, 1974 Edition, as described in the Overpressure Protection Report (UFSAR Appendix 5.2A). The total available relieving capacity for all valves on all of the steam lines is 15,473,628 lbs/hr at 1190 psia. A minimum of one OPERABLE safety valve per steam generator ensures that sufficient relieving capacity is available for removing decay heat.

STARTUP and/or POWER OPERATION is allowable with safety valves inoperable within the limitations of the ACTION requirements on the basis of the reduction in secondary system steam flow and THERMAL POWER required by the reduced reactor trip settings of the Power Level-High channels. The reduced reactor trip allowable values are derived on the following bases:

$$SP = \frac{(X) - (Y)(V)}{X} \times 111.0$$

where:

SP = reduced reactor trip allowable value in percent of RATED THERMAL POWER.

V = maximum number of inoperable safety valves per steam line.

111.0 = Power Level-High Trip allowable value from Table 2.2-1.

X = Total relieving capacity of all safety valves per steam line in lbs/hour (7,736,814 lbs/hr at 1190 psia).

Y = Maximum relieving capacity of any one safety valve in lbs/hour (859,646 lbs/hr at 1190 psia).

## PLANT SYSTEMS

### BASES

---

#### 3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the auxiliary feedwater system ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss of off-site power.

Each electric driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 700 gpm at a pressure of 1170 psig to the entrance of the steam generators. The steam driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 700 gpm at a pressure of 1170 psig to the entrance of the steam generators. This capacity is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F when the shutdown cooling system may be placed into operation.

#### 3/4.7.1.3 CONDENSATE STORAGE TANKS

The OPERABILITY of the condensate storage tank T-121 with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 2 hours followed by cooldown to shutdown cooling initiation, with steam discharge to atmosphere with concurrent loss of offsite power and most limiting single failure. The OPERABILITY of condensate storage tank T-120 in conjunction with tank T-121 ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 24 hours including cooldown to shutdown cooling initiation, with steam discharge to atmosphere with concurrent loss of offsite power and most limiting single failure. The contained water volume limits are specified relative to the highest auxiliary feedwater pump suction inlet in the tank for T-121, and to the T-121 cross connect siphon inlet for T-120. (Water volume below these datum levels is not considered recoverable for purposes of this specification.) Vortexing, internal structure, and instrument error are considered in determining the tank levels corresponding to the specified water volume limits.

Prior to achieving 100% RATED THERMAL POWER, Figure 3.7-1 is used to determine the minimum required water volume for T-121 for the maximum power level (hence maximum decay heat) achieved.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Lott

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 81  
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Southern California Edison Company, San Diego Gas and Electric Company, the City of Riverside, California, and the City of Anaheim, California (the licensee) dated November 8, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 81, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James E. Dyer, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 28, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 81

FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the areas of change.

REMOVE

XIX  
3/4 7-1  
3/4 7-2  
3/4 7-3  
B 3/4 7-1

INSERT

XIX  
3/4 7-1  
3/4 7-2  
3/4 7-3  
B 3/4 7-1

INDEX

LIST OF TABLES

---

<u>TABLE</u>	<u>PAGE</u>
4.3-7 ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS.....	3/4 3-55
3.3-11 FIRE DETECTION INSTRUMENTS.....	3/4 3-58
3.3-12 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION -- DELETED	
4.3-8 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS -- DELETED	
3.3-13 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION....	3/4 3-66
4.3-9 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS.....	3/4 3-68
4.4-1 MINIMUM NUMBER OF STEAM GENERATORS TO BE INSPECTED DURING INSERVICE INSPECTION.....	3/4 4-14
4.4-2 STEAM GENERATOR TUBE INSPECTION.....	3/4 4-15
3.4-1 REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES.....	3/4 4-20
3.4-2 REACTOR COOLANT SYSTEM CHEMISTRY.....	3/4 4-22
4.4-3 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS SURVEILLANCE REQUIREMENTS.....	3/4 4-23
4.4-4 PRIMARY COOLANT SPECIFIC ACTIVITY SAMPLE.....	3/4 4-26
4.4-5 REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM - WITHDRAWAL SCHEDULE.....	3/4 4-29
3.4-3 LOW TEMPERATURE RCS OVERPRESSURE PROTECTION RANGE.....	3/4 4-31b
4.6-1 TENDON SURVEILLANCE.....	3/4 6-12
4.6-2 TENDON LIFT-OFF FORCE.....	3/4 6-13
3.6-1 CONTAINMENT ISOLATION VALVES.....	3/4 6-21
3.7-1 MAIN STEAM SAFETY VALVES .....	3/4 7-2
3.7-2 MAXIMUM ALLOWABLE VALUE LINEAR POWER LEVEL-HIGH TRIP WITH INOPERABLE MAIN STEAM SAFETY VALVES DURING OPERATION WITH BOTH STEAM GENERATORS.....	3/4 7-3



INDEX

LIST OF TABLES

---

<u>TABLE</u>		<u>PAGE</u>
4.7-1	SECONDARY COOLANT SYSTEM SPECIFIC ACTIVITY SAMPLE AND ANALYSIS PROGRAM.....	3/4 7-9
3.7-5	SAFETY-RELATED SPRAY AND/OR SPRINKLER SYSTEMS.....	3/4 7-32
3.7-6	FIRE HOSE STATIONS.....	3/4 7-34
4.8-1	DIESEL GENERATOR TEST SCHEDULE.....	3/4 8-7
4.8-2	BATTERY SURVEILLANCE REQUIREMENTS.....	3/4 8-11
3.8-1	CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES.....	3/4 8-18
3.8-2	MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION BYPASS DEVICES PERMANENTLY BYPASSED.....	3/4 8-32
4.11-1	RADIOACTIVE LIQUID SAMPLING AND ANALYSIS PROGRAM -- DELETED	
4.11-2	RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM -- DELETED	
3.12-1	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM -- DELETED	
3.12-2	REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES -- DELETED	
4.12-1	MAXIMUM VALVES FOR THE LOWER LIMITS OF DETECTION -- DELETED	
B3/4.4-1	REACTOR VESSEL TOUGHNESS.....	B3/4 4-8
5.7-1	COMPONENT CYCLIC OR TRANSIENT LIMITS.....	5-8
6.2-1	MINIMUM SHIFT CREW COMPOSITION.....	6-5

### 3/4.7 PLANT SYSTEMS

#### 3/4.7.1 TURBINE CYCLE

##### SAFETY VALVES

#### LIMITING CONDITION FOR OPERATION

---

3.7.1.1 All main steam safety valves shall be OPERABLE with lift settings as specified in Table 3.7-1.

APPLICABILITY: MODES 1, 2 and 3.

##### ACTION:

- a. With both reactor coolant loops and associated steam generators in operation and with one or more main steam safety valves inoperable, operation in MODES 1, 2 and 3 may proceed provided, that within 4 hours, either the inoperable valve is restored to OPERABLE status or the Power Level-High trip setpoint is reduced per Table 3.7-2; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.7.1.1 No additional Surveillance Requirements other than those required by Specification 4.0.5.

TABLE 3.7-1  
MAIN STEAM SAFETY VALVES

	<u>VALVE NUMBER</u>		<u>LIFT SETTING (<math>\pm 1\%</math>)*</u>	<u>ORIFICE SIZE</u>
	<u>Line No. 1</u>	<u>Line No. 2</u>		
a.	3PSV-8401	3PSV-8410	1100 psia	16 in <sup>2</sup>
b.	3PSV-8402	3PSV-8411	1107 psia	16 in <sup>2</sup>
c.	3PSV-8403	3PSV-8412	1114 psia	16 in <sup>2</sup>
d.	3PSV-8404	3PSV-8413	1121 psia	16 in <sup>2</sup>
e.	3PSV-8405	3PSV-8414	1128 psia	16 in <sup>2</sup>
f.	3PSV-8406	3PSV-8415	1135 psia	16 in <sup>2</sup>
g.	3PSV-8407	3PSV-8416	1142 psia	16 in <sup>2</sup>
h.	3PSV-8408	3PSV-8417	1149 psia	16 in <sup>2</sup>
i.	3PSV-8409	3PSV-8418	1155 psia	16 in <sup>2</sup>

---

\*The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

TABLE 3.7-2

MAXIMUM ALLOWABLE VALUE LINEAR POWER LEVEL-HIGH TRIP WITH INOPERABLE  
MAIN STEAM SAFETY VALVES DURING OPERATION WITH BOTH STEAM GENERATORS

<u>Maximum Number of Inoperable Safety Valves on Any Operating Steam Generator</u>	<u>Maximum Allowable Value Linear Power Level-High Trip (Percent of RATED THERMAL POWER)</u>
1	98.6
2	86.3
3	74.0
4	61.6

## PLANT SYSTEMS

### AUXILIARY FEEDWATER SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.7.1.2 At least three independent steam generator auxiliary feedwater pumps and associated flow paths shall be OPERABLE with:

- a. Two motor-driven auxiliary feedwater pumps, each capable of being powered from separate emergency busses, and
- b. One steam turbine-driven auxiliary feedwater pump capable of being powered from an OPERABLE steam supply system.

APPLICABILITY: MODES 1, 2 and 3.

#### ACTION:

- a. With one auxiliary feedwater pump inoperable, restore the required auxiliary feedwater pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With two auxiliary pumps inoperable, be in at least HOT STANDBY within 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With three auxiliary feedwater pumps inoperable, immediately initiate corrective action to restore at least one auxiliary feedwater pump to OPERABLE status as soon as possible.

#### SURVEILLANCE REQUIREMENTS

---

4.7.1.2.1 Each auxiliary feedwater pump shall be demonstrated OPERABLE:

- a. At least once per 31 days by:
  1. Testing the turbine driven pump and both motor driven pumps pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for the turbine-driven pump for entry into MODE 3.
  2. Verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
  3. Verifying that both manual valves in the suction lines from the primary AFW supply tank (condensate storage tank T-121) to each AFW pump, and the manual discharge line valve of each AFW pump are locked in the open position.

## 3/4.7 PLANT SYSTEMS

### BASES

---

#### 3/4.7.1 TURBINE CYCLE

##### 3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam safety valves (MSSVs) ensures that the secondary system pressure will not exceed 110% (1210 psia) of its design pressure of 1100 psia during the most severe anticipated system operational transient. The total relief capacity available is greater than the maximum steam flow required after a turbine trip from 102% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink.

The MSSV lift setpoints are staggered, as shown in Table 3.7-1, such that only those valves needed for pressure relief will actuate. The MSSV lift settings and relieving capacities meet the requirements of Section III of the ASME Boiler and Pressure Vessel Code, 1974 Edition, as described in the Overpressure Protection Report (UFSAR Appendix 5.2A). The total available relieving capacity for all valves on all of the steam lines is 15,473,628 lbs/hr at 1190 psia. A minimum of one OPERABLE safety valve per steam generator ensures that sufficient relieving capacity is available for removing decay heat.

STARTUP and/or POWER OPERATION is allowable with safety valves inoperable within the limitations of the ACTION requirements on the basis of the reduction in secondary system steam flow and THERMAL POWER required by the reduced reactor trip settings of the Power Level-High channels. The reduced reactor trip allowable values are derived on the following bases:

$$SP = \frac{(X) - (Y)(V)}{X} \times 111.0$$

where:

SP = reduced reactor trip allowable value in percent of RATED THERMAL POWER.

V = maximum number of inoperable safety valves per steam line.

111.0 = Power Level-High Trip allowable value from Table 2.2-1.

X = Total relieving capacity of all safety valves per steam line in lbs/hour (7,736,814 lbs/hr at 1190 psia).

Y = Maximum relieving capacity of any one safety valve in lbs/hour (859,646 lbs/hr at 1190 psia).

## PLANT SYSTEMS

### BASES

---

#### 3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the auxiliary feedwater system ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss of offsite power.

Each electric-driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 700 gpm at a pressure of 1170 psig to the entrance of the steam generators. The steam-driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 700 gpm at a pressure of 1170 psig to the entrance of the steam generators. This capacity is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F when the shutdown cooling system may be placed into operation.

#### 3/4.7.1.3 CONDENSATE STORAGE TANKS

The OPERABILITY of the condensate storage tank T-121 with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 2 hours followed by cooldown to shutdown cooling initiation, with steam discharge to atmosphere with concurrent loss of offsite power and most limiting single failure. The OPERABILITY of condensate storage tank T-120 in conjunction with tank T-121 ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 24 hours including cooldown to shutdown cooling initiation, with steam discharge to atmosphere with concurrent loss of offsite power and most limiting single failure. The contained water volume limits are specified relative to the highest auxiliary feedwater pump suction inlet in the tank for T-121, and to the T-121 cross connect siphon inlet for T-120. (Water volume below these datum levels is not considered recoverable for purposes of this specification.) Vortexing, internal structure and instrument error are considered in determining the tank levels corresponding to the specified water volume limits.

Prior to achieving 100% RATED THERMAL POWER, Figure 3.7-1 is used to determine the minimum required water volume for T-121 for the maximum power level (hence maximum decay heat) achieved.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TRSLR

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 91 AND 81 TO

FACILITY OPERATING LICENSE NOS. NPF-10 AND NPF-15

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NOS. 2 AND 3

DOCKET NOS. 50-361 AND 50-362

1.0 INTRODUCTION

By letter dated November 8, 1990, Southern California Edison Company, et al. (SCE or the licensee) requested changes to the Technical Specifications (TS) for Facility Operating License Nos. NPF-10 and NPF-15 that authorize operation of San Onofre Nuclear Generating Station, Unit Nos. 2 and 3 in San Diego County, California. The licensee requested to revise TS 3/4.7.1.1, "Safety Valves," TS Table 3.7-1, "Steam Line Safety Valves Per Loop," TS Table 3.7-2, "Maximum Allowable Linear Power Level-High Trip Setpoint With Inoperable Steam Line Safety Valves During Operation With Both Steam Generators," and the corresponding Bases section.

2.0 EVALUATION

The licensee requested these amendments due to a change in the allowable value for Linear Power Level-High in TS Table 2.2-1, "Reactor Protective Instrumentation Trip Setpoint Limits," as granted in Amendment Nos. 88 and 78 on June 8, 1990 by the NRC. In this case, the aforementioned amendments were granted to account for an increase in the allowed tolerance for trip bistable functional testing for certain instrument surveillances. This change reduced the allowable value for linear power from 111.3% rated thermal power to 111.0% rated thermal power. This value affects the equation used to reduce the core operating power level in case of inoperable main steam line safety valves as found in the current Bases, which was not recognized at the time of the aforementioned amendments. This change would ensure consistency within the Technical Specifications. Additionally, the licensee requested these amendments to make editorial revisions, such as removing ambiguous statements, clarify design requirements, and correct typographical and numerical errors, which are primarily administrative in nature.



While the licensee states there has been no safety impact as a result of the lower allowable value on plant operation, and administrative controls are in place to ensure this, the Bases equation to lower reactor rated thermal power is affected such that the values for reduced reactor power with inoperable main steam line safety valves as found in TS Table 3.7-2 are reduced. The licensee states that this change does not affect the overpressure protection analysis as found in the Updated Final Safety Analysis Report, Appendix 5.2A. This analysis assumes that high pressurizer pressure causes a reactor trip and not high linear power level.

The licensee states that editorial revisions are necessary to revise the Bases section to clarify the safety valve's design requirements, particularly the requirement to limit secondary system pressure to less than 1210 psia during anticipated operational transients. Also, other editorial modifications to ensure consistent wording and correct numerical errors were evaluated.

The staff agrees with the licensee that the overpressure protection analysis is not affected by the new values for maximum allowable linear power level-high trip in TS Table 3.7-2. While this is a small reduction from the current values found in TS Table 3.7-2, it is appropriate to correct the values to ensure consistency within the Technical Specifications. Independent calculations confirm that the new (and lowered) values presented in the table are correct. Moreover, the design requirement, as specified in the modified Bases, to limit secondary system pressure to less than 1210 psia is appropriate. Administrative editorial modifications for the modified Technical Specifications are appropriate to maintain consistency and eliminate ambiguity.

Therefore, based upon the licensee's letter dated November 8, 1990, and the information presented herein, the proposed modifications to the Technical Specifications are acceptable.

### 3.0 ENVIRONMENTAL CONSIDERATION

The amendments involve changes with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20, or changes a surveillance requirement. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorial exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

### 4.0 CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of

these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Lawrence E. Kokajko

Dated: December 28, 1990