

Docket Nos. 50-361
and 50-362

October 11, 1991

Mr. Harold B. Ray
Senior Vice President
Southern California Edison Co.
Irvine Operations Center
23 Parker Street
Irvine, California 92718

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Co.
101 Ash Street
San Diego, California 92112

Gentlemen:

SUBJECT: CORRECTION TO AMENDMENT NOS. 99 AND 88 FOR THE SAN ONOFRE NUCLEAR
GENERATING STATION UNIT NOS. 2 AND 3 (TAC NOS. 80613 AND 80614)

On October 1, 1991, the Commission issued Amendment Nos. 99 and 88 to Facility
Operating License Nos. NPF-10 and NPF-15 for the San Onofre Nuclear
Generating Station, Unit Nos. 2 and 3, in response to your application dated
June 17, 1991 (PCN-339).

The amendments revised Technical Specification (TS) 3/4.7.1.2 and its
associated Bases to identify that the Auxiliary Feedwater System performs a
dual function in an event which requires steam generator isolation and
secondary heat removal. TS pages 3/4 7-4 for both units contained a
typographical error at 3.7.1.2.1.c.3. A manual crosstie valve was referred to
as number "130MU635." The correct reference is "1305MU635."

Corrected TS pages 3/4 7-4 with their backup pages are enclosed. Please
accept our apologies for any inconvenience this error may have caused you.

Sincerely,

Original Signed by:
Lawrence E. Kokajko, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS pages 3/4 7-4

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	NRC & LPDRs	BBoger	MVirgilio	PKreutzer
RCesaro	LKokajko	TQuay	OGC	DHagan
GHill (8)	Wanda Jones	CGrimes	SFlanders	ACRS (10)
GPA/PA	OC/LFMB	PD4 p/f	RZimmerman (4)	

2110310059 911011
PDR ADDCK 05000361
PDR

OFC	:LA:PD5:DRPW	:PM:PD5:DRPW	:D:PD5:DRPW	:	:
NAME	:PKreutzer	:LKokajko	:TQuay	:	:
DATE	:10/10/91	:10/10/91	:10/11/91	:	:

DFOL
11
[Signature]



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 11, 1991

Docket Nos. 50-361
and 50-362

Mr. Harold B. Ray
Senior Vice President
Southern California Edison Co.
Irvine Operations Center
23 Parker Street
Irvine, California 92718

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Co.
101 Ash Street
San Diego, California 92112

Gentlemen:

SUBJECT: CORRECTION TO AMENDMENT NOS. 99 AND 88 FOR THE SAN ONOFRE NUCLEAR
GENERATING STATION UNIT NOS. 2 AND 3 (TAC NOS. 80613 AND 80614)

On October 1, 1991, the Commission issued Amendment Nos. 99 and 88 to Facility
Operating License Nos. NPF-10 and NPF-15 for the San Onofre Nuclear
Generating Station, Unit Nos. 2 and 3, in response to your application dated
June 17, 1991 (PCN-339).

The amendments revised Technical Specification (TS) 3/4.7.1.2 and its
associated Bases to identify that the Auxiliary Feedwater System performs a
dual function in an event which requires steam generator isolation and
secondary heat removal. TS pages 3/4 7-4 for both units contained a
typographical error at 3.7.1.2.1.c.3. A manual crosstie valve was referred to
as number "130MU635." The correct reference is "1305MU635."

Corrected TS pages 3/4 7-4 with their backup pages are enclosed. Please
accept our apologies for any inconvenience this error may have caused you.

Sincerely,

A handwritten signature in black ink, appearing to read "L. E. Kokajko".

Lawrence E. Kokajko, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS pages 3/4 7-4

cc w/enclosure:
See next page

Messrs. Ray and Cotton
Southern California Edison Company

San Onofre Nuclear Generating
Station, Unit Nos. 2 and 3

cc:

James A. Beoletto, Esq.
Southern California Edison Company
Irvine Operations Center
23 Parker Street
Irvine, California 92718

Mr. Richard J. Kosiba, Project Manager
Bechtel Power Corporation
12440 E. Imperial Highway
Norwalk, California 90650

Chairman, Board of Supervisors
County of San Diego
1600 Pacific Highway, Room 335
San Diego, California 92101

Mr. Robert G. Lacy
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Alan R. Watts, Esq.
Rourke & Woodruff
701 S. Parker St. No. 7000
Orange, California 92668-4702

Mr. John Hickman
Senior Health Physicist
Environmental Radioactive Mgmt. Unit
Environmental Management Branch
State Department of Health Services
714 P Street, Room 616
Sacramento, California 95814

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City of Riverside
3900 Main Street
Riverside, California 92522

Resident Inspector/San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, California 92674

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mayor
City of San Clemente
100 Avenida Presidio
San Clemente, California 92672

Mr. Phil Johnson
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Mr. Don J. Womeldorf
Chief, Environmental Management Branch
California Department of Health Services
714 P Street, Room 616
Sacramento, California 95814

PLANT SYSTEMS

AUXILIARY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.1.2.1 At least three independent steam generator auxiliary feedwater pumps and associated flow paths shall be OPERABLE with:

- a. Two motor-driven auxiliary feedwater pumps, each capable of being powered from separate emergency busses,
- b. One steam turbine-driven auxiliary feedwater pump capable of being powered from an OPERABLE steam supply system, and
- c. Manual valves in the correct position and automatic valves each capable of being opened and closed, with the following exceptions:
 1. Motor-driven auxiliary feedwater pump discharge bypass control valves, HV-4762 and HV-4763, need only be capable of being closed,
 2. Steam turbine-driven auxiliary feedwater pump steam supply isolation valves, HV-8200 and HV-8201, and turbine stop valve, HV-4716, need only be capable of being opened, and
 3. Manual crosstie valves 1305MU634 and 1305MU635 may be open in Mode 3 provided a minimum of 2 hours has elapsed since reactor shutdown.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With one auxiliary feedwater pump or its associated flow path inoperable, restore the required auxiliary feedwater pump and its associated flow path to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With either two auxiliary feedwater pumps, two flow paths, or one pump and one separate flow path inoperable, be in at least HOT STANDBY within 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With three auxiliary feedwater pumps or flow paths inoperable, immediately initiate corrective action to restore at least one auxiliary feedwater pump and its associated flow path to OPERABLE status as soon as possible.
- d. With an automatic valve in any flow path incapable of closing upon receipt of a Main Steam Isolation Signal, close the affected valve or its block valve within 4 hours and enter actions a, b, or c if there is a loss of the flow path(s). Testing pursuant to Technical Specification 3.3.2 does not constitute entry into this ACTION Statement.

PLANT SYSTEMS

AUXILIARY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.1.2.1 At least three independent steam generator auxiliary feedwater pumps and associated flow paths shall be OPERABLE with:

- a. Two motor-driven auxiliary feedwater pumps, each capable of being powered from separate emergency busses,
- b. One steam turbine-driven auxiliary feedwater pump capable of being powered from an OPERABLE steam supply system, and
- c. Manual valves in the correct position and automatic valves each capable of being opened and closed, with the following exceptions:
 1. Motor-driven auxiliary feedwater pump discharge bypass control valves, HV-4762 and HV-4763, need only be capable of being closed,
 2. Steam turbine-driven auxiliary feedwater pump steam supply isolation valves, HV-8200 and HV-8201, and turbine stop valve, HV-4716, need only be capable of being opened, and
 3. Manual crosstie valves 1305MU634 and 1305MU635 may be open in Mode 3 provided a minimum of 2 hours has elapsed since reactor shutdown.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With one auxiliary feedwater pump or its associated flow path inoperable, restore the required auxiliary feedwater pump and its associated flow path to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With either two auxiliary feedwater pumps, two flow paths, or one pump and one separate flow path inoperable, be in at least HOT STANDBY within 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With three auxiliary feedwater pumps or flow paths inoperable, immediately initiate corrective action to restore at least one auxiliary feedwater pump and its associated flow path to OPERABLE status as soon as possible.
- d. With an automatic valve in any flow path incapable of closing upon receipt of a Main Steam Isolation Signal, close the affected valve or its block valve within 4 hours and enter actions a, b, or c if there is a loss of the flow path(s). Testing pursuant to Technical Specification 3.3.2 does not constitute entry into this ACTION Statement.