



Kewaunee Nuclear Power Plant
N490 Highway 42
Kewaunee, WI 54216-9511
920.388.2560

Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, WI 54241
920.755.2321

Kewaunee / Point Beach Nuclear
Operated by Nuclear Management Company, LLC

NRC 2002-0058

GL 97-02

July 09, 2002

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Dockets 50-266 And 50-301
Point Beach Nuclear Plant, Units 1 And 2
Monthly Operating Reports

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of June 2002.

Sincerely,

T. J. Webb
Regulatory Affairs Manager

KML

Attachment

cc: J. D. Loock, PSCW
NRC Region III
NRC Senior Resident Inspector
NRC Project Manager

IE24

ATTACHMENT 1

Letter from Thomas J. Webb (NMC)

To

Document Control Desk (NRC)

Dated

July 09, 2002

Re: Monthly Operating Report – June 2002

NRC 2002-0058

GL 97-02

July 09, 2002

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Dockets 50-266 And 50-301
Point Beach Nuclear Plant, Units 1 And 2
Monthly Operating Reports

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of June 2002.

Sincerely,

T. J. Webb
Regulatory Affairs Manager

KML

Attachment

cc: J. D. Loock, PSCW
NRC Region III
NRC Senior Resident Inspector
NRC Project Manager

Docket 50-266 and 50-301
NRC-2002-0058

Bcc:	R. A. Abdo (WE)	D. E. Day	M. E. Reddemann	K. E. Peveler
	R. A. Anderson(NMC)	K. Kretzer	G. A. Charnoff	C. B. Jilek
	INPO Records Center	A. J. Cayia	L. J. Armstrong	McGraw-Hill
	Companies			
	R. R. Grigg (WE)	R. M. Daflucas	C. S. Smoker (NMC)	T. E. Ruiz
	E. J. Weinkam III (NMC)	T. W. Hanna	G. D. Strharsky	R. R. Winget
	D. A. Weaver (WE)	B. Day	RSL File (3)	B. D. Kemp
	T.H. Taylor	File		

Docket 50-266 and 50-301
NRC-2002-0058

ATTACHMENT 1

Letter from Thomas J. Webb (NMC)

To

Document Control Desk (NRC)

Dated

July 09, 2002

Re: Monthly Operating Report – June 2002

OPERATING DATA REPORT

DOCKET NO. 50-266
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1
DATE 07/02/02
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD June - 2002

1. DESIGN ELECTRICAL RATING (MWE-NET)	515.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	510.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	4,343.0	227,952.8
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	720.0	4,343.0	224,437.0
5. UNIT RESERVER SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	361,012.0	2,188,370.0	103,763,890.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-266
 UNIT NAME: Point Beach, Unit 1
 DATE: 07/02/2002
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: June 2002
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5. Other (Explain)

SUMMARY:

Unit 1 average daily power for the month of June was 501.4 MWe.
 There were no Licensee Event Reports (LERs) submitted to the NRC.
 There were no Significant Operating Events.

OPERATING DATA REPORT

DOCKET NO. 50-301
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2
DATE 07/02/02
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD June - 2002

1. DESIGN ELECTRICAL RATING (MWE-NET)	515.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	512.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	3,554.4	221,336.1
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	720.0	3,518.6	218,348.7
5. UNIT RESERVER SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	369,857.0	1,751,428.0	102,534,936.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-301
 UNIT NAME: Point Beach, Unit 2
 DATE: 07/02/2002
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: June 2002
 (Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
						COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination F. Administrative
- G. Operational Error (Explain) H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

SUMMARY:

Unit 2 average daily power for the month of June was 513.7 MWe.
 There was one Licensee Event Report (LER) 301/2002-002-00, Pressurizer Safety Valve Failed to Lift at Test Pressure
 There were no Significant Operating Events.

This report reflects corrections made to the June 2001 and February 2002 reports.