

July 10, 2002

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Stop P1-137  
Washington, DC 20555-0001



Gentlemen:

ULNRC04699

**DOCKET NUMBER 50-483  
UNION ELECTRIC CO.  
CALLAWAY PLANT UNIT 1  
FACILITY OPERATING LICENSE NPF-30  
MONTHLY OPERATING REPORT  
JUNE/2002**

The enclosed Monthly Operating Report for June/2002 is submitted pursuant to Section 5.6.4 of the Callaway Unit 1 Technical Specifications.

*Warren A. Witt*

Warren A. Witt  
Manager, Callaway Plant

WAW/JER/slk

Enclosure

IE24

ULNRC04699

July 10, 2002

Page 2

cc: Mr. Ellis W. Merschoff  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Mr. Jack Donohew (2 copies)  
Licensing Project Manager, Callaway Plant  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop 7E1  
Washington, DC 20555-2738

Manager, Electric Department  
Missouri Public Service Commission  
PO Box 360  
Jefferson City, MO 65102

Mr. Thomas A. Baxter  
Shaw, Pittman, Potts, & Trowbridge  
2300 N. Street N.W.  
Washington, DC 20037

Enclosure  
ULNRC04699  
July 10, 2002

DOCKET NO.: 50-483  
UNIT NAME: CALLAWAY UNIT 1  
COMPLETED BY: J. E. Ready  
TELEPHONE: 573/676-8617  
FAX: 573/676-4202

REPORTING PERIOD: **June/2002**

1. DESIGN ELECTRICAL RATING (MWe-Net): 1171
2. MAX. DEPEND. CAPACITY (MWe-Net): 1125

	<u>THIS MONTH</u>	<u>YR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720	4,023	137,986
4. HOURS GENERATOR ON-LINE	720	3,977	136,127
5. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
6. NET ELECTRICAL ENERGY GENERATED (MWH)	854,151	4,494,080	149,651,598

Enclosure  
ULNRC04699  
July 10, 2002

**UNIT SHUTDOWNS**

DOCKET NO.: 50-483  
UNIT NAME: CALLAWAY UNIT 1  
COMPLETED BY: J. E. Ready  
TELEPHONE: 573/676-8617  
FAX: 573/676-4202

**REPORT June/2002**

<b><u>NO.</u></b>	<b><u>DATE</u></b>	<b>TYPE</b> <b>F: FORCED</b> <b>S: <u>SCHEDULED</u></b>	<b>DURATION</b> <b>(HOURS)</b>	<b><u>REASON</u></b>	<b>METHOD OF</b> <b>SHUTTING DOWN</b> <b>THE REACTOR</b>	<b>CORRECTIVE</b> <b>ACTIONS/</b> <b><u>COMMENTS</u></b>
-------------------	--------------------	---	-----------------------------------	----------------------	--	--

SUMMARY The Callaway Plant did not have a shutdown during the month of June

<b><u>REASON</u></b>	<b><u>METHOD</u></b>
A: EQUIPMENT FAILURE (EXPLAIN)	1: MANUAL
B: MAINT. OR TEST	2: MANUAL SCRAM
C: REFUELING	3: AUTOMATIC SCRAM
D: REGULATORY RESTRICTION	4: CONTINUATION
E: OPERATOR TRAINING / LICENSE EXAMINATION	5: OTHER (EXPLAIN)
F: ADMINISTRATIVE	
G: OPERATIONAL ERROR (EXPLAIN)	
H: OTHER (EXPLAIN)	