Docket No. 50-482

Mr. Bart D. Withers President and Chief Executive Officer Wolf Creek Nuclear Operating Corporation Post Office Box 411 Burlington, Kansas 66839

Dear Mr. Withers:

CORRECTION TO AMENDMENT NO. 23 TO FACILITY OPERATING SUBJECT: LICENSE NO. NPF-42 - WOLF CREEK GENERATING STATION

On December 5, 1988 the staff issued Amendment No. 23 to Facility Operating License No. NPF-42 to revise the Technical Specifications (TS) and corresponding Bases necessary for Cycle 4 operation in response to your application dated June 24, 1988.

Due to an administrative error, TS pages 3/4 1-11 and 3/4 1-12 were inadvertently omitted from the amendment package. Enclosed are the corrected instruction page with a marginal line indicating the area of change and TS pages 3/4 1-11 and 3/4 1-12. Please accept our apology for any inconvenience this may have caused you.

Sincerely,

Doug/Ta/s V. Pickett, Project Manager Project Directorate - IV Division of Reactor Projects - III. IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page

DISTRIBUTION Decket Lile

DUCKEL FILE
L. Rubenstein
D. Hagan
Wanda Jones
ARM/LFMB

NRC PDR P. Noonan E. Jordan E. Butcher PD4 Plant File

Local PDR D. Pickett B. Grimes ACRS (10) J. Calvo

PD4 Reading OGC-Rockville T. Meek (4) GPA/PA

PDA/IA	J.M.
104/17	
PNoonant	sh
121. 100	
12/12/00	

ADOCK

PD4/PM ? DPickett 12/13/88

PD4/D MAC JCalvo 12/3/88

Docket No. 50-482

5

Mr. Bart D. Withers President and Chief Executive Officer Wolf Creek Nuclear Operating Corporation Post Office Box 411 Burlington, Kansas 66839

Dear Mr. Withers:

SUBJECT: CORRECTION TO AMENDMENT NO. 23 TO FACILITY OPERATING LICENSE NO. NPF-42 - WOLF CREEK GENERATING STATION

On December 5, 1988 the staff issued Amendment No. 23 to Facility Operating License No. NPF-42 to revise the Technical Specifications (TS) and corresponding Bases necessary for Cycle 4 operation in response to your application dated June 24, 1988.

Due to an administrative error, TS pages 3/4 1-11 and 3/4 1-12 were inadvertently omitted from the amendment package. Enclosed are the corrected instruction page with a marginal line indicating the area of change and TS pages 3/4 1-11 and 3/4 1-12. Please accept our apology for any inconvenience this may have caused you.

Sincerely,

Doug Taks V. Pickett, Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page

#### DISTRIBUTION Docket File L. Rubenstein D. Hagan

Wanda Jones

٤

ARM/LFMB

NRC PDR P. Noonan E. Jordan E. Butcher PD4 Plant File Local PDR D. Pickett B. Grimes ACRS (10) J. Calvo

PD4 Reading OGC-Rockville T. Meek (4) GPA/PA

PD4/LADA	PD4/PM Q	PD4/D MAC
PNoonant sir	DPickett	JCalvo
12/12/188	12/13/88	12/13/88



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

December 13, 1988

Docket No. 50-482

Mr. Bart D. Withers President and Chief Executive Officer Wolf Creek Nuclear Operating Corporation Post Office Box 411 Burlington, Kansas 66839

Dear Mr. Withers:

SUBJECT: CORRECTION TO AMENDMENT NO. 23 TO FACILITY OPERATING LICENSE NO. NPF-42 - WOLF CREEK GENERATING STATION

On December 5, 1988 the staff issued Amendment No. 23 to Facility Operating License No. NPF-42 to revise the Technical Specifications (TS) and corresponding Bases necessary for Cycle 4 operation in response to your application dated June 24, 1988.

Due to an administrative error, TS pages 3/4 1-11 and 3/4 1-12 were inadvertently omitted from the amendment package. Enclosed are the corrected instruction page with a marginal line indicating the area of change and TS pages 3/4 1-11 and 3/4 1-12. Please accept our apology for any inconvenience this may have caused you.

Sincerely,

teles ~ \_

Douglas V. Pickett, Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page Mr. Bart D. Withers Wolf Creek Nuclear Operating Corporation

cc: Jay Silberg, Esq. Shaw, Pittman, Potts & Trowbridge 1800 M Street, NW Washington, D.C. 20036

Chris R. Rogers, P.E. Manager, Electric Department Public Service Commission P. O. Box 360 Jefferson City, Missouri 65102

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

Senior Resident Inspector/Wolf Creek c/o U. S. Nuclear Regulatory Commission P. O. Box 311 Burlington, Kansas 66839

Mr. Robert Elliot, Chief Engineer Utilities Division Kansas Corporation Commission 4th Floor - State Office Building Topeka, Kansas 66612-1571 Wolf Creek Generating Station Unit No. 1

Mr. Gerald Allen Public Health Physicist Bureau of Air Quality & Radiation Control Division of Environment Kansas Department of Health and Environment Forbes Field Building 321 Topeka, Kansas 66620

Mr. Gary Boyer, Plant Manager Wolf Creek Nuclear Operating Corp. P. O. Box 411 Burlington, Kansas 66839

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. Otto Maynard, Manager Licensing Wolf Creek Nuclear Operating Corp. P. O. Box 411 Burlington, Kansas 66839

## ATTACHMENT TO LICENSE AMENDMENT NO. 23

×. . .

#### FACILITY OPERATING LICENSE NO. NPF-42

## DOCKET NO. 50-482

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES	INSERT PAGES
2-4	2-4
2-5	2-5
2-8	2-8
2-10	2-10
B 2-1	B 2-1
3/4 1-11	3/4 1-11
3/4 1-12	3/4 1-12
3/4 2-8	3/4 2-8
3/4 2-9	3/4 2-9
3/4 5-1	3/4 5-1
3/4 5-10	3/4 5-10
3/4 10-4	3/4 10-4
B 3/4 1-2	B 3/4 1-2
B 3/4 1-3	B 3/4 1-3
B 3/4 2-5	B 3/4 2-5
B 3/4 5-2	B 3/4 5-2

8812160025 PDR Ano P

881213 05000482 PDC

## REACTIVITY CONTROL SYSTEMS

5 B

## BORATED WATER SOURCE - SHUTDOWN

#### LIMITING CONDITION FOR OPERATION

3.1.2.5 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A Boric Acid Storage System with:
  - 1) A minimum contained borated water volume of 2968 gallons,
  - 2) Between 7000 and 7700 ppm of boron, and
  - 3) A minimum solution temperature of 65°F.
- b. The refueling water storage tank (RWST) with:
  - 1) A minimum contained borated water volume of 55,416 gallons,
  - 2) A minimum boron concentration of 2400 ppm, and
  - 3) A minimum solution temperature of 37°F.

APPLICABILITY: MODES 5 and 6.

#### ACTION:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.

#### SURVEILLANCE REQUIREMENTS

4.1.2.5 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
  - 1) Verifying the boron concentration of the water,
  - 2) Verifying the contained borated water volume, and
  - 3) Verifying the Boric Acid Storage System solution temperature when it is the source of borated water.
- b. At least once per 24 hours by verifying the RWST temperature when it is the source of borated water and the outside air temperature is less than 37°F.

## REACTIVITY CONTROL SYSTEMS

# BORATED WATER SOURCES - OPERATING

## LIMITING CONDITION FOR OPERATION

3.1.2.6 As a minimum, the following borated water sources shall be OPERABLE as required by Specification 3.1.2.2 for MODES 1, 2, and 3 and one of the following borated water sources shall be OPERABLE as required by Specifica-tion 3.1.2.1 for MODE 4:

- a. A Boric Acid Storage System with:
  - 1) A minimum contained borated water volume of 17,658 gallons,
  - 2) Between 7000 and 7700 ppm of boron, and
  - 3) A minimum solution temperature of 65°F.
- b. The refueling water storage tank (RWST) with:
  - 1) A minimum contained borated water volume of 394,000 gallons
  - 2) Between 2400 and 2500 ppm of boron,
  - 3) A minimum solution temperature of 37°F, and
  - 4) A maximum solution temperature of 100°F.

APPLICABILITY: MODES 1, 2, 3, and 4.

### ACTION:

- a. With the Boric Acid Storage System inoperable and being used as one of the above required borated water sources in MODE 1, 2 or 3, restore the storage system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least  $1\% \Delta k/k$  at 200°F; restore the Boric Acid Storage System to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the RWST inoperable in MODE 1, 2, or 3, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With no borated water source OPERABLE in MODE 4, restore one borated water source to OPERABLE status within 6 hours or be in COLD SHUTDOWN within the following 30 hours.

WOLF CREEK - UNIT 1