

April 3, 1989

Docket No. 50-482

Mr. Bart D. Withers  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
Post Office Box 411  
Burlington, Kansas 66839

Dear Mr. Withers:

SUBJECT: WOLF CREEK GENERATING STATION - WITHDRAWAL OF AN AMENDMENT  
REQUEST (TAC NO. 63949)

By letter dated November 7, 1986, you applied for an amendment to the Wolf Creek Generating Station Operating License, No. NPF-42. The proposed change would have modified the facility technical specifications pertaining to Emergency Core Cooling Systems Sections 3.5.1 and 3.5.2. The proposed change would permit operation in Mode 3 with low pressure injection discharge valves (8809A and 8809B) isolated or one accumulator discharge isolation valve (8808A, B, C, or D) isolated for an unlimited length of time with no restriction relating to reactor coolant system pressure. Subsequently, by letter dated March 22, 1989, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/s/

Douglas V. Pickett, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
Notice

cc w/enclosure:  
See next page

DISTRIBUTION

Docket File

G. Holahan  
OGC-Rockville  
T. Meek (4)  
GPA/PA

NRC PDR  
L. Rubenstein  
D. Hagan  
Wanda Jones  
ARM/LFMB

Local PDR  
P. Noonan  
E. Jordan  
E. Butcher  
PD4 Plant File

PD4 Reading  
D. Pickett  
B. Grimes  
ACRS (10)

PD4/LA *[Signature]*  
PNoonan  
04/3/89

PD4/PM  
DPickett:sr  
04/3/89

PD4/D *[Signature]*  
JCalvo  
04/3/89 *[Signature]*

DF01  
1/6

8904170014 890403  
PDR ADDCK 05000482  
P PNU



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

April 3, 1989

Docket No. 50-482

Mr. Bart D. Withers  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
Post Office Box 411  
Burlington, Kansas 66839

Dear Mr. Withers:

SUBJECT: WOLF CREEK GENERATING STATION - WITHDRAWAL OF AN AMENDMENT  
REQUEST (TAC NO. 63949)

By letter dated November 7, 1986, you applied for an amendment to the Wolf Creek Generating Station Operating License, No. NPF-42. The proposed change would have modified the facility technical specifications pertaining to Emergency Core Cooling Systems, Sections 3.5.1 and 3.5.2. The proposed change would permit operation in Mode 3 with low pressure injection discharge valves (8809A and 8809B) isolated or one accumulator discharge isolation valve (8808A, B, C, or D) isolated for an unlimited length of time with no restriction relating to reactor coolant system pressure. Subsequently, by letter dated March 22, 1989, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

*Douglas V. Pickett*

Douglas V. Pickett, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
Notice

cc w/enclosure:  
See next page

Mr. Bart D. Withers  
Wolf Creek Nuclear Operating Corporation

Wolf Creek Generating Station  
Unit No. 1

cc:

Jay Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, NW  
Washington, D.C. 20036

Chris R. Rogers, P.E.  
Manager, Electric Department  
Public Service Commission  
P. O. Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Senior Resident Inspector/Wolf Creek  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 311  
Burlington, Kansas 66839

Mr. Robert Elliot, Chief Engineer  
Utilities Division  
Kansas Corporation Commission  
4th Floor - State Office Building  
Topeka, Kansas 66612-1571

Office of the Governor  
State of Kansas  
Topeka, Kansas 66612

Attorney General  
1st Floor - The Statehouse  
Topeka, Kansas 66612

Chairman, Coffey County Commission  
Coffey County Courthouse  
Burlington, Kansas 66839

Mr. Gerald Allen  
Public Health Physicist  
Bureau of Air Quality & Radiation  
Control  
Division of Environment  
Kansas Department of Health  
and Environment  
Forbes Field Building 321  
Topeka, Kansas 66620

Mr. Gary Boyer, Plant Manager  
Wolf Creek Nuclear Operating Corp.  
P. O. Box 411  
Burlington, Kansas 66839

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Otto Maynard, Manager Licensing  
Wolf Creek Nuclear Operating Corp.  
P. O. Box 411  
Burlington, Kansas 66839

UNITED STATES NUCLEAR REGULATORY COMMISSIONWOLF CREEK NUCLEAR OPERATING CORPORATIONDOCKET NO. 50-482NOTICE OF WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The United States Nuclear Regulatory Commission (the Commission) has granted the request of Wolf Creek Nuclear Operating Corporation (the licensee) to withdraw its November 7, 1986 application for proposed amendment to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station, Unit No. 1, located in Burlington Kansas.

The proposed amendment would have revised the technical specifications which would have permitted operation in Mode 3 with certain emergency core cooling system injection valves closed for an unlimited length of time with no restrictions on reactor coolant system pressure.

The Commission has previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on November 25, 1986 (51 FR 42665). However, by letter dated March 22, 1989, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated November 7, 1986, and the licensee's letter dated March 22, 1989, which withdrew the application for license amendment. The above documents are available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C., and the local public documents rooms for

8904170016 890403  
PDR ADDCK 05000482  
P PNU

the Wolf Creek Generating Station located at Emporia State University, William Allen White Library, 1200 Commercial Street, Emporia, Kansas 66801 and Washburn University School of Law Library, Topeka, Kansas.

Dated at Rockville, Maryland this 3rd day of April 1989.

FOR THE NUCLEAR REGULATORY COMMISSION

*Douglas V. Pickett*

Douglas V. Pickett, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation