May 31, 1991

Docket No. 50-482

DISTRIBUTION:

Docket File	BBoger
NRC PDR	GHill (4)
Local PDR	Wanda Jones
PDIV-2 Reading	JCalvo
EPeyton	ACRS (10)
DPickett (2)	GPA/PA
CGrimes	OC/LFMB
OGC	DHagan
Plant File	JRaleigh
AHowell, RIV	JRajan

Mr. Bart D. Withers
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, Kansas 66839

Dear Mr. Withers:

SUBJECT: WOLF CREEK GENERATING STATION - AMENDMENT NO. 44 TO FACILITY OPERATING LICENSE NO. NPF-42 (TAC NO.79922)

The Commission has issued the enclosed Amendment No. 44 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station. The amendment consists of changes to the Technical Specifications in response to your application dated March 5, 1991 (ET 91-0044)

The amendment revises Technical Specification 4.7.8 to incorporate an alternative snubber visual inspection schedule as provided by Generic Letter 90-09, "Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions." This is a line-item improvement that is consistent with the Commission's Policy Statement on Technical Specification improvements.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

Douglas V. Pickett, Project Manager
Project Directorate IV-2
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:
1. Amendment No. 44 to NPF-42
2. Safety Evaluation

cc w/enclosures:
See next page

CP1

OFC	:PDIV-2/LA	:PDIV-2/PM	:OGC	:PDIV-2/D	:	:	:
	:esp	:DVP	:PRF	:GDick for	:	:	:
NAME	:EPeyton	:DPickett:	:	:CGrimes	:	:	:
DATE	:5/8/91	:5/10/91	:5/13/91	:5/30/91	:	:	:

OFFICIAL RECORD COPY
Document Name: WOLF CREEK NPF42 TAC 79922

DF01
1/1

9106070221 910531
PDR ADOCK 05000482
P PDR

NRC FILE CENTER COPY

cc w/enclosures:
Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, NW
Washington, D.C. 20036

Mr. Chris R. Rogers, P.E.
Manager, Electric Department
Public Service Commission
P. O. Box 360
Jefferson City, Missouri 65102

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 311
Burlington, Kansas 66839

Mr. Robert Elliot, Chief Engineer
Utilities Division
Kansas Corporation Commission
4th Floor - State Office Building
Topeka, Kansas 66612-1571

Office of the Governor
State of Kansas
Topeka, Kansas 66612

Attorney General
1st Floor - The Statehouse
Topeka, Kansas 66612

Chairman, Coffey County Commission
Coffey County Courthouse
Burlington, Kansas 66839

Mr. Gerald Allen
Public Health Physicist
Bureau of Air Quality & Radiation Control
Division of Environment
Kansas Department of Health
and Environment
Forbes Field Building 321
Topeka, Kansas 66620

Mr. Gary D. Boyer
Director Plant Operations
Wolf Creek Nuclear Operating Corporation
P. O. Box 411
Burlington, Kansas 66839

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Otto Maynard, Manager
Regulatory Services
Wolf Creek Nuclear Operating Corporation
P. O. Box 411
Burlington, Kansas 66839

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 44
License No. NPF-42

1. The Nuclear Regulatory Commission (the Commission) has found that:

   A. The application for amendment to the Wolf Creek Generating Station (the facility) Facility Operating License No. NPF-42 filed by the Wolf Creek Nuclear Operating Corporation (the Corporation), dated March 5, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;

   B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;

   C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;

   D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and

   E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9106070224 910531
PDR ADOCK 05000482
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-42 is hereby amended to read as follows:

   2. Technical Specifications

      The Technical Specifications contained in Appendix A, as revised through Amendment No. 44 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

George F. Dick, Acting Director
Project Directorate IV-2
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 31, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 44

FACILITY OPERATING LICENSE NO. NPF-42

DOCKET NO. 50-482

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE	INSERT
X	X
XI	XI
3/4 7-19	3/4 7-19
3/4 7-20	3/4 7-20
3/4 7-24	3/4 7-24
3/4 7-25	3/4 7-25
3/4 7-26	3/4 7-26
3/4 7-27	3/4 7-27
3/4 7-28	3/4 7-28
	3/4 7-29
	3/4 7-30

SECTION		PAGE
3/4.5.2	ECCS SUBSYSTEMS - $T_{avg} \geq 350°F$	3/4 5-3
3/4.5.3	ECCS SUBSYSTEMS - $T_{avg} < 350°F$	3/4 5-7
3/4.5.4	ECCS SUBSYSTEMS - $T_{avg} \leq 200°F$	3/4 5-9
3/4.5.5	REFUELING WATER STORAGE TANK	3/4 5-10
3/4.6	CONTAINMENT SYSTEMS	
3/4.6.1	PRIMARY CONTAINMENT	
	Containment Integrity	3/4 6-1
	Containment Leakage	3/4 6-2
	Containment Air Locks	3/4 6-4
	Internal Pressure	3/4 6-6
	Air Temperature	3/4 6-7
	Containment Vessel Structural Integrity	3/4 6-8
	Containment Ventilation System	3/4 6-11
3/4.6.2	DEPRESSURIZATION AND COOLING SYSTEMS	
	Containment Spray System	3/4 6-13
	Spray Additive System	3/4 6-14
	Containment Cooling System	3/4 6-15
3/4.6.3	CONTAINMENT ISOLATION VALVES	3/4 6-16
TABLE 3.6-1	CONTAINMENT ISOLATION VALVES	3/4 6-18
3/4.6.4	COMBUSTIBLE GAS CONTROL	
	Hydrogen Analyzers	3/4 6-31
	Hydrogen Control Systems	3/4 6-32
3/4.7	PLANT SYSTEMS	
3/4.7.1	TURBINE CYCLE	
	Safety Valves	3/4 7-1

SECTION PAGE

TABLE 3.7-1 MAXIMUM ALLOWABLE POWER RANGE NEUTRON FLUX HIGH SETPOINT WITH INOPERABLE STEAM LINE SAFETY VALVES DURING FOUR LOOP OPERATION..... 3/4 7-2

TABLE 3.7-2 STEAM LINE SAFETY VALVES PER LOOP..... 3/4 7-3
Auxiliary Feedwater System..... 3/4 7-4
Condensate Storage Tank..... 3/4 7-6
Specific Activity..... 3/4 7-7
TABLE 4.7-1 SECONDARY COOLANT SYSTEM SPECIFIC ACTIVITY SAMPLE AND ANALYSIS PROGRAM..... 3/4 7-8
Main Steam Line Isolation Valves..... 3/4 7-9

3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION..... 3/4 7-10

3/4.7.3 COMPONENT COOLING WATER SYSTEM..... 3/4 7-11

3/4.7.4 ESSENTIAL SERVICE WATER SYSTEM..... 3/4 7-12

3/4.7.5 ULTIMATE HEAT SINK..... 3/4 7-13

3/4.7.6 CONTROL ROOM EMERGENCY VENTILATION SYSTEM..... 3/4 7-14

3/4.7.7 EMERGENCY EXHAUST SYSTEM..... 3/4 7-17

3/4.7.8 SNUBBERS..... 3/4 7-19

TABLE 4.7-2 SNUBBER VISUAL INSPECTION INTERVAL..... 3/4 7-24

FIGURE 4.7-1 SAMPLING PLAN 2) FOR SNUBBER FUNCTIONAL TEST..... 3/4 7-26

3/4.7.9 SEALED SOURCE CONTAMINATION..... 3/4 7-27

SECTION	PAGE
PLANT SYSTEMS (Continued)	
3/4.7.10 DELETED	
TABLE 3.7-3 DELETED	
3/4.7.11 DELETED	
3/4.7.12 AREA TEMPERATURE MONITORING.....	3/4 7-29
TABLE 3.7-4 AREA TEMPERATURE MONITORING.....	3/4 7-30
3/4.8 ELECTRICAL POWER SYSTEMS	
3/4.8.1 A.C. SOURCES	
Operating.....	3/4 8-1
TABLE 4.8-1 DIESEL GENERATOR TEST SCHEDULE.....	3/4 8-7
Shutdown.....	3/4 8-8
3/4.8.2 D.C. SOURCES	
Operating.....	3/4 8-9
TABLE 4.8-2 BATTERY SURVEILLANCE REQUIREMENTS.....	3/4 8-11
Shutdown.....	3/4 8-12
3/4.8.3 ONSITE POWER DISTRIBUTION	
Operating.....	3/4 8-13
Shutdown.....	3/4 8-15
3/4.8.4 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES	
Containment Penetration Conductor Overcurrent Protective Devices.....	3/4 8-16

SECTION		PAGE
3/4.9	REFUELING OPERATIONS	
3/4.9.1	BORON CONCENTRATION	3/4 9-1
3/4.9.2	INSTRUMENTATION	3/4 9-2
3/4.9.3	DECAY TIME	3/4 9-3
3/4.9.4	CONTAINMENT BUILDING PENETRATIONS	3/4 9-4
3/4.9.5	COMMUNICATIONS	3/4 9-5
3/4.9.6	REFUELING MACHINE	3/4 9-6
3/4.9.7	CRANE TRAVEL - SPENT FUEL STORAGE FACILITY	3/4 9-8
3/4.9.8	RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION	
	High Water Level	3/4 9-9
	Low Water Level	3/4 9-10
3/4.9.9	CONTAINMENT VENTILATION SYSTEM	3/4 9-11
3/4.9.10	WATER LEVEL - REACTOR VESSEL	
	Fuel Assemblies	3/4 9-12
	Control Rods	3/4 9-13
3/4.9.11	WATER LEVEL - STORAGE POOL	3/4 9-14
3/4.9.12	SPENT FUEL ASSEMBLY STORAGE	3/4 9-15
FIGURE 3.9-1	MINIMUM REQUIRED FUEL ASSEMBLY EXPOSURE AS A FUNCTION OF INITIAL ENRICHMENT TO PERMIT STORAGE IN REGION 2	3/4 9-16
3/4.9.13	EMERGENCY EXHAUST SYSTEM	3/4 9-17

3/4.7.8 SNUBBERS

LIMITING CONDITION FOR OPERATION

3.7.8 All snubbers shall be OPERABLE. The only snubbers excluded from the requirement are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed would have no adverse effect on any safety-related system.

APPLICABILITY: MODES 1, 2, 3, and 4. MODES 5 and 6 for snubbers located on systems required OPERABLE in those MODES.

ACTION:

With one or more snubbers inoperable on any system, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.8g on the attached component or declare the attached system inoperable and follow the appropriate ACTION statement for that system.

SURVEILLANCE REQUIREMENTS

4.7.8 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program and the requirements of Specification 4.0.5.

a. Inspection Types

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

b. Visual Inspections

Snubbers are categorized as inaccessible or accessible during reactor operation. Each of these categories (inaccessible and accessible) may be inspected independently according to the schedule determined by Table 4.7-2. The visual inspection interval for each type snubber shall be determined based upon the criteria provided in Table 4.7-2 and the first inspection interval determined using this criteria shall be based upon the previous inspection interval as established by the requirements in effect before amendment 44.

SURVEILLANCE REQUIREMENTS (Continued)

c. Visual Inspection Acceptance Criteria

Visual inspections shall verify that: (1) there are no visible indications of damage or impaired OPERABILITY, and (2) attachments to the foundation or supporting structure are functional, and (3) fasteners for attachment of the snubber to the component and to the snubber anchorage are functional. Snubbers which appear inoperable as a result of visual inspections shall be classified as unacceptable and may be reclassified acceptable for the purpose of establishing the next visual inspection interval, provided that: (1) the cause of the rejection is clearly established and remedied for that particular snubber and for other snubbers irrespective of type that may be generically susceptible; or (2) the affected snubber is functionally tested in the as-found condition and determined OPERABLE per Specification 4.7.8f. All snubbers found connected to an inoperable common hydraulic fluid reservoir shall be counted as unacceptable for determining the next inspection interval. A review and evaluation shall be performed and documented to determine system operability with an unacceptable snubber. If operability cannot be justified, the system shall be declared inoperable and the ACTION requirements shall be met.

d. Transient Event Inspections

An inspection shall be performed of all hydraulic and mechanical snubbers attached to sections of systems that have experienced unexpected, potentially damaging transients as determined from a review of operational data and a visual inspection of the systems within 6 months following such an event. In addition to satisfying the visual inspection acceptance criteria, freedom-of-motion of mechanical snubbers shall be verified using at least one of the following: (1) manually induced snubber movement; (2) evaluation of in-place snubber piston setting; or (3) stroking the mechanical snubber through its full range of travel.

SURVEILLANCE REQUIREMENTS (Continued)

g. Service Life Monitoring Program (Continued)

For the snubbers found inoperable, an engineering evaluation shall be performed on the components to which the inoperable snubbers are attached. The purpose of this engineering evaluation shall be to determine if the components to which the inoperable snubbers are attached were adversely affected by the inoperability of the snubbers in order to ensure that the component remains capable of meeting the designed service.

If any snubber selected for functional testing either fails to lock up or fails to move, i.e., frozen-in-place, the cause will be evaluated and, if caused by manufacturer or design deficiency, all snubbers of the same type subject to the same defect shall be functionally tested. This testing requirement shall be independent of the requirements stated in Specification 4.7.8e. for snubbers not meeting the functional test acceptance criteria.

h. Functional Testing of Repaired and Replaced Snubbers

Snubbers which fail the visual inspection or the functional test acceptance criteria shall be repaired or replaced. Replacement snubbers and snubbers which have repairs which might affect the functional test results shall be tested to meet the functional test criteria before installation in the unit. Mechanical snubbers shall have met the acceptance criteria subsequent to their most recent service, and the freedom-of-motion test must have been performed within 12 months before being installed in the unit.

i. Snubber Service Life Program

The service life of hydraulic and mechanical snubbers shall be monitored to ensure that the service life is not exceeded between surveillance inspections. The maximum expected service life for various seals, springs, and other critical parts shall be determined and established based on engineering information and shall be extended or shortened based on monitored test results and failure history. Critical parts shall be replaced so that the maximum service life will not be exceeded during a period when the snubber is required to be OPERABLE. The parts replacements shall be documented and the documentation shall be retained in accordance with Specification 6.10.2.

TABLE 4.7-2
SNUBBER VISUAL INSPECTION INTERVAL

Population per Catergory (Notes 1 and 2)		NUMBER OF UNACCEPTABLE SNUBBERS Column A Extend Interval (Extend 3 and 6)	Column B Repeat Interval (Notes 4 and 6)	Column C Reduce Interval (Notes 5 and 6)
1		0	0	1
80		0	0	2
100		0	1	4
150		0	3	8
200		2	5	13
300		5	12	25
400		8	18	36
500		12	24	48
750		20	40	78
1000	or greater	29	56	109

Note 1: The next visual inspection interval for a snubber category shall be determined based upon the previous inspection interval and the number of unacceptable snubbers found during that interval. Snubbers may be categorized, based upon their accessibility during power operation, as accessible or inaccessible. These categories may be examined separately or jointly. However, categories must be determined and documented before any inspection and that determination shall be the basis upon which to determine the next inspection interval for that category.

Note 2: Interpolation between population per category and the number of unacceptable snubbers is permissible. Use next lower integer for the value of the limit for Columns A, B, and C if that integer includes a fractional value of unacceptable snubbers as determined by interpolation.

Table 4.7-2 (Continued)
SNUBBER VISUAL INSPECTION INTERVAL

Note 3: If the number of unacceptable snubbers is equal to or less than the number in Column A, the next inspection interval may be twice the previous interval but not greater than 48 months.

Note 4: If the number of unacceptable snubbers is equal to or less than the number in Column B but greater than the number in Column A, the next inspection interval shall be the same as the previous interval.

Note 5: If the number of unacceptable snubbers is equal to or greater than the number in Column C, the next inspection interval shall be two-thirds of the previous interval. However, if the number of unacceptable snubbers is less than the number in Column C but greater than the number in Column B, the next interval shall be reduced proportionally by interpolation, that is, the previous interval shall be reduced by a factor that is one-third of the ratio of the difference between the number of unacceptable snubbers found during the previous interval and the number in Column B to the difference in the numbers in Column B and C.

Note 6: The provisions of Specification 4.0.2 are applicable for all inspection intervals up to and including 48 months.



FIGURE 4.7-1

SAMPLE PLAN 2) FOR SNUBBER FUNCTIONAL TEST

3/4.7.9 SEALED SOURCE CONTAMINATION

LIMITING CONDITION FOR OPERATION

3.7.9 Each sealed source containing radioactive material either in excess of 100 microCuries of beta and/or gamma-emitting material or 5 microCuries of alpha emitting material shall be free of greater than or equal to 0.005 microCurie of removable contamination.

APPLICABILITY: At all times.

ACTION:

a. With a sealed source having removable contamination in excess of the above limits, immediately withdraw the sealed source from use and either:

   1. Decontaminate and repair the sealed source, or

   2. Dispose of the sealed source in accordance with Commission Regulations.

b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.7.9.1 Test Requirements - Each sealed source shall be tested for leakage and/or contamination by:

a. The licensee, or

b. Other persons specifically authorized by the Commission or an Agreement State.

The test method shall have a detection sensitivity of at least 0.005 microCurie per test sample.

4.7.9.2 Test Frequencies - Each category of sealed sources (excluding startup sources and fission detectors previously subjected to core flux) shall be tested at the frequency described below.

a. Sources in use - At least once per 6 months for all sealed sources containing radioactive materials:

   1) With a half-life greater than 30 days (excluding Hydrogen 3), and

   2) In any form other than gas.

SURVEILLANCE REQUIREMENTS (Continued)

b. Stored sources not in use - Each sealed source and fission detector shall be tested prior to use or transfer to another licensee unless tested within the previous 6 months. Sealed sources and fission detectors transferred without a certificate indicating the last test date shall be tested prior to being placed into use; and

c. Startup sources and fission detectors - Each sealed startup source and fission detector shall be tested within 31 days prior to being subjected to core flux or installed in the core and following repair or maintenance to the source.

4.7.9.3 Reports - A report shall be prepared and submitted to the Commission on an annual basis if sealed source or fission detector leakage tests reveal the presence of greater than or equal to 0.005 microCurie of removable contamination.

3/4.7.12 AREA TEMPERATURE MONITORING

LIMITING CONDITION FOR OPERATION

3.7.12 The temperature limit of each area given in Table 3.7-4 shall not be exceeded for more than 8 hours or by more than 30°F.

APPLICABILITY: Whenever the equipment in an affected area is required to be OPERABLE.

ACTION:

a. With one or more areas exceeding the temperature limit(s) shown in Table 3.7-4 for more than 8 hours, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report that provides a record of the cumulative time and the amount by which the temperature in the affected area(s) exceeded the limit(s) and an analysis to demonstrate the continued OPERABILITY of the affected equipment. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

b. With one or more areas exceeding the temperature limit(s) shown in Table 3.7-4 by more than 30°F, prepare and submit a Special Report as required by ACTION a. above, and within 4 hours either restore the area(s) to within the temperature limit(s) or declare the equipment in the affected area(s) inoperable.

SURVEILLANCE REQUIREMENTS

4.7.12 The temperature in each of the areas shown in Table 3.7-4 shall be determined to be within its limit at least once per 12 hours.

TABLE 3.7-4

AREA TEMPERATURE MONITORING

	AREA	MAXIMUM TEMPERATURE LIMIT (°F)
1.	ESW Pump Room A	119
2.	ESW Pump Room B	119
3.	Auxiliary Feedwater Pump Room A	119
4.	Auxiliary Feedwater Pump Room B	119
5.	Turbine Driven Auxiliary Feedwater Pump Room	147
6.	ESF Switchgear Room I	87
7.	ESF Switchgear Room II	87
8.	RHR Pump Room A	119
9.	RHR Pump Room B	119
10.	CTMT Spray Pump Room A	119
11.	CTMT Spray Pump Room B	119
12.	Safety Injection Pump Room A	119
13.	Safety Injection Pump Room B	119
14.	Centrifugal Charging Pump Room A	119
15.	Centrifugal Charging Pump Room B	119
16.	Electrical Penetration Room A	101
17.	Electrical Penetration Room B	101
18.	Component Cooling Water Room A	119
19.	Component Cooling Water Room B	119
20.	Diesel Generator Room A	119
21.	Diesel Generator Room B	119
22.	Control Room	84

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 44 TO FACILITY OPERATING LICENSE NO. NPF-42

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

1.0 INTRODUCTION

By application dated March 5, 1991, Wolf Creek Nuclear Operating Corporation (the licensee) requested changes to the Technical Specifications (Appendix A to Facility Operating License No. NPF-42) for the Wolf Creek Generating Station. The proposed changes would revise Specification 4.7.8 to incorporate an alternative snubber visual inspection schedule as provided by Generic Letter 90-09, "Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions."

2.0 EVALUATION

Technical Specifications (TS) impose surveillance requirements for visual inspection and functional testing of all safety-related snubbers. A visual inspection is the observation of the condition of installed snubbers to identify those that are damaged, degraded, or inoperable as caused by physical means, leakage, corrosion, or environmental exposure. To verify that a snubber can operate within specific performance limits, the licensee performs functional testing that typically involves removing the snubber and testing it on a specially-designed test stand. Functional testing provides a 95 percent confidence level that 90 percent to 100 percent of the snubbers operate within the specified acceptance limits. The performance of visual examinations is a separate process that complements the functional testing program and provides additional confidence in snubber operability.

The TS specifies a schedule for snubber visual inspections that is based on the number of inoperable snubbers found during the previous visual inspection. The schedules for visual inspections and for the functional testing assume that refueling intervals will not exceed 18 months. Because the current schedule for snubber visual inspections is based only on the number of inoperable snubbers found during the previous visual inspection, irrespective of the size of the snubber population, licensees having a large number of snubbers find that the visual inspection schedule is excessively restrictive. Some licensees have spent a significant amount of resources and have subjected plant personnel to unnecessary radiological exposure to comply with the visual examination requirements.

9106070247 910531
PDR ADOCK 05000482
P PDR

To alleviate this situation, in Generic Letter (GL) 90-09 the staff developed an alternate schedule for visual inspections that maintains the same confidence level as the existing schedule and generally will allow the licensee to perform visual inspections and corrective actions during plant outages. Because this line-item TS improvement will reduce future occupational radiation exposure and is highly cost effective, the alternative inspection schedule is consistent with the Commission's Policy Statement on TS improvements.

The alternative inspection schedule is based on the number of unacceptable snubbers found during the previous inspection in proportion to the sizes of the various snubber populations or categories. A snubber is considered unacceptable if it fails the acceptance criteria of the visual inspection. The alternative inspection interval is based on a fuel cycle of up to 24 months and may be as long as 2 fuel cycles, or 48 months for plants with other fuel cycles, depending on the number of unacceptable snubbers found during the previous visual inspection.

In its letter of March 5, 1991, the licensee proposed changes to Technical Specification 4.7.8 for the snubber visual examination schedule. Since the alternative inspection schedule proposed by the licensee is consistent with the guidance provided in GL 90-09, the staff finds the proposed changes acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Kansas State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (56 FR 13672). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Douglas Pickett, PDIV-2/DRPW
Jai Rajan, EMEB/DET

Date: May 31, 1991