

August 27, 1993

Docket No. 50-482

DISTRIBUTION:

Docket File	JRoe
NRC PDR	GHill (2)
Local PDR	OPA
PDIV-2 Reading	CGrimes
EPeyton	ACRS (10)
WReckley (2)	OC/LFMB
EAdensam	DHagan
OGC	WJohnson, RIV

Mr. Neil S. Carns  
 President and Chief Executive Officer  
 Wolf Creek Nuclear Operating Corporation  
 Post Office Box 411  
 Burlington, Kansas 66839

Dear Mr. Carns:

SUBJECT: WOLF CREEK GENERATING STATION - AMENDMENT NO. 67 TO FACILITY  
 OPERATING LICENSE NO. NPF-42 (TAC NO. M85305)

The Commission has issued the enclosed Amendment No. 67 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station. The amendment consists of changes to the Technical Specifications in response to your application dated

The amendment revises Technical Specifications Sections 4.0.3 and 4.0.4 and associated Bases on the applicability of surveillance requirements in accordance with the guidance of Generic Letter 87-09, "Sections 3.0 and 4.0 of the Standard Technical Specifications (STS) on the Applicability of Limiting Conditions for Operation and Surveillance Requirements."

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

William D. Reckley, Project Manager  
 Project Directorate IV-2  
 Division of Reactor Projects III/IV/V  
 Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.67 to NPF-42
2. Safety Evaluation

cc w/enclosures:  
 See next page

OFFICE	PDIV-2/LA	PDIV-2/PM	OGC	PDIV-2/D	OTSB
NAME	EPeyton	WReckley:nb	C MARCO	SBlack	CGrimes
DATE	7/28/93	7/29/93	8/11/93	8/12/93	8/19/93

Document Name: b:\M85305.Amd

TGD #93-130

9309140367 930827  
 PDR ADOCK 05000482  
 P PDR

**NRC FILE CENTER COPY**

*DFol*  
*11*

cc w/enclosures:

Jay Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW  
Washington, D.C. 20037

Mr. C. John Renken  
Policy and Federal Department  
Missouri Public Service Commission  
P. O. Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 311  
Burlington, Kansas 66839

Mr. Robert Elliot, Chief Engineer  
Utilities Division  
Kansas Corporation Commission  
1500 SW Arrowhead Road  
Topeka, Kansas 66604-4027

Office of the Governor  
State of Kansas  
Topeka, Kansas 66612

Attorney General  
1st Floor - The Statehouse  
Topeka, Kansas 66612

County Clerk  
Coffey County Courthouse  
Burlington, Kansas 66839

Mr. Gerald Allen  
Public Health Physicist  
Bureau of Environmental Health Services  
Division of Health  
Kansas Department of Health  
and Environment  
109 SW Ninth  
Topeka, Kansas 66612

Mr. Otto Maynard  
Director Plant Operations  
Wolf Creek Nuclear Operating Corporation  
P. O. Box 411  
Burlington, Kansas 66839

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Keven J. Moles  
Manager Regulatory Services  
Wolf Creek Nuclear Operating Corporation  
P. O. Box 411  
Burlington, Kansas 66839



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 67  
License No. NPF-42

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Wolf Creek Generating Station (the facility) Facility Operating License No. NPF-42 filed by the Wolf Creek Nuclear Operating Corporation (the Corporation), dated December 22, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9309140374 930827  
PDR ADDCK 05000482  
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-42 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 67, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Suzanne C. Black, Director  
Project Directorate IV-2  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 27, 1993

ATTACHMENT TO LICENSE AMENDMENT NO. 67

FACILITY OPERATING LICENSE NO. NPF-42

DOCKET NO. 50-482

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE

3/4 0-2  
B 3/4 0-2  
B 3/4 0-3

INSERT

3/4 0-2  
B 3/4 0-2  
B 3/4 0-3  
B 3/4 0-4

## 3/4 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

### 3/4.0 APPLICABILITY

#### LIMITING CONDITION FOR OPERATION

---

3.0.1 Compliance with the Limiting Conditions for Operation contained in the succeeding specifications is required during the OPERATIONAL MODES or other conditions specified therein; except that upon failure to meet the Limiting Conditions for Operation, the associated ACTION requirements shall be met.

3.0.2 Noncompliance with a specification shall exist when the requirements of the Limiting Condition for Operation and associated ACTION requirements are not met within the specified time intervals. If the Limiting Condition for Operation is restored prior to expiration of the specified time intervals, completion of the ACTION requirements is not required.

3.0.3 When a Limiting Condition for Operation is not met, except as provided in the associated ACTION requirements, within 1 hour action shall be initiated to place the unit in a MODE in which the specification does not apply by placing it, as applicable, in:

- a. At least HOT STANDBY within the next 6 hours,
- b. At least HOT SHUTDOWN within the following 6 hours, and
- c. At least COLD SHUTDOWN within the subsequent 24 hours.

Where corrective measures are completed that permit operation under the ACTION requirements, the action may be taken in accordance with the specified time limits as measured from the time of failure to meet the Limiting Condition for Operation. Exceptions to these requirements are stated in the individual specifications.

This Specification is not applicable in MODE 5 or 6.

3.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the conditions for the Limiting Condition for Operation are met without reliance on provisions contained in the ACTION requirements. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements. Exceptions to these requirements are stated in the individual specifications.

## APPLICABILITY

### SURVEILLANCE REQUIREMENTS

---

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25% of the specified interval.

4.0.3 Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specification 4.0.2, shall constitute noncompliance with the OPERABILITY requirements for a Limiting Condition for Operation. The allowable outage time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. The ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the ACTION requirements are less than 24 hours. Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with a Limiting Condition of Operation has been performed within the stated surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR Part 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR Part 50, Section 50.55a(6)(i);

### 3/4.0 APPLICABILITY

#### BASES

---

The intent of this provision is to ensure that facility operation is not initiated with either required equipment or systems inoperable or other specified limits being exceeded.

Exceptions to this provisions have been provided for a limited number of specifications when startup with inoperable equipment would not affect plant safety. These exceptions are stated in the ACTION statements of the appropriate specifications.

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements. Surveillance Requirements for Special Test Exceptions need only be performed when the Special Test Exception is being utilized as an exception to an individual specification.

4.0.2 Specification 4.0.2 establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18 month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 The provisions of this specification establishes the failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, as a condition that constitutes a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Under the provisions of this specification, systems and components are assumed to be OPERABLE when Surveillance Requirements have been satisfactorily performed within the allowed surveillance interval. However, nothing in this provision is to be construed as implying that systems or components are OPERABLE when they are found or known to be inoperable although still meeting the Surveillance Requirements. This specification also clarifies that the ACTION requirements are applicable when Surveillance Requirements have not been completed within the allowed surveillance interval and that the time limits of the ACTION requirements apply from the point in

### 3/4.0 APPLICABILITY

#### BASES

time it is identified that a surveillance has not been performed and not at the time that the allowed surveillance interval was exceeded. Completion of the Surveillance Requirement within the allowable outage time limits of the ACTION requirements restores compliance with the requirements of Specification 4.0.3. However, this does not negate the fact that failure to have performed the surveillance within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, was a violation of the OPERABILITY requirements of a Limiting Condition for Operation.

If the allowable outage time limits of the ACTION requirements are less than 24 hours or a shutdown is required to comply with the ACTION requirements, e.g., Specification 3.0.3, a 24-hour allowance is provided to permit a delay in implementing the ACTION requirements. This provides an adequate time limit to complete Surveillance Requirements that have not been performed. The purpose of this allowance is to permit the completion of a surveillance before a shutdown would be required to comply with ACTION requirements or before other remedial measures would be required that may preclude completion of a surveillance. The basis for this allowance includes consideration for plant conditions, adequate planning, availability of personnel, the time required to perform the surveillance, and the safety significance of the delay in completing the required surveillance. If a surveillance is not completed within the 24-hour allowance, the allowable outage time limits of the ACTION requirements are applicable at that time. When a surveillance is performed within the 24-hour allowance and the Surveillance Requirements are not met, the time limits of the ACTION requirements are applicable at the time that the surveillance is terminated.

Surveillance Requirements do not have to be performed on inoperable equipment because the ACTION requirements define the remedial measures that apply. However, the Surveillance Requirements have to be met to demonstrate that inoperable equipment has been restored to OPERABLE status.

4.0.4 This specification establishes the requirement that all applicable surveillances must be met before entry into an OPERATIONAL MODE or other condition of operation specified in the Applicability statement. The purpose of this specification is to ensure that system and component OPERABILITY requirements or parameter limits are met before entry into a MODE or condition for which these systems and components ensure safe operation of the facility. This provision applies to changes in OPERATIONAL MODES or other specified conditions associated with plant shutdown as well as startup.

Under the provisions of this specification, the applicable Surveillance Requirements must be performed within the specified surveillance interval to ensure that the Limiting Conditions for Operation are met during initial plant startup or following a plant outage.

When a shutdown is required to comply with ACTION requirements, the provisions of Specification 4.0.4 do not apply because this would delay placing the facility in a lower MODE of operation.

### 3/4.0 APPLICABILITY

#### BASES

---

4.0.5 This specification ensures that inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves will be performed in accordance with a periodically updated version of Section XI of the ASME Boiler and Pressure Vessel Code and Addenda as required by 10 CFR 50.55a. Relief from any of the above requirements has been provided in writing by the Commission and is not a part of these Technical Specifications.

This specification includes a clarification of the frequencies for performing the inservice inspection and testing activities required by Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda. This clarification is provided to ensure consistency in surveillance intervals throughout these Technical Specifications and to remove any ambiguities relative to the frequencies for performing the required inservice inspection and testing activities.

Under the terms of this specification, the more restrictive requirements of the Technical Specifications take precedence over the ASME Boiler and Pressure Vessel Code and applicable Addenda. For example, the requirements of Specification 4.0.4 to perform surveillance activities prior to entry into an OPERATIONAL MODE or other specified applicability condition takes precedence over the ASME Boiler and Pressure Vessel Code provision which allows pumps to be tested up to 1 week after return to normal operation. And for example, the Technical Specification definition of OPERABLE does not grant a grace period before a device that is not capable of performing its specified function is declared inoperable and takes precedence over the ASME Boiler and Pressure Vessel Code provision which allows a valve to be incapable of performing its specified function for up to 24 hours before being declared inoperable.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 67 TO FACILITY OPERATING LICENSE NO. NPF-42  
WOLF CREEK NUCLEAR OPERATING CORPORATION  
WOLF CREEK GENERATING STATION  
DOCKET NO. 50-482

1.0 INTRODUCTION

By letter dated December 22, 1992, Wolf Creek Nuclear Operating Corporation, the licensee, requested an amendment to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station. The proposed amendment would change the plant Technical Specifications (TS) based on the recommendations provided by the NRC staff in Generic Letter (GL) 87-09, "Sections 3.0 and 4.0 of the Standard Technical Specifications (STS) on the Applicability of Limiting Conditions for Operation and Surveillance Requirements" related to the applicability of limiting conditions for operation (LCO) and the surveillance requirements of TS 4.0. Specifically, the licensee has requested the following revisions to TS 4.0.3 and 4.0.4:

Specification 4.0.3 would be revised to incorporate a 24-hour delay in implementing action requirements due to a missed surveillance when the action requirements provide a restoration time that is less than 24 hours.

Specification 4.0.4 would be revised to clarify that "This provision shall not prevent passage through or to OPERATIONAL CONDITIONS as required to comply with ACTION requirements."

2.0 EVALUATION

The changes proposed by the licensee have been reviewed considering the limitations set forth in GL 87-09 for TS 4.0.3 and 4.0.4 as follows.

Specification 4.0.3

In GL 87-09 the staff stated that it is overly conservative to assume that systems or components are inoperable when a surveillance requirement has not been performed, because the vast majority of surveillances demonstrate that systems or components in fact are operable. Because the allowable outage time limits of some action requirements do not provide an appropriate time limit for performing a missed surveillance before shutdown requirements apply, the TS should include a time limit that would allow a delay of the required actions to permit the performance of the missed surveillance.

The NRC staff provided in GL 87-09 a clarification that: (a) it is not the intent of 4.0.3 that the action requirements preclude the performance of surveillance allowed under any exception to TS 4.0.4; and (b) the delay of up to 24 hours in TS 4.0.3 for the applicability of action requirements provides an appropriate time limit for the completion of surveillance requirements that become applicable as a consequence of any exception to TS 4.0.4.

The NRC staff finds the proposed changes to TS 4.0.4 acceptable.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Kansas State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

The amendment involves changes to surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (58 FR 32392). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: John K. Ganiere, NRR

Date: August 27, 1993

This time limit should be based on considerations of plant conditions, adequate planning, availability of personnel, and the time required to perform the surveillance, as well as the safety significance of the delay in completion of the surveillance. After reviewing possible limits, the staff concluded that, based on these considerations, 24 hours would be an acceptable time limit for completing a missed surveillance when the allowable outage times of the action requirements are less than this time limit or when shutdown action requirements apply. The 24-hour time limit would balance the risks associated with an allowance for completing the surveillance within this period against the risks associated with the potential for a plant upset and challenge to safety systems when the alternative is a shutdown to comply with action requirements before the surveillance can be completed.

Based on the above, the following change to Specification 4.0.3 is acceptable:

Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specification 4.0.2, shall constitute noncompliance with the OPERABILITY requirements for a Limiting Condition for Operation. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. Compliance with the ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the Action requirements are less than 24 hours.

#### Specification 4.0.4

TS 4.0.4 prohibits entry into an operational condition or other specified condition until all required surveillances have been performed. This could cause an interpretation problem when operational condition changes are required in order to comply with action statements. Specifically, two possible conflicts between TS 4.0.3 and 4.0.4 could exist. The first conflict arises because TS 4.0.4 prohibits entry into an operational mode or other specified condition when surveillance requirements have not been performed within the specified surveillance interval. The proposed modification to resolve this conflict involves the revision to TS 4.0.3 to permit a delay of up to 24 hours in the application of the action requirements, as explained above, and a clarification to TS 4.0.4 to allow passage through or to operational modes as required to comply with action requirements. The second potential conflict between TS 4.0.3 and 4.0.4 arises because an exception to the requirements of 4.0.4 is allowed when surveillance requirements can be completed only after entry into a mode or condition. However, after entry into this mode or condition, the requirements of TS 4.0.3 may not be met because the Surveillance Requirements may not have been performed within the allowable surveillance interval.

The licensee proposes to resolve these conflicts by providing the following clarifying statement to TS 4.0.4:

"This provision shall not prevent passage through or to OPERATIONAL CONDITIONS as required to comply with ACTION requirements."