

JUL 15 2002

LR-N02-0252



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 2
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **June 2002** are being forwarded.

Sincerely,

A handwritten signature in black ink that reads "D. F. Garchow". The signature is written in a cursive style with a large, sweeping initial "D".

D. F. Garchow
Vice President - Operations

RAR
Attachments

C Distribution

IE24

DOCKET NO.: 50-311
 UNIT: Salem 2
 DATE: 07/10/02
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period June 2002

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1131		
1092		
Month	Year-to-date	Cumulative
720	3286	115999
720	3203	112541
0	0	0
797288	3488657	114310198

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-311
UNIT: Salem 2
DATE: 07/10/02
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 2 began the month at 100% reactor power.
- On June 10, Salem 2 reduced power to approximately 75% as requested by the Load Dispatcher due to a fire near the 500KV 5021 Deans Line. Power was restored to approximately 100% later that day.
- At the end of the month, Salem 2 completed 44 days of continuous on line operation.