

Exelon Generation Company, LLC
Byron Station
4450 North German Church Road
Byron, IL 61010-9794

www.exeloncorp.com

July 15, 2002

LTR: BYRON 2002-0073
File: 2.07.0200

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Byron Station, Units 1 and 2
Facility Operating License Nos. NPF-37 and NPF-66
NRC Docket Nos. STN 50-454 and STN 50-455

Subject: Monthly Operating Report

In accordance with Technical Specification 5.6.4, "Monthly Operating Reports," we are submitting the Monthly Operating Report for Byron Station, Units 1 and 2. This report covers the period June 1, 2002, through June 30, 2002.

If you have any questions regarding this report, please contact Mr. William Grundmann, Regulatory Assurance Manager, at (815) 406-2800.

Respectfully,



Stephen E. Kuczynski
Plant Manager
Byron Nuclear Generating Station

SEK/DD/rah

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Byron Station
NRC Project Manager – NRR – Byron Station
Office of Nuclear Facility Safety – Illinois Department of Nuclear Safety

JE24

ATTACHMENT

BYRON STATION, UNIT 1 AND UNIT 2
MONTHLY OPERATING REPORT

EXELON GENERATION COMPANY, LLC

FACILITY OPERATING LICENSE NOS. NPF-37 AND NPF-66
NRC DOCKET NOS. STN 50-454 AND STN 50-455

OPERATING DATA REPORT
UNIT ONE

DOCKET NO.	50-454
UNIT NAME	Byron One
DATE	07/15/02
COMPLETED BY	D. Drawbaugh
TELEPHONE	(815) 406-2813

REPORTING PERIOD: June, 2002
(Month/Year)

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
1. Design Electrical Rating (MWe-Net). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	1,187	N/A	N/A
2. Maximum Dependable Capacity (MWe-Net). The gross electrical output as measured at the output terminals of the turbine-generator during the most restrictive seasonal conditions minus the normal station service loads.	1,163	N/A	N/A
3. Number of Hours the Reactor was Critical. The total number of hours during the gross hours of the reporting period that the reactor was critical.	720	3,914.25	124,869.82
4. Number of Hours the Generator was On Line (also called Service Hours). The total number of hours during the gross hours of the reporting period that the unit operated with breakers closed to the station bus. The sum of the hours the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	720	3,901.18	123,865.72
5. Unit Reserve Shutdown Hours. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0	0	0
6. Net Electrical Energy (MWH). The gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	859,306	4,609,454	128,048,031

UNIT SHUTDOWNS

DOCKET NO. 50-454
 UNIT NAME Byron One
 DATE 07/15/02
 COMPLETED BY D. Drawbaugh
 TELEPHONE (815) 406-2813

REPORTING PERIOD: June 2002

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS

SUMMARY: Unit 1 On-Line During the Month of June.

- (1) Reason
- A – Equipment Failure (Explain)
 - B – Maintenance Test
 - C – Refueling
 - D – Regulatory Restriction
 - E – Operator Training/License Examination
 - F – Administrative
 - G – Operational Error (Explain)
 - H – Other (Explain)

- (2) Method
- 1 – Manual
 - 2 – Manual Trip/Scram
 - 3 – Automatic Trip/Scram
 - 4 – Continuation
 - 5 – Other (Explain)

UNIQUE REPORTING REQUIREMENTS (UNIT ONE)
for the month of June, 2002

1. Safety/Relief valve operations for Unit One. This information is provided pursuant to the reporting requirements contained in Technical Specification 5.6.4, "Monthly Operating Report."

<u>DATE</u>	<u>VALVES ACTUATED</u>	<u>NO. & TYPE ACTUATION</u>	<u>PLANT CONDITION</u>	<u>DESCRIPTION OF EVENT</u>
None				

2. Licensee generated changes to Offsite Dose Calculation Manual.

None

3. Indications of failed fuel.

None. Fuel Reliability Indicator: (FRI) = 3.47 E-06 μ Ci/cc.

4. Licensee Events Reports

The following is a tabular summary of all Licensee Event Reports for Byron Station, Unit One, issued during the reporting period, June 1, 2002, through June 30, 2002. This information is provided pursuant to the reportable occurrence reporting requirements as set forth in 10 CFR 50.73, "Licensee Event Report System."

<u>Licensee Event Report Number</u>	<u>Report Date</u>	<u>Title of Occurrence</u>
-------------------------------------	--------------------	----------------------------

None

OPERATING DATA REPORT
UNIT TWO

DOCKET NO.	50-455
UNIT NAME	Byron Two
DATE	07/15/02
COMPLETED BY	D. Drawbaugh
TELEPHONE	(815) 406-2813

REPORTING PERIOD: June, 2002
(Month/Year)

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
1. Design Electrical Rating (MWe-Net). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	1,155	N/A	N/A
2. Maximum Dependable Capacity (MWe-Net). The gross electrical output as measured at the output terminals of the turbine-generator during the most restrictive seasonal conditions minus the normal station service loads.	1,131	N/A	N/A
3. Number of Hours the Reactor was Critical. The total number of hours during the gross hours of the reporting period that the reactor was critical.	593.20	4,216.20	117,299.58
4. Number of Hours the Generator was On Line (also called Service Hours). The total number of hours during the gross hours of the reporting period that the unit operated with breakers closed to the station bus. The sum of the hours the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	585.50	4,208.50	116,517.78
5. Unit Reserve Shutdown Hours. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0	0	0
6. Net Electrical Energy (MWH). The gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	673,367	4,985,569	120,979,562

UNIT SHUTDOWNS

DOCKET NO. 50-455
 UNIT NAME Byron Two
 DATE 07/15/02
 COMPLETED BY D. Drawbaugh
 TELEPHONE (815) 406-2813

REPORTING PERIOD: June 2002

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
						COMMENTS
1	06/22/02	F	134.5	A	2	Steam Generator Tube Leak Repair

SUMMARY: Unit Two Off-Line for B2F23.

- (1) Reason
- A – Equipment Failure (Explain)
 - B – Maintenance Test
 - C – Refueling
 - D – Regulatory Restriction
 - E – Operator Training/License Examination
 - F – Administrative
 - G – Operational Error (Explain)
 - H – Other (Explain)

- (2) Method
- 1 – Manual
 - 2 – Manual Trip/Scram
 - 3 – Automatic Trip/Scram
 - 4 – Continuation
 - 5 – Other (Explain)

UNIQUE REPORTING REQUIREMENTS (UNIT TWO)
for the month of June, 2002

1. Safety/Relief valve operations for Unit Two. This information is provided pursuant to the reporting requirements contained in Technical Specification 5.6.4, "Monthly Operating Report."

<u>DATE</u>	<u>VALVES ACTUATED</u>	<u>NO. & TYPE ACTUATION</u>	<u>PLANT CONDITION</u>	<u>DESCRIPTION OF EVENT</u>
None				

2. Licensee generated changes to Offsite Dose Calculation Manual.

None

3. Indications of failed fuel.

None. Fuel Reliability Indicator: (FRI) = 1.83 E-06 μ Ci/cc.

4. Licensee Events Reports

The following is a tabular summary of all Licensee Event Reports for Byron Station, Unit Two, issued during the reporting period, June 1, 2002, through June 30, 2002. This information is provided pursuant to the reportable occurrence reporting requirements as set forth in 10 CFR 50.73, "Licensee Event Report System."

<u>Licensee Event Report Number</u>	<u>Report Date</u>	<u>Title of Occurrence</u>
-------------------------------------	--------------------	----------------------------

None