

Exelon Generation
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450-9765
Tel 815-942-2920

www.exeloncorp.com

July 15, 2002

RHLTR: #02-0050

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001


Dresden Nuclear Power Station, Units 2 and 3
Facility Operating License Nos. DPR-19 and DPR-25
Docket Nos. 50-237 and 50-249

Subject: Monthly Operating Report for June 2002

In accordance with Technical Specifications, Section 5.6.4, "Monthly Operating Reports," we are submitting the June 2002 Monthly Operating Report for Dresden Nuclear Power Station (DNPS), Units 2 and 3.

Should you have any questions concerning this letter, please contact Mr. Bob Rybak, Regulatory Assurance Manager, at (815) 416 - 2800.

Respectfully,



R. J. Hovey
Site Vice President
Dresden Nuclear Power Station

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector - Dresden Nuclear Power Station

IE24

ATTACHMENT

DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3

MONTHLY OPERATING REPORT

FOR JUNE 2002

EXELON GENERATION COMPANY, LLC

FACILITY OPERATING LICENSE NOS. DPR-19 AND DPR-25

NRC DOCKET NOS. 50-237 AND 50-249

TABLE OF CONTENTS

I. Summary of Operating Experience

- A. Unit 2 Monthly Operating Experience Summary
- B. Unit 3 Monthly Operating Experience Summary

II. Operating Data Statistics

- A. Operating Data Report - Dresden Unit 2
- B. Operating Data Report - Dresden Unit 3

III Unit Shutdowns

- A. Unit 2 Shutdowns
- B. Unit 3 Shutdowns

IV. Challenges to Safety and Relief Valves

I. SUMMARY OF OPERATING EXPERIENCE FOR JUNE 2002

A. UNIT 2 MONTHLY OPERATING EXPERIENCE SUMMARY

Unit 2 operated throughout the period at full power except for short periods for routine maintenance and surveillances.

B. UNIT 3 MONTHLY OPERATING EXPERIENCE SUMMARY

Unit 3 operated throughout the period at full power except for short periods for routine maintenance, surveillances or lack of load demand.

II. OPERATING DATA STATISTICS

A. Dresden Unit 2 Operating Data Report for June 2002

DOCKET NO. 050-237
DATE July 02, 2002
COMPLETED BY Don Hamilton
TELEPHONE (815) 416-3585

OPERATING STATUS

1. REPORTING PERIOD: June 2002
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth): 2,957
MAXIMUM DEPENDABLE CAPACITY (MWe NET): 850 (estimated)
DESIGN ELECTRICAL RATING (MWe Net): 867

Unit Two Monthly Operating Status			
	This Month	Year to Date	Cumulative
3. Reactor Critical - Hours	720	4,343	211,981
4. Hours Generator On-Line	720	4,343	203,492
5. Unit Reserve Shutdown - Hours	0	0	4
6. Net Electrical Energy Generated - MWHe	622,451	3,738,607	134,221,288

II. OPERATING DATA STATISTICS

B. Dresden Unit 3 Operating Data Report for June 2002

DOCKET NO. 050-249
DATE July 02, 2002
COMPLETED BY Don Hamilton
TELEPHONE (815) 416-3585

OPERATING STATUS

1. REPORTING PERIOD: June 2002
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth): 2,527
MAXIMUM DEPENDABLE CAPACITY (MWe Net): 773
DESIGN ELECTRICAL RATING (MWe Net): 795

Unit Three Monthly Operating Status			
	This Month	Year to Date	Cumulative
5. Reactor Critical - Hours	720	4,165	199,183
6. Hours Generator On-Line	720	4,146	191,307
9. Unit Reserve Shutdown – Hours	0	0	1
10. Net Electrical Energy Generated – MWHe	554,497	3,241,772	126,544,307

III. UNIT SHUTDOWNS

A. Unit 2 Shutdowns for June 2002

NO	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN REACTOR(3)	CORRECTIVE ACTIONS/ COMMENTS
None						

B. Unit 3 Shutdowns for June 2002

NO	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN REACTOR(3)	CORRECTIVE ACTIONS/ COMMENTS
None						

LEGEND:

(1) Type:

F - Forced
S - Scheduled

(2) Reason

A. Equipment Failure (Explain)
B. Maintenance or Test
C. Refueling
D. Regulatory Restriction
E. Operator Training & Licensing Exam
F. Administrative
G. Operational Error
H. Other (Explain)

(3) Method

1. Manual
2. Manual Scram
3. Automatic Scram
4. Other (Explain)
5. Load Reduction

IV. Challenges to Safety and Relief Valves

Unit 2 None
Unit 3 None