

# Post-examination Comments

(Green Paper)

1. Licensee Submitted Post-examination Comments

**NORTH ANNA  
EXAM 2002-301**

**50-338 AND 50-339  
JUNE 6, 10-14, & 24-25, 2002**

David A. Heacock  
Site Vice President



**Dominion Generation**  
North Anna Power Station  
P.O. Box 402, Mineral, VA 23117  
Phone: 540-894-2101, Fax: 540-894-2878  
David.Heacock@dom.com

June 20, 2002

Mr. Michael Ernstes  
Operator Licensing and Human Performance Branch  
United States Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303

Serial No. 02-404  
NAPS/GSS  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7

Dear Mr. Ernstes:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**NORTH ANNA POWER STATION UNITS 1 AND 2**  
**OPERATOR LICENSE EXAMINATION COMMENTS**

The following comments are provided in regards to the operator license examination that was conducted at North Anna Power Station on June 7, 2002.

**Question #72** (SRO examinations): Distractor "D" was inadvertently labeled as the correct answer. This typographical error was noted during the post exam review by the proctor. The correct answer should be "A", (97%).

**Question #89** (SRO examinations): Distractor "D" was inadvertently labeled as the correct answer. This typographical error was noted during the post exam review by the proctor. The correct answer should be "C" (to prevent damaging the PRZR heaters).

**Question #15** (RO and SRO examinations): This question did not state a length of time for the event (long term or short term). In the short term, "D" would be the correct answer. As the PRT pressure rises towards 100 psi, the temperature also rises. This remains true until the PRT rupture disc relieves, then the pressure will decrease and stabilize. This makes answer "C" correct. Our recommendation is for the NRC to accept both "C" and "D" as the correct answer. There are no further utility official comments on the examination.

If you have any questions, please contact Mr. H. A. Royal at (540) 894-2446.

Very truly yours,

Mr. David A. Heacock  
Site Vice President

JUN 26 2002  
JUN 27 2002

cc:

Mr. Ronald F. Aiello, License Examiner  
U. S. Nuclear Regulatory Commission  
Region II  
Operator Licensing and Human Performance Branch  
Sam Nunn Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 29555

Mr. M. J. Morgan  
NRC Senior Resident Inspector  
North Anna Power Station