



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

November 6, 1986

Docket No. 50-397

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
P.O. Box 968
3000 George Washington Way
Richland, Washington 99352

Dear Mr. Sorensen:

Subject: Issuance of Amendment No. 31 to Facility Operating
License No. NPF-21 - WPPSS Nuclear Project No. 2

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 31 to Facility Operating License No. NPF-21 to the Washington Public Power Supply System for WPPSS Nuclear Project No. 2, located in Benton County near Richland, Washington. This amendment is in response to your letters dated October 28, 1985, and February 24, 1986.

This amendment revises Section 3.6.3 (Primary Containment Isolation Valves) and 3.6.5.2 (Secondary Containment Automatic Isolation Valves) of the WNP-2 Technical Specifications. The amendment allows reactor mode changes with primary or secondary containment isolation valves inoperable provided they are closed and secured.

A copy of the related safety evaluation supporting Amendment No. 31 to Facility Operating License No. NPF-21 is enclosed.

Sincerely,

Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosures:

1. Amendment No. 31 to Facility
Operating License No. NPF-21
2. Safety Evaluation

cc w/enclosures:
See next page

DESIGNATED ORIGINAL

Certified By

8611180184 861106
PDR ADOCK 05000397
P PDR

Mr. G. C. Sorensen, Manager
Washington Public Power Supply System

WPPSS Nuclear Project No. 2
(WNP-2)

cc:
Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N.W.
Washington, D.C. 20036

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Mr. G. E. Doupe, Esquire
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99532

Mr. Curtis Eschels, Chairman
Energy Facility Site Evaluation Council
Mail Stop PY-11
Olympia, Washington 98504

P. L. Powell, Licensing Manager
Washington Public Power Supply System
P. O. Box 968, MD 956B
Richland, Washington 99352

Mr. W. G. Conn
Burns and Roe, Incorporated
c/o Washington Public Power Supply
System
P. O. Box 968, MD 994E
Richland, Washington 99352

R. B. Glasscock, Director
Licensing and Assurance
Washington Public Power Supply System
P. O. Box 968, MD 280
Richland, Washington 99352

Mr. C. M. Powers
WNP-2 Plant Manager
Washington Public Power Supply System
P. O. Box MD 927M
Richland, Washington 99352



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. 50-397

WPPSS NUCLEAR PROJECT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 31
License No. NPF-21

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The applications for amendment filed by the Washington Public Power Supply System (the Supply System, also the licensee), dated October 28, 1985, and February 24, 1986, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment; and paragraph 2.C.(2) of the Facility Operating License No. NPF-21 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 31, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8611180190 861106
PDR ADOCK 05000397
P PDR

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: November 6, 1986

ENCLOSURE TO LICENSE AMENDMENT NO. 31

FACILITY OPERATING LICENSE NO. NPF-21

DOCKET NO. 50-397

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 6-19
3/4 6-39

INSERT

3/4 6-19
3/4 6-39

CONTAINMENT SYSTEMS

3/4.6.3 PRIMARY CONTAINMENT ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.3 The primary containment isolation valves and the reactor instrumentation line excess flow check valves shown in Table 3.6.3-1 shall be OPERABLE with isolation times less than or equal to those shown in Table 3.6.3-1.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

- a. With one or more of the primary containment isolation valves shown in Table 3.6.3-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and within 4 hours either:
 1. Restore the inoperable valve(s) to OPERABLE status, or
 2. Isolate each affected penetration by use of at least one deactivated automatic valve secured in the isolated position,* or
 3. Isolate each affected penetration by use of at least one closed manual valve or blind flange*, and
 4. The provisions of Specification 3.0.4 are not applicable provided that the affected penetration is isolated in accordance with ACTION a.2. or a.3. above, and provided that the associated system, if applicable, is declared inoperable and the appropriate ACTION statements for that system are performed.

Otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

- b. With one or more of the reactor instrumentation line excess flow check valves shown in Table 3.6.3-1 inoperable, operation may continue and the provisions of Specifications 3.0.3 and 3.0.4 are not applicable provided that within 4 hours either:
 1. The inoperable valve is returned to OPERABLE status, or
 2. The instrument line is isolated and the associated instrument is declared inoperable.

Otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

*Isolation valves closed to satisfy these requirements may be reopened on an intermittent basis under administrative control.

CONTAINMENT SYSTEMS

SECONDARY CONTAINMENT AUTOMATIC ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.5.2 The secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2-1 shall be OPERABLE with isolation times less than or equal to the times shown in Table 3.6.5.2-1.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, 3 and *.

ACTION:

With one or more of the secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and within 8 hours either:

- a. Restore the inoperable valves to OPERABLE status, or
- b. Isolate each affected penetration by use of at least one deactivated valve secured in the isolation position, or
- c. Isolate each affected penetration by use of at least one closed manual valve or blind flange, and
- d. The provisions of Specification 3.0.4 are not applicable provided that the affected penetration is isolated in accordance with ACTION b. or c. above, and provided that the associated system, if applicable, is declared inoperable and the appropriate ACTION statements for that system are performed.

Otherwise, in OPERATIONAL CONDITION 1, 2, or 3, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

Otherwise, in OPERATIONAL CONDITION *, suspend handling of irradiated fuel in the secondary containment, CORE ALTERATIONS and operations with a potential for draining the reactor vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.5.2 Each secondary containment ventilation system automatic isolation valve shown in Table 3.6.5.2-1 shall be demonstrated OPERABLE:

- a. Prior to returning the valve to service after maintenance, repair, replacement work is performed on the valve or its associated actuator, control, or power circuit by cycling the valve through at least one complete cycle of full travel and verifying the specified isolation time.
- b. During COLD SHUTDOWN or REFUELING at least once per 18 months by verifying that on a containment isolation test signal each isolation valve actuates to its isolation position.
- c. By verifying the isolation time to be within its limit when tested pursuant to Specification 4.0.5

*When irradiated fuel is being handled in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 31 TO FACILITY OPERATING LICENSE NO. NPF-21

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

WPPSS NUCLEAR PROJECT NO. 2

DOCKET NO. 50-397

1.0 INTRODUCTION

By the letter dated October 28, 1985 the licensee requested a Technical Specification amendment to allow continued reactor operation with one of two containment isolation valves in series inoperable.

By letter dated February 24, 1986, and at the suggestion of the staff, the licensee requested a modification to the specification wording to conform to the wording of the standard Technical Specifications. The changes were not substantive and the amendment request was not renoticed.

2.0 EVALUATION

The intent of Sections 3/4.6.3 (Primary Containment Isolation Valves) and 3/4.6.5.2 (Secondary Containment Automatic Isolation Valves) of the Technical Specifications is to assure proper containment of radioactivity in the primary and secondary containments. This assurance is obtained by requiring that all lines penetrating the containments be isolated in the event of an accident. This change to the Technical Specifications allows continued reactor operation (i.e. allows reactor mode changes) with inoperable automatic or manual isolation valves, provided that the inoperable valves are secured in the closed position. Since the design function of the containments, to contain radioactivity, is maintained if inoperable isolation valves are closed, plant safety is not degraded and the changes are thus acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation and use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that this amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (51 FR 1882) on January 15, 1986, and consulted with the state of Washington. No public comments were received, and the state of Washington did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Frank J. Witt, NRR

Dated: November 6, 1986

AMENDMENT NO. 31 TO FACILITY OPERATING LICENSE NO. NPF-21
WPPSS NUCLEAR PROJECT NO. 2

DISTRIBUTION:

Docket No. 50-397

NRC PDR

Local PDR

PRC System

NSIC

BWD-3 r/f

JBradfute (2)

EHylton (1)

EAdensam

Attorney, OELD

CMiles

RDiggs

JPartlow

EJordan

BGrimes

LHarmon

TBarnhart (4)

EButcher