



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 23, 1986

Docket No. 50-397

Mr. G. C. Sorensen, Manager  
Regulatory Programs  
Washington Public Power Supply System  
P.O. Box 968  
3000 George Washington Way  
Richland, Washington 99352

Dear Mr. Sorensen:

Subject: Issuance of Amendment No. 25 to Facility Operating  
License No. NPF-21 - WPPSS Nuclear Project No. 2

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 25 to Facility Operating License No. NPF-21 to the Washington Public Power Supply System for WPPSS Nuclear Project No. 2, located in Benton County near Richland, Washington. This amendment is in response to your letter dated March 28, 1986, as clarified by your letters dated May 7 and 8, 1986.

This amendment revises a license condition of the WNP-2 Operating License NPF-21. Attachment 2, Paragraph 3.(a) of License Condition 2.C.(16) now requires that the licensee shall implement (install or upgrade) requirements of Regulatory Guide 1.97, Rev. 2, with the exception only of flux monitoring, prior to startup following the first refueling outage. This amendment permits implementation of this Regulatory Guide requirement to be delayed for the Suppression Pool Level Monitoring System also.

A copy of the related safety evaluation supporting Amendment No. 25 to Facility Operating License No. NPF-21 is enclosed.

Sincerely,


Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
Division of BWR Licensing

Enclosures:

1. Amendment No. 25 to Facility  
Operating License No. NPF-21
2. Safety Evaluation

cc w/enclosures:  
See next page

DESIGNATED ORIGINAL

Certified By 

8605300331 860523  
PDR ADOCK 05000397  
P PDR

Mr. G. C. Sorensen, Manager  
Washington Public Power Supply System

WPPSS Nuclear Project No. 2  
(WNP-2)

CC:

Nicholas S. Reynolds, Esq.  
Bishop, Liberman, Cook,  
Purcell & Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D.C. 20036

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. G. E. Doupe, Esquire  
Washington Public Power Supply System  
P. O. Box 968  
3000 George Washington Way  
Richland, Washington 99532

Mr. Curtis Eschels, Chairman  
Energy Facility Site Evaluation Council  
Mail Stop PY-11  
Olympia, Washington 98504

P. L. Powell, Licensing Manager  
Washington Public Power Supply System  
P. O. Box 968, MD 956B  
Richland, Washington 99352

Mr. W. G. Conn  
Burns and Roe, Incorporated  
c/o Washington Public Power Supply  
System  
P. O. Box 968, MD 994E  
Richland, Washington 99352

R. B. Glasscock, Director  
Licensing and Assurance  
Washington Public Power Supply System  
P. O. Box 968, MD 280  
Richland, Washington 99352

Mr. C. M. Powers  
WNP-2 Plant Manager  
Washington Public Power Supply System  
P. O. Box MD 927M  
Richland, Washington 99352



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. 50-397

WPPSS NUCLEAR PROJECT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 25  
License No. NPF-21

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for amendment filed by the Washington Public Power Supply System (the Supply System, also the licensee), dated March 28, 1986, and clarified by letters dated May 7 and 8, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. NPF-21, Attachment 2, Paragraph 3. of License Condition 2.C.(16) is hereby amended to read as follows:

Attachment 2, Paragraph 3.


- (a) The licensee shall implement (installation or upgrade) requirements of Regulatory Guide 1.97, Revision 2 with the exception of items (b) and (c) below prior to startup following the first refueling outage.
- (b) The licensee shall implement (installation or upgrade) requirements of Regulatory Guide 1.97, Revision 2, for flux monitoring prior to startup following the second refueling outage.

8605300336 860523  
PDR ADOCK 05000397  
PDR

(c) The licensee shall implement (install and have operational) a wide range suppression pool level monitoring system which satisfies the Category 1 equipment specifications in accordance with Regulatory Guide 1.97, Revision 2, prior to startup following the second refueling outage.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
Division of BWR Licensing

Date of Issuance: May 23, 1986



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
SUPPORTING AMENDMENT NO. 25 TO FACILITY OPERATING LICENSE NO. NPF-21

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

WPPSS NUCLEAR PROJECT NO. 2

DOCKET NO. 50-397

1.0 INTRODUCTION

Attachment 2, Paragraph 3.(a) of License Condition 2.C.(16) of the WNP-2 Operating License NPF-21, now requires that the licensee shall implement (install or upgrade) requirements of Regulatory Guide 1.97, Rev. 2, with the exception of flux monitoring, prior to startup following the first refueling outage. By letter dated March 28, 1986, the Supply System requested that implementation of this Regulatory Guide requirement be delayed until the second refueling outage for two specific systems: Suppression Pool Level Monitoring and Post Accident Sampling System. On May 8, 1986, the Supply System withdrew its request to delay implementation of the Regulatory Guide requirements for the Post Accident Sampling System. This evaluation, therefore, relates only to the Suppression Pool Level Monitoring System.

Prior to initial plant startup, the licensee installed a suppression pool water level monitoring system (wide range) to satisfy the requirements of GDC 13 and 19 as discussed in Regulatory Guide (R.G.) 1.97, Revision 2. Suppression pool water level is considered to be a Type C Category 1 variable.

The level monitoring system was custom built for WNP-2 and was designed with the objective to function both in normal and postulated accident environments. Thus it was expected that the wide range level monitoring system would perform the required safety function for post-accident monitoring and thus was considered qualifiable. The WNP-2 operating license was conditioned (License Condition No. 2.C(16)) to require that the wide range level instrumentation undergo environmental qualification testing to verify its operability under the expected post-accident environmental conditions. It was further required that this verification program be completed prior to startup after the first refueling outage. Subsequently, the licensee initiated a test program to verify the design accuracy capability of the system. During the test phase, excessive instrument drift (beyond design specifications) was noted while conducting temperature cycling tests. Two separate tests were conducted to resolve the drift problem with the equipment. Both tests proved unsuccessful. The licensee has abandoned any further efforts to qualify the currently installed instrumentation. The licensee has provided information by letter dated March 28, 1986, and May 7, 1986, requesting a deferral (i.e., until second refueling outage) of License Condition No. 2.C(16), Attachment 2, Item 3(a) as related to this issue. The staff's evaluation of this information follows.

## 2.0 EVALUATION

The licensee is considering alternate designs that will employ qualified instruments to preclude the above described situation from reoccurring. The staff has been informed through discussions with the licensee that the level monitoring system presently being procured consists of a nitrogen bubbler system and signal conditioning instrumentation all of which has been identified as qualified instrumentation based on existing qualification data. Also, as an alternative to the bubbler system, the licensee is considering a resistance temperature detector (RTD) arrangement at various levels and a differential pressure transmitter using the RCIC suction line as a variable leg.

The licensee has stated that procurement of materials and installation of the new design cannot be accomplished within the present refueling outage schedule (restart scheduled for May 20, 1986). Given temporary relief from the requirement, the licensee proposes to utilize the currently installed wide range suppression pool level monitoring instrumentation until the second refueling outage (scheduled for spring of 1987). The licensee has verified that this additional time would support the required instrument procurement schedules (currently forecasted for January 1987) to obtain a fully qualified system. The installed wide range channels have accurately indicated suppression pool level since installation and are currently indicating within three (3) inches of one another and the narrow range instrumentation, which is qualified, at a suppression pool temperature of 70°F.

As discussed above, the temperature qualification testing performed by Wyle Laboratories resulted in channel inaccuracies that were outside the range of required design specifications. However, the test data have been reviewed by the licensee to substantiate and quantify the error as a result of temperature increases. The Wyle Laboratories data were obtained at 20°F intervals over a range of 70° to 270°F (worst-case temperature expected for suppression pool level instrumentation). The results indicate a 2% drift of full range per 20°F temperature increase. The licensee has committed to incorporate a curve into the emergency procedures to account for the error that would be expected due to temperature increases from 70°F (normal operating conditions). This curve shall be implemented prior to startup from the first refueling which is currently underway. This implementation will require verification by the WNP-2 Resident Inspector prior to plant startup.

Based on the above evaluation, the staff accepts the licensee's proposal to utilize the currently existing wide range suppression pool level monitoring system for continued interim operations. This acceptance is based on first

cycle operational performance of the currently installed wide range level indicating channels, conservative application of the test data, addition of correction curve to emergency procedures (to be verified by the Resident Inspector), and the licensee's commitment to install a fully qualified wide range level indicating system at the second refueling outage.

### 3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation and use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that this amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

### 4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (51 FR 15418) on April 23, 1986, and consulted with the state of Washington. No public comments were received, and the state of Washington did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Robert W. Steven, NRR

Dated: May 23, 1986

AMENDMENT NO. 25 TO FACILITY OPERATING LICENSE NO. NPF-21  
WPPSS NUCLEAR PROJECT NO. 2

DISTRIBUTION:

Docket No. 50-397  
NRC PDR  
Local PDR  
PRC System  
NSIC  
BWD-3 r/f  
JBradfute (2)  
EHylton (1)  
EAdensam  
Attorney, OELD  
CMiles  
RDiggs  
JPartlow  
EJordan  
BGrimes  
LHarmon  
TBarnhart (4)