

# **PALO VERDE NUCLEAR GENERATING STATION**

## **UNIT 2 INSERVICE INSPECTION REPORT**

### **TENTH REFUELING OUTAGE**

**ARIZONA PUBLIC SERVICE  
5801 S. WINTERSBURG ROAD  
TONOPAH, AZ 85354**

PREPARED BY: *J. B. Lee*

DATE: 7/10/02

REVIEWED BY: *Wally O'Neil*

DATE: 7-11-02

APPROVED BY: *Michael Melton*

DATE: 7-11-02

COMMERCIAL SERVICE DATE: 09/19/86

REPORT DATE: 07/10/02

**ENCLOSURE 1**

**SECOND 10-YEAR ISI INTERVAL**

**SUMMARY REPORT**

**TENTH REFUELING OUTAGE**

**PALO VERDE NUCLEAR GENERATING STATION**

**UNIT 2**

**TABLE OF CONTENTS**

<u>SECTION</u>	<u>PAGE</u>
1. INTRODUCTION.....	1
2. EXAMINATION SUMMARY.....	1
3. EXAMINATION TECHNIQUES .....	2
4. ACCESSIBILITY .....	2
5. PERSONNEL.....	2
6. EQUIPMENT AND MATERIALS .....	2
7. REPAIRS AND REPLACEMENTS .....	3

**APPENDICES**

APPENDIX

- APPENDIX A - Inservice Inspection Summary Report
- APPENDIX B - Inservice Inspection Code Limitations
- APPENDIX C - Form NIS-1
- APPENDIX D - Forms NIS-2

# UNIT 2 INSERVICE INSPECTION REPORT

## 1. Introduction

This report is a summary of the Inservice Inspection (ISI) examinations performed during the tenth refueling outage at the Palo Verde Nuclear Generating Station (PVNGS) Unit 2. This report also includes all applicable examinations conducted since the last refueling outage. Selected examinations are being applied towards Period 1, with no credit taken for Period 2. This was the first refueling for Interval 2, Period 2, which was conducted from March 16, 2002 through April 17, 2002. Palo Verde Unit 2 began commercial operation on September 19, 1986.

This report identifies the components examined, the examination methods used, the examination report numbers, and summarizes the examination results for each of the following categories:

1. ASME Section XI, Class 1 and 2 pressure retaining components and their supports.
2. Augmented High Energy Piping systems in accordance with PVNGS UFSAR Section 6.6.8.

This report is a summary of the ISI examinations performed during the Second Interval Second Period. All of the examination report numbers listed in Appendix "A" are for the tenth refueling and examinations performed since the last Summary Report. The examinations performed during the first period of the second interval were submitted by letter 102-04525-CDC/AKK/RKB, dated February 1, 2001.

## 2. Examination Summary

The evaluation of the results from the ISI examinations indicated the integrity of the systems have been maintained. All discrepancies were corrected or determined "use-as-is" in accordance with PVNGS work control practices and ASME Section XI.

Visual examination of CH149H004 (ASME Class 2 Item F1.20 & F1.40, Zone 105) identified that the strut paddle ends were bent. The damaged portion of the strut was replaced and is listed in Section 7 for repairs and replacements. The probable cause was water hammer. A stress analysis was performed under CRDR 2507107 and determined that sufficient margins exist in the system and support designs to handle these increases. Therefore, the piping system was not compromised.

The Pressurizer skirt weld had rejectable indications within the weld. These indications were previously found and evaluated in 1993 and were determined satisfactory to "use as is" per MNCR 93-RC-2027. There has been essentially no change in the size or shape of the indications, characterized as sub-surface linear indications. As a requirement of IWB-3132.4 / IWB-2420 (b) and (c), this item has been reexamined every period for three successive inspections periods with essentially no change in the identified conditions. Period two of the second interval is the third successive examination and allows reverting to the original schedule of successive inspections.

Boric acid residue was detected on the tubing connected to the reactor vessel in-core instrument nozzles. The condition was investigated under CRAI 2334858 and determined to be the result of a prior packing leak and leakage from the ICI seal table. No indications of leakage of the tubes, nozzles, or reactor vessel were detected.

Various non-rejectable indications were detected during the performance of examinations. These indications were recorded and are maintained on file.

### 3. Examination Techniques

The three types of examinations utilized to perform the Inservice Examinations, along with the actual nondestructive examination techniques, are identified in the legend below:

Visual - VT	VT-1	General Condition
	VT-2	Leakage
	VT-3	Structural Condition
Surface	PT	Liquid Penetrant
	MT	Magnetic Particle
Volumetric	UT	Ultrasonic
	RT	Radiography

All of the nondestructive examinations were performed using specific techniques and procedures that are indicated in ASME Section XI, or alternative examinations that are demonstrated to be equivalent or superior to those identified.

### 4. Accessibility

All items were examined to the extent practical. Code limitations encountered during the examination that exceed the criteria of code case N490 are documented in Appendix B.

### 5. Personnel

All nondestructive examinations were performed by Arizona Public Service Co. (APS), Lambert, MacGill, Thomas, Inc. (LMT), or MQS. All personnel were certified in accordance with programs written to comply with the applicable requirements of ASME Section XI. Copies of all certifications are maintained on file. Hartford Steam Boiler Inspection and Insurance Company of Connecticut provided the Authorized Nuclear Inservice Inspector (ANII).

### 6. Equipment and Materials

The equipment and materials utilized were certified to the requirements of ASME Section XI. Copies of all certifications are maintained on file.

## 7. Repairs and Replacements

One replacement and no repairs were performed, as a result of ISI examinations performed during U2R10. The replacement is as follows and is further addressed in the Section 2 Summary:

<u>ZONE</u>	<u>WO / CRDR</u>	<u>ITEM SUMMARY #</u>	<u>DISCREPANCY</u>
105	2506194 / 2507107	2-105-CH-149-H004	Bent strut paddle ends replaced

The applicable records and reports for the specific maintenance repair or replacements performed after the last summary report are maintained on file at Palo Verde. The applicable NIS-2 forms are an attachment to Appendix D and are submitted for review with this report.

**APPENDIX A**

**INSERVICE INSPECTION  
SUMMARY REPORT**

## Appendix A

### Report Layout

The Appendix A column headings for the tables on the following pages are defined below:

<b>CLASS:</b>	ASME Section XI Subsection IWB for Class 1 and IWC for Class 2.
<b>CATEGORY:</b>	ASME Section XI Category Numbers are listed in Table IWB-2500-1 for Class 1 and Table IWC-2500-1 for Class 2. N/A indicates that a category has not been assigned.
<b>ITEM:</b>	The ASME Section XI Item Numbers are listed in Table IWB-2500-1 for Class 1 and Table IWC-2500-1 for Class 2. Items that start with AHE are associated with Augmented High Energy piping systems. The RCP Flywheels are marked as N/A in ASME and are identified as N/A (RCP FLYWHEEL - R.G. 1.14) in Appendix A.
<b>Required:</b>	The number of examinations scheduled in the ISI Program Summary Manual to be completed during the second period of the second interval. ( ) identifies augmented examinations for IEB 79-13 and SER 83-07.
<b>Complete:</b>	The number of examinations completed and credited during the first outage of the second period or since the last summary report. ( ) identifies augmented examinations for IEB 79-13 and SER 83-07.
<b>(continued):</b>	Indicates that the ASME Item is continued from a previous page.
<b>Summary No.:</b>	The first number identifies the unit. The second set of numbers identifies the zone. The third, and in some cases fourth set of numbers, identify the item examined as referenced in the ISI Program zone drawings.
<b>Component ID:</b>	Item examined as referenced in the ISI Program zone drawings.
<b>Component Description:</b>	Describes the item examined.
<b>System:</b>	Identifies the system designation the component is a part of.
<b>System Description:</b>	Describes the system or portion of the system that contains component examined.
<b>Workscope:</b>	Identifies the basis for the examination. ISI indicates a scheduled exam required by the ISI Program. AUG indicates Augmented High Energy or special exams to satisfy other commitments or concerns. PSE indicates an exam required as part of a repair, replacement, or modification.
<b>Report No.:</b>	The two letters designate the method, the next two numbers designate the unit number, and the next set of numbers identifies the sequential number of the report.
<b>Work Request No.:</b>	Identifies associated work document numbers
<b>Examination Remarks:</b>	Provides additional information applicable to the specific examination report. Re-exam or replacement remarks indicate acceptable examination results.



## Appendix A

### Definition of Terms

Aux:	Auxiliary
AF:	Auxiliary Feedwater
CEDM:	Control Element Drive Mechanism
CH:	Chemical and Volume Control
Cir:	Circumferential
Col	Column
Cont:	Containment
CS:	Containment Spray
Dwncmr:	Downcomer
FW:	Feedwater
HPSI:	High Pressure Safety Injection
ICI:	In Core Instrumentation
IEB:	Inspection and Enforcement Bulletin
ISI:	Inservice Inspection
LPSI:	Low Pressure Safety Injection
MT:	Magnetic Particle Test
PSE:	Preservice Examination
PSV:	Pressurizer Safety Valve
PZR:	Pressurizer
RC:	Reactor Coolant
RCP:	Reactor Coolant Pump
RCS:	Reactor Coolant System
RV:	Reactor Vessel
Sch:	Schedule of pipe
SG:	Steam Generator
SI:	Safety Injection
UT:	Ultrasonic Testing

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 1</b>	<b>CATEGORY: B-A</b>	<b>ITEM: B1.40</b>	<b>Required: 33%</b>	<b>Complete: 0%</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-002-001	2-1	Reactor Vessel Head-to-Flange Weld	RC	Closure Head
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-076	Examined 120° to 240° (15' to 32')		

<b>CLASS: 1</b>	<b>CATEGORY: B-B</b>	<b>ITEM: B2.11</b>	<b>Required: 66%</b>	<b>Complete: 66%</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-008	5-8	Shell to Top Head	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-025	Examined 0° to 240° (0' to 19' 5")		

<b>CLASS: 1</b>	<b>CATEGORY: BB</b>	<b>ITEM: B2.12</b>	<b>Required: 100%*</b>	<b>Complete: 100%*</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-006	5-6	PZR Upper Shell Long Seam	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-030	*1' of long seam		
ISI	UT-02-032	*1' of long seam		
ISI	UT-02-035	*1' of long seam		
ISI	UT-02-038	*1' of long seam		

<b>CLASS: 1</b>	<b>CATEGORY: BD</b>	<b>ITEM: B3.110</b>	<b>Required: 2</b>	<b>Complete: 2</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-010	5-10	Nozzle to Vessel Weld	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-027	Limited UT examinations, see Appendix B		
ISI	UT-02-033			
ISI	UT-02-036			
ISI	UT-02-039			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-013	5-13	Nozzle to Vessel Weld	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-031	Limited UT examinations, see Appendix B		
ISI	UT-02-034			
ISI	UT-02-037			
ISI	UT-02-040			

<b>CLASS: 1</b>	<b>CATEGORY: BD</b>	<b>ITEM: B3.120</b>	<b>Required: 2</b>	<b>Complete: 2</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-010	5-10	Nozzle Inner Radius	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-067	Inner radius		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-013	5-13	Nozzle Inner Radius	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-066	Inner radius		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 1</b>	<b>CATEGORY: BE</b>	<b>ITEM: B4.12</b>	<b>Required: 8</b>	<b>Complete: 8</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-002-CEDM-Nozzles	2-CEDM-Nozzles	CEDM Nozzles	RC	Closure Head
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-412	All nozzles examined, credit for 8		
<b>CLASS: 1</b>	<b>CATEGORY: BE</b>	<b>ITEM: B4.13</b>	<b>Required: 5</b>	<b>Complete: 5</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-001-ICI	2-1-INST. Nozzles	ICI Nozzle Partial Penetration Welds	RC	Reactor Vessel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-410	Reject - Acceptable per CRAI 2334858, no change. All nozzles examined, credit for 5		
<b>CLASS: 1</b>	<b>CATEGORY: BE</b>	<b>ITEM: B4.20</b>	<b>Required: 12</b>	<b>Complete: 12</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-HEATERS	2-5-PZR-Heaters	Pressurizer Heaters	RC	Pressurizer
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-413	Includes supplemental examination of all heaters (CE Info Bulletin 89-06)		
<b>CLASS: 1</b>	<b>CATEGORY: BF</b>	<b>ITEM: B5.40</b>	<b>Required: 2</b>	<b>Complete: 2</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-029-005-033	5-33	Safe End to PZR Nozzle	RC	Combined Pressurizer Spray
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-030			
ISI	RT-02-001			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-005-031	5-31	Safety Nozzle-to-Safe End Weld @ 270°	RC	Pressurizer Safeties
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-028			
ISI	UT-02-061	93% coverage acceptable per code case N-490		
ISI	UT-02-062			
ISI	UT-02-063			
ISI	UT-02-064	93% coverage acceptable per code case N-490		
<b>CLASS: 1</b>	<b>CATEGORY: B-G-1</b>	<b>ITEM: B6.10</b>	<b>Required: 18</b>	<b>Complete: 0</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-002-Nuts	Nuts	Reactor Vessel Closure Head Nuts	RC	Closure Head
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-156	Nuts 18-36, Nut # 18 credited to period 1		
<b>CLASS: 1</b>	<b>CATEGORY: B-G-1</b>	<b>ITEM: B6.30</b>	<b>Required: 18</b>	<b>Complete: 18</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-002-Studs	Studs	Reactor Vessel Closure Studs	RC	Closure Head
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-154	Studs 18-28, Stud # 18 credited to period 1		
ISI	MT-02-155	Studs 29-36		
ISI	UT-02-083	Studs 18-36, Stud # 18 credited to period 1		
<b>CLASS: 1</b>	<b>CATEGORY: B-G-1</b>	<b>ITEM: B6.180</b>	<b>Required: 20</b>	<b>Complete: 0</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-Flange Studs	Flange Studs	RCP 1A Flange Studs	RC	Reactor Coolant Pump 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	VT-02-357	16 Studs. Supplemental examination for IEIN 80-27 and IEB 82-02		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-1      ITEM: B6.180      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-Flange Studs	Flange Studs	RCP 1B Flange Studs	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	VT-02-361	16 Studs. Supplemental examination for IEIN 80-27 and IEB 82-02		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-Flange Studs	Flange Studs	RCP 2A Flange Studs	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	VT-02-364	16 Studs. Supplemental examination for IEIN 80-27 and IEB 82-02		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-019-Flange Studs	Flange Studs	RCP 2B Flange Studs	RC	Reactor Coolant Pump 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-022	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-023	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-024	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-025	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-026	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-027	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-028	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-029	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-030	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-031	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-032	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-033	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-034	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-035	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-036	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	MT-02-037	1 of 16 Studs. Supplemental examination for IEB 82-02		
AUG	VT-02-403	16 Studs. Supplemental examination for IEIN 80-27 and IEB 82-02		

**CLASS: 1      CATEGORY: B-G-1      ITEM: B6.190      Required: 100%      Complete: 100%**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-019-Flange	Flange	RCP 2B Flange Surface	RC	Reactor Coolant Pump 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-414			

**CLASS: 1      CATEGORY: B-G-1      ITEM: B6.200      Required: 20      Complete: 20**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-Clamping Ring	Clamping Ring	RCP 1A Clamping Ring	RC	Reactor Coolant Pump 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-359			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-Flange Nuts	Flange Nuts	RCP 1A Flange Nuts	RC	Reactor Coolant Pump 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-358	16 Nuts		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-Clamping Ring	Clamping Ring	RCP 1B Clamping Ring	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-363			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-1      ITEM: B6.200      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-Flange Nuts	Flange Nuts	RCP 1B Flange Nuts	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-360	16 Nuts		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-Clamping Ring	Clamping Ring	RCP 2A Clamping Ring	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-365			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-Flange Nuts	Flange Nuts	RCP 2A Flange Nuts	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-362	16 Nuts		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-019-Clamping Ring	Clamping Ring	RCP 2B Clamping Ring	RC	Reactor Coolant Pump 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-245			
ISI	VT-02-367			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-019-Flange Nuts	Flange Nuts	RCP 2B Flange Nuts	RC	Reactor Coolant Pump 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-366	16 Nuts		

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.20      Required: 20      Complete: 20**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-Nuts	Nuts	PZR Manway Nuts	RC	Pressurizer-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-282	20 Nuts, includes IEB supplemental examinations		
AUG	01-2051	VT 20 Nuts		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-Studs	Studs	PZR Manway Studs	RC	Pressurizer-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-148	20 Studs, IEB 82-02 supplemental examinations. 1 direction		
ISI	VT-02-262	20 Studs, includes IEB supplemental examinations		
AUG	01-2051	VT 20 Studs		

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.30      Required: 80      Complete: 80**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-003-CL-Nuts	CL Nuts	SG1 Cold Leg Manway Nuts	SG	SG 1-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-278	20 Nuts, includes IEB 82-02 supplemental examinations		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.30      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-003-CL-Studs	CL Studs	SG1 Cold Leg Manway Studs	RC	SG #1-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-149	20 Studs, IEB 82-02 supplemental examinations. 1 direction		
ISI	VT-02-263	20 Studs, includes IEB 82-02 supplemental examinations		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-003-HL-Nuts	HL Nuts	SG1 Hot Leg Manway Nuts	RC	SG #1-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-279	20 Nuts, includes IEB 82-02 supplemental examinations		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-003-HL-Studs	HL Studs	SG1 Hot Leg Manway Studs	RC	SG #1-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-150	20 Studs, IEB 82-02 supplemental examinations. 1 direction		
ISI	VT-02-266	20 Studs, includes IEB 82-02 supplemental examinations		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-004-CL-Nuts	CL Nuts	SG2 Cold Leg Manway Nuts	RC	SG #2-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-280	20 Nuts, includes IEB 82-02 supplemental examinations		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-004-CL-Studs	CL Studs	SG2 Cold Leg Manway Studs	RC	SG #2-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-151	20 Studs, IEB 82-02 supplemental examinations. 1 direction		
ISI	VT-02-264	20 Studs, includes IEB 82-02 supplemental examinations		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-004-HL-Nuts	HL Nuts	SG2 Hot Leg Manway Nuts	RC	SG #2-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-281	20 Nuts, includes IEB 82-02 supplemental examinations		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-004-HL-Studs	HL Studs	SG2 Hot Leg Manway Studs	RC	SG #2-Manway
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-152	20 Studs, IEB 82-02 supplemental examinations. 1 direction		
ISI	VT-02-265	20 Studs, includes IEB 82-02 supplemental examinations		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.50      Required: 1      Complete: 1**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-PSV200	PSV200	Flange Studs and Nuts	RC	Pressurizer Safeties

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-038	1 of 16 Nuts * Includes IEB 82-02 supplemental examination of all items
AUG	MT-02-039	1 of 16 Nuts
AUG	MT-02-040	1 of 16 Nuts
AUG	MT-02-041	1 of 16 Nuts
AUG	MT-02-042	1 of 16 Nuts
AUG	MT-02-043	1 of 16 Nuts
AUG	MT-02-044	1 of 16 Nuts
AUG	MT-02-045	1 of 16 Nuts
AUG	MT-02-046	1 of 16 Nuts
AUG	MT-02-047	1 of 16 Nuts
AUG	MT-02-048	1 of 16 Nuts
AUG	MT-02-049	1 of 16 Nuts
AUG	MT-02-050	1 of 16 Nuts
AUG	MT-02-051	1 of 16 Nuts
AUG	MT-02-052	1 of 16 Nuts
AUG	MT-02-053	1 of 16 Nuts
AUG	MT-02-054	1 of 8 Studs
AUG	MT-02-055	1 of 8 Studs
AUG	MT-02-056	1 of 8 Studs
AUG	MT-02-057	1 of 8 Studs
AUG	MT-02-058	1 of 8 Studs
AUG	MT-02-059	1 of 8 Studs
AUG	MT-02-060	1 of 8 Studs
AUG	MT-02-061	1 of 8 Studs
AUG	VT-02-108	1 of 16 Nuts
AUG	VT-02-109	1 of 16 Nuts
AUG	VT-02-110	1 of 16 Nuts
AUG	VT-02-111	1 of 16 Nuts
AUG	VT-02-112	1 of 16 Nuts
AUG	VT-02-113	1 of 16 Nuts
AUG	VT-02-114	1 of 16 Nuts
AUG	VT-02-115	1 of 16 Nuts
AUG	VT-02-116	1 of 16 Nuts
AUG	VT-02-117	1 of 16 Nuts
AUG	VT-02-118	1 of 16 Nuts
AUG	VT-02-119	1 of 16 Nuts
AUG	VT-02-120	1 of 16 Nuts
AUG	VT-02-121	1 of 16 Nuts
AUG	VT-02-122	1 of 16 Nuts
AUG	VT-02-123	1 of 16 Nuts
AUG	VT-02-124	1 of 8 Studs
AUG	VT-02-125	1 of 8 Studs
AUG	VT-02-126	1 of 8 Studs
AUG	VT-02-127	1 of 8 Studs
AUG	VT-02-128	1 of 8 Studs
AUG	VT-02-129	1 of 8 Studs
AUG	VT-02-130	1 of 8 Studs
AUG	VT-02-131	1 of 8 Studs

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.50      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-PSV201	PSV201	Flange Studs and Nuts	RC	Pressurizer Safeties

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-062	1 of 16 Nuts * Includes IEB 82-02 supplemental examination of all items
AUG	MT-02-063	1 of 16 Nuts
AUG	MT-02-064	1 of 16 Nuts
AUG	MT-02-065	1 of 16 Nuts
AUG	MT-02-066	1 of 16 Nuts
AUG	MT-02-067	1 of 16 Nuts
AUG	MT-02-068	1 of 16 Nuts
AUG	MT-02-069	1 of 16 Nuts
AUG	MT-02-070	1 of 16 Nuts
AUG	MT-02-071	1 of 16 Nuts
AUG	MT-02-072	1 of 16 Nuts
AUG	MT-02-073	1 of 16 Nuts
AUG	MT-02-074	1 of 16 Nuts
AUG	MT-02-075	1 of 16 Nuts
AUG	MT-02-076	1 of 16 Nuts
AUG	MT-02-077	1 of 16 Nuts
AUG	MT-02-078	1 of 8 Studs
AUG	MT-02-079	1 of 8 Studs
AUG	MT-02-080	1 of 8 Studs
AUG	MT-02-081	1 of 8 Studs
AUG	MT-02-082	1 of 8 Studs
AUG	MT-02-083	1 of 8 Studs
AUG	MT-02-084	1 of 8 Studs
AUG	MT-02-085	1 of 8 Studs
AUG	VT-02-132	1 of 16 Nuts
AUG	VT-02-133	1 of 16 Nuts
AUG	VT-02-134	1 of 16 Nuts
AUG	VT-02-135	1 of 16 Nuts
AUG	VT-02-136	1 of 16 Nuts
AUG	VT-02-137	1 of 16 Nuts
AUG	VT-02-138	1 of 16 Nuts
AUG	VT-02-139	1 of 16 Nuts
AUG	VT-02-140	1 of 16 Nuts
AUG	VT-02-141	1 of 16 Nuts
AUG	VT-02-142	1 of 16 Nuts
AUG	VT-02-143	1 of 16 Nuts
AUG	VT-02-144	1 of 16 Nuts
AUG	VT-02-145	1 of 16 Nuts
AUG	VT-02-146	1 of 16 Nuts
AUG	VT-02-147	1 of 16 Nuts
AUG	VT-02-148	1 of 8 Studs
AUG	VT-02-149	1 of 8 Studs
AUG	VT-02-150	1 of 8 Studs
AUG	VT-02-151	1 of 8 Studs
AUG	VT-02-152	1 of 8 Studs
AUG	VT-02-153	1 of 8 Studs
AUG	VT-02-154	1 of 8 Studs
AUG	VT-02-155	1 of 8 Studs



**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.50      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-PSV202	PSV202	Flange Studs and Nuts	RC	Pressurizer Safeties
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-086	1 of 16 Nuts * Includes IEB 82-02 supplemental examination of all items		
AUG	MT-02-087	1 of 16 Nuts		
AUG	MT-02-088	1 of 16 Nuts		
AUG	MT-02-089	1 of 16 Nuts		
AUG	MT-02-090	1 of 16 Nuts		
AUG	MT-02-091	1 of 16 Nuts		
AUG	MT-02-092	1 of 16 Nuts		
AUG	MT-02-093	1 of 16 Nuts		
AUG	MT-02-094	1 of 16 Nuts		
AUG	MT-02-095	1 of 16 Nuts		
AUG	MT-02-096	1 of 16 Nuts		
AUG	MT-02-097	1 of 16 Nuts		
AUG	MT-02-098	1 of 16 Nuts		
AUG	MT-02-099	1 of 16 Nuts		
AUG	MT-02-100	1 of 16 Nuts		
AUG	MT-02-101	1 of 16 Nuts		
AUG	MT-02-102	1 of 8 Studs		
AUG	MT-02-103	1 of 8 Studs		
AUG	MT-02-104	1 of 8 Studs		
AUG	MT-02-105	1 of 8 Studs		
AUG	MT-02-106	1 of 8 Studs		
AUG	MT-02-107	1 of 8 Studs		
AUG	MT-02-108	1 of 8 Studs		
AUG	MT-02-109	1 of 8 Studs		
ISI	VT-02-156	1 of 16 Nuts		
ISI	VT-02-157	1 of 16 Nuts		
ISI	VT-02-158	1 of 16 Nuts		
ISI	VT-02-159	1 of 16 Nuts		
ISI	VT-02-160	1 of 16 Nuts		
ISI	VT-02-161	1 of 16 Nuts		
ISI	VT-02-162	1 of 16 Nuts		
ISI	VT-02-163	1 of 16 Nuts		
ISI	VT-02-164	1 of 16 Nuts		
ISI	VT-02-165	1 of 16 Nuts		
ISI	VT-02-166	1 of 16 Nuts		
ISI	VT-02-167	1 of 16 Nuts		
ISI	VT-02-168	1 of 16 Nuts		
ISI	VT-02-169	1 of 16 Nuts		
ISI	VT-02-170	1 of 16 Nuts		
ISI	VT-02-171	1 of 16 Nuts		
ISI	VT-02-172	1 of 8 Studs		
ISI	VT-02-173	1 of 8 Studs		
ISI	VT-02-174	1 of 8 Studs		
ISI	VT-02-175	1 of 8 Studs		
ISI	VT-02-176	1 of 8 Studs		
ISI	VT-02-177	1 of 8 Studs		
ISI	VT-02-178	1 of 8 Studs		
ISI	VT-02-179	1 of 8 Studs		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.50      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-PSV203	PSV203	Flange Studs and Nuts	RC	Pressurizer Safeties

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-110	1 of 16 Nuts * Includes IEB 82-02 supplemental examination of all items
AUG	MT-02-111	1 of 16 Nuts
AUG	MT-02-112	1 of 16 Nuts
AUG	MT-02-113	1 of 16 Nuts
AUG	MT-02-114	1 of 16 Nuts
AUG	MT-02-115	1 of 16 Nuts
AUG	MT-02-116	1 of 16 Nuts
AUG	MT-02-117	1 of 16 Nuts
AUG	MT-02-118	1 of 16 Nuts
AUG	MT-02-119	1 of 16 Nuts
AUG	MT-02-120	1 of 16 Nuts
AUG	MT-02-121	1 of 16 Nuts
AUG	MT-02-122	1 of 16 Nuts
AUG	MT-02-123	1 of 16 Nuts
AUG	MT-02-124	1 of 16 Nuts
AUG	MT-02-125	1 of 16 Nuts
AUG	MT-02-126	1 of 8 Studs
AUG	MT-02-127	1 of 8 Studs
AUG	MT-02-128	1 of 8 Studs
AUG	MT-02-129	1 of 8 Studs
AUG	MT-02-130	1 of 8 Studs
AUG	MT-02-131	1 of 8 Studs
AUG	MT-02-132	1 of 8 Studs
AUG	MT-02-133	1 of 8 Studs
AUG	VT-02-180	1 of 16 Nuts
AUG	VT-02-181	1 of 16 Nuts
AUG	VT-02-182	1 of 16 Nuts
AUG	VT-02-183	1 of 16 Nuts
AUG	VT-02-184	1 of 16 Nuts
AUG	VT-02-185	1 of 16 Nuts
AUG	VT-02-186	1 of 16 Nuts
AUG	VT-02-187	1 of 16 Nuts
AUG	VT-02-188	1 of 16 Nuts
AUG	VT-02-189	1 of 16 Nuts
AUG	VT-02-190	1 of 16 Nuts
AUG	VT-02-191	1 of 16 Nuts
AUG	VT-02-192	1 of 16 Nuts
AUG	VT-02-193	1 of 16 Nuts
AUG	VT-02-194	1 of 16 Nuts
AUG	VT-02-195	1 of 16 Nuts
AUG	VT-02-196	1 of 8 Studs
AUG	VT-02-197	1 of 8 Studs
AUG	VT-02-198	1 of 8 Studs
AUG	VT-02-199	1 of 8 Studs
AUG	VT-02-200	1 of 8 Studs
AUG	VT-02-201	1 of 8 Studs
AUG	VT-02-202	1 of 8 Studs
AUG	VT-02-203	1 of 8 Studs

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.60      Required: 20      Complete: 5**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-Seal Housing Studs	Studs	RCP 1B Seal Cover Bolting	RC	Reactor Coolant Pump 1B

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-257	16 Studs only

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.60      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-Seal Housing Studs	Studs	RCP 2A Seal Cover Bolting	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-215	1 of 16 Studs only		
ISI	VT-02-216	1 of 16 Studs only		
ISI	VT-02-217	1 of 16 Studs only		
ISI	VT-02-218	1 of 16 Studs only		
ISI	VT-02-219	1 of 16 Studs only		
ISI	VT-02-220	1 of 16 Studs only		
ISI	VT-02-221	1 of 16 Studs only		
ISI	VT-02-222	1 of 16 Studs only		
ISI	VT-02-223	1 of 16 Studs only		
ISI	VT-02-224	1 of 16 Studs only		
ISI	VT-02-225	1 of 16 Studs only		
ISI	VT-02-226	1 of 16 Studs only		
ISI	VT-02-227	1 of 16 Studs only		
ISI	VT-02-228	1 of 16 Studs only		
ISI	VT-02-229	1 of 16 Studs only		
ISI	VT-02-230	1 of 16 Studs only		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-019-Seal Housing Studs	Studs	RCP 2B Seal Cover Bolting	RC	Reactor Coolant Pump 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-258	16 Studs and Nuts		
ISI	02-2001	VT 16 Studs		

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.70      Required: 18      Complete: 17**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-022-V652	UV-652	Valve Bolts, Studs, and Nuts	SI	Shutdown Cooling Loop 2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-058			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-023-V235	V-235	Valve Bolts, Studs, and Nuts	SI	SI 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-237			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-023-UV634	UV-634	Valve Bolts, Studs, and Nuts	SI	SI 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-236			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-024-V245	V-245	Valve Bolts, Studs, and Nuts	SI	SI 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-270			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.70      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-024-V644	UV644	Valve Bolts, Studs, and Nuts	SI	SI 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-242			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-025-V217	V-217	Valve Bolts, Studs, and Nuts	SI	SI 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-260			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-026-V541	V-541	Valve Bolts, Studs, and Nuts	SI	SI 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-320			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-026-V624	UV-624	Valve Bolts, Studs, and Nuts	SI	SI 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-321			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-027-V100E	PV-100E	Valve Bolts, Studs, and Nuts	RC	Pressurizer Spray 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-371			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-V100F	PV-100F	Valve Bolts, Studs, and Nuts	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-368			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-033-V235	V-235	Valve Bolts, Studs, and Nuts	RC	Drain Line 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-312			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-033-V335	V-335	Valve Bolts, Studs, and Nuts	RC	Drain Line 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-311			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-034-V233	V-233	Valve Bolts, Studs, and Nuts	RC	Drain Line 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-322			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-034-V333	V-333	Valve Bolts, Studs, and Nuts	RC	Drain Line 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-323			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-G-2      ITEM: B7.70      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-V522	V-522	Valve Bolts, Studs, and Nuts	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-314	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-V957	V-957	Valve Bolts, Studs, and Nuts	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-313	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-V532	V-532	Valve Bolts, Studs, and Nuts	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-324	

**CLASS: 1      CATEGORY: B-H      ITEM: B8.20      Required: 0\*      Complete: 0\***

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-005-001	5-1	Support Skirt	RC	Pressurizer

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-018	*Reexamine area at 19' to 26'.
ISI	UT-02-056	*Reexamine indications at 19' to 26'. Limited UT examinations see Appendix B
ISI	UT-02-057	*Reexamine indications at 19' to 26'. Reject – Acceptable per MNCR 93-RC-2027
ISI	UT-02-058	*Reexamine indications at 19' to 26'.
ISI	UT-02-059	*Reexamine indications at 19' to 26'.

**CLASS: 1      CATEGORY: B-J      ITEM: B9.11 & B9.12 Required: 23      Complete: 17**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-006-016-001	16-1	Outlet Nozzle to Extension Piece Weld	RC	RCS Primary Piping

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-019	No credit for surface exam on long seam
ISI	UT-02-120	Includes long seam

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-006-017-001	17-1	Outlet Nozzle to Extension Piece Weld	RC	RCS Primary Piping

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-020	No credit for surface exam on long seam
ISI	UT-02-116	Includes long seam

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-006-018-001	18-1	Outlet Nozzle to Extension Piece Weld	RC	RCS Primary Piping

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-007	Includes long seam
ISI	UT-02-121	Includes long seam

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-006-019-001	19-1	Outlet Nozzle to Extension Piece Weld	RC	RCS Primary Piping

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-021	No credit for surface exam on long seam
ISI	UT-02-079	Includes long seam

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

<b>CLASS: 1</b>		<b>CATEGORY: B-J</b>		<b>ITEM: B9.11 &amp; B9.12 (continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-021-014	21-14	16" Sch 160 Elbow-to-Pipe	RC	Shutdown Cooling Loop 1	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
ISI	PT-02-059				
ISI	UT-02-125				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-021-015	21-15	16" Sch 160 Pipe-to-Elbow	RC	Shutdown Cooling Loop 1	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
ISI	PT-02-060				
ISI	UT-02-126				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-022-001	22-1	16" Pipe to Pipe	RC	Shutdown Cooling Loop 2	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
ISI	PT-02-016				
ISI	UT-02-007				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-022-007-009	7-9	Nozzle-to-16" Sch Pipe	RC	Shutdown Cooling Loop 2	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
ISI	PT-02-017				
ISI	UT-02-010				
ISI	UT-02-011				
ISI	UT-02-026				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-022-017	22-17	16" Sch 160 Pipe-to-Elbow	SI	Shutdown Cooling Loop 2	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
ISI	PT-02-041				
ISI	UT-02-052				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-023-006	23-6	Pipe to Valve	SI	SI 1A	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
AUG	PT-02-064				
AUG	UT-02-090	Limited UT examinations, see Appendix B			
AUG	UT-02-091				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-024-006	24-6	Pipe to Valve	SI	SI 1B	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
AUG	PT-02-004				
AUG	UT-02-001	Limited UT examinations, see Appendix B			
AUG	UT-02-003				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>	
2-024-014	24-14	Valve to Pipe	SI	SI 1B	
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>			
ISI	PT-02-037				
ISI	UT-02-045	Limited UT examinations, see Appendix B			
ISI	UT-02-050				

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

<b>CLASS: 1</b>	<b>CATEGORY: B-J</b>	<b>ITEM: B9.11 &amp; B9.12 (continued)</b>		
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-024-016	24-16	Pipe to Valve	SI	SI 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-038			
ISI	UT-02-046	Limited UT examinations, see Appendix B		
ISI	UT-02-048			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-024-019	24-19	Valve to Pipe	SI	SI 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-034			
ISI	UT-02-047	Limited UT examinations, see Appendix B		
ISI	UT-02-051			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-025-001	25-1	14" Sch 160 Elbow-to-RC Loop 2A Safe End	SI	SI 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-058			
ISI	UT-02-109			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-025-004	25-4	Valve to Pipe	SI	SI 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-072			
ISI	UT-02-110	Limited UT examinations, see Appendix B		
ISI	UT-02-113			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-025-006	25-6	Pipe to Valve	SI	SI 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-052			
ISI	UT-02-111	Limited UT examinations, see Appendix B		
ISI	UT-02-114			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-025-013-010	13-10	SI Nozzle-to-Safe End Weld	SI	SI 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-112	No credit, surface exam required		
ISI	UT-02-119			
ISI	UT-02-122			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-026-006	26-6	Pipe to Valve	SI	SI 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	PT-02-003			
AUG	UT-02-002	Limited UT examinations, see Appendix B		
AUG	UT-02-004			

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-J      ITEM: B9.11 & B9.12 (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-026-017	26-17	Valve to Pipe	SI	SI 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-035			
ISI	UT-02-044	Limited UT examinations, see Appendix B		
ISI	UT-02-049			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-029-001	29-1	4" Sch 160 Pipe-to Pressurizer Nozzle	RC	Combined Pressurizer Spray
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-026			
ISI	UT-02-068	supplemental exam		
ISI	UT-02-124			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-009	31-9	Pressurizer Safe End to 6" Sch 160 Elbow	RC	Pressurizer Safeties
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-029			
ISI	UT-02-028			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-031-010	31-10	6" Sch 160 Elbow-to-Pipe	RC	Pressurizer Safeties
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-027			
ISI	UT-02-029			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-036-075	36-75	16" Sch 160 Circumferential Head Weld	RC	Letdown Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-070			
ISI	UT-02-106			
<b>CLASS: 1      CATEGORY: B-J      ITEM: B9.21      Required: 31      Complete: 29</b>				
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-027-008	27-8	Pipe to Valve	RC	Pressurizer Spray 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-007			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-027-010	27-10	Pipe to Elbow	RC	Pressurizer Spray 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-006			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-027-016	27-16	Valve to Elbow	RC	Pressurizer Spray 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-008			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-009	28-9	Pipe to Valve	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-009			



**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-J      ITEM: B9.21      (continued)**

Summary No. 2-028-011	<u>Component ID</u> 28-11	<u>Component Description</u> Valve to Pipe	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1B
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-010	<u>Examination Remarks</u>		
Summary No. 2-028-011-011	<u>Component ID</u> 11-11	<u>Component Description</u> Spray Nozzle-to-Safe End Weld	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1B
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-040	<u>Examination Remarks</u>		
Summary No. 2-028-020	<u>Component ID</u> 28-20	<u>Component Description</u> Valve to Pipe	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1B
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-011	<u>Examination Remarks</u>		
Summary No. 2-030-005	<u>Component ID</u> 30-5	<u>Component Description</u> 2" Sch 160 Pipe-to-TEE	<u>System</u> CH	<u>System Description</u> AUX. Pressurizer Spray
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-074	<u>Examination Remarks</u>		
Summary No. 2-030-006	<u>Component ID</u> 30-6	<u>Component Description</u> 2" Sch 160 Tee-to-Pipe	<u>System</u> CH	<u>System Description</u> AUX. Pressurizer Spray
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-073	<u>Examination Remarks</u>		
Summary No. 2-033-001	<u>Component ID</u> 33-1	<u>Component Description</u> Safe End to Pipe	<u>System</u> RC	<u>System Description</u> Drain Line 1B
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-048	<u>Examination Remarks</u>		
Summary No. 2-033-005	<u>Component ID</u> 33-5	<u>Component Description</u> Elbow-to-2" Sch160 Pipe	<u>System</u> RC	<u>System Description</u> Drain Line 1B
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-049	<u>Examination Remarks</u>		
Summary No. 2-033-010-018	<u>Component ID</u> 10-18	<u>Component Description</u> Drain Nozzle-to-Safe End Weld Extension Piece	<u>System</u> RC	<u>System Description</u> Drain Line 1B Weld
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-051	<u>Examination Remarks</u>		
Summary No. 2-036-025	<u>Component ID</u> 36-25	<u>Component Description</u> 2" Sch 160 Pipe-to-Elbow	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-065	<u>Examination Remarks</u>		
Summary No. 2-036-026	<u>Component ID</u> 36-26	<u>Component Description</u> 2" Sch 160 Elbow-to-Pipe	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> PT-02-066	<u>Examination Remarks</u>		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-J      ITEM: B9.21      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-036-043	36-43	Pipe to Elbow	RC	Letdown Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-067			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-036-044	36-44	2" Sch 160 Elbow-to-Pipe	RC	Letdown Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-068			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-036-045	36-45	2" Sch 160 Pipe-to-Elbow	RC	Letdown Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-069			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-036-080	36-80	2" Sch 160 Pipe-to-Elbow	RC	Letdown Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-071			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-029	37-29	3" Sch 160 Elbow-to-Pipe	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-053			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-030	37-30	3" Sch 160 Pipe-to-Elbow	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-054			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-032	37-32	3" Sch 160 Pipe-to-Concentric Reducer	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-055			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-033	37-33	2" Sch 160 Concentric Reducer-to-Pipe	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-056			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-034	37-34	2" Sch 160 Pipe-to-Safe End Loop 2A	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-057			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-038-001	38-1	Sweeplet-to-Pipe	RC	Drain Line Loop 1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-062			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: B-J      ITEM: B9.21      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-012	39-12	3" Sch 160 Pipe-to-Elbow	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	PT-02-013	
ISI	UT-02-022	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-013	39-13	3" Sch 160 Elbow-to-Pipe	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	PT-02-014	
ISI	UT-02-021	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-024	39-24	3" Sch 160 Pipe-to-Valve V-522	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	PT-02-019	
ISI	UT-02-015	Limited UT examinations, see Appendix B
ISI	UT-02-016	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-006	40-6	3" Sch 160 Elbow to Pipe	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	PT-02-012	
ISI	UT-02-019	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-007	40-7	Pipe to Elbow	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	PT-02-020	
ISI	UT-02-020	

**CLASS: 1      CATEGORY: B-J      ITEM: B9.31      Required: 1      Complete: 1**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-006-013-008	13-8	SI Nozzle-to-Pipe Weld	RC	RCS Primary Piping

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-006	
ISI	UT-02-118	
ISI	UT-02-123	

**CLASS: 1      CATEGORY: B-J      ITEM: B9.32      Required: 3      Complete: 1**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-006-013-009	13-9	Charging Nozzle-to-Pipe Weld	RC	RCS Primary Piping

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-157	

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 1</b>		<b>CATEGORY: B-J</b>		<b>ITEM: B9.40</b>		<b>Required: 2</b>		<b>Complete: 2</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-033-006	33-6	2" Sch 160 Pipe-to-Valve		RC	Drain Line 1B				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
ISI	PT-02-050								
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-034-006	34-6	2" Sch 160 Pipe-to-Valve		RC	Drain Line 2A				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
ISI	PT-02-061								
<b>CLASS: 1</b>		<b>CATEGORY: B-K-1</b>		<b>ITEM: B10.10</b>		<b>Required: 1</b>		<b>Complete: 1</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-036-RC-091-H6-S	RC-91-H6	Support		RC	Letdown Line				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
ISI	PT-02-005								
<b>CLASS: 1</b>		<b>CATEGORY: B-L-2</b>		<b>ITEM: B12.20</b>		<b>Required: 1</b>		<b>Complete: 1</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-019-RCP Bowl	Pump Case 2MRCEP01D	Pump Casing Internal Surfaces		RC	Reactor Coolant Pump 2B				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
ISI	VT-02-072								
<b>CLASS: 1</b>		<b>CATEGORY: B-O</b>		<b>ITEM: B14.10</b>		<b>Required: 4</b>		<b>Complete: 4</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-002-CEDM-9-78	CEDM-9-78	Upper Housing Weld		RC	Reactor Vessel Closure Head CEDM Housing				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
AUG	PT-02-078								
ISI	UT-02-086								
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-002-CEDM-9-88	CEDM-9-88	Upper Housing Weld		RC	Reactor Vessel Closure Head CEDM Housing				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
AUG	PT-02-080								
ISI	UT-02-087								
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-002-CEDM-10-78	CEDM-10-78	Tube Housing Lower Weld		RC	Reactor Vessel Closure Head CEDM Housing				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
AUG	PT-02-079								
ISI	UT-02-088								
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>				
2-002-CEDM-10-88	CEDM-10-88	Tube Housing Lower Weld		RC	Reactor Vessel Closure Head CEDM Housing				
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>							
AUG	PT-02-081								
ISI	UT-02-089								

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 1</b>	<b>CATEGORY: B-P</b>	<b>ITEM: B15.10, 20, 30, 40, 50, 60 70</b>	<b>Required: All</b>	<b>Complete: All</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-RCS Pres. Test	RCS Leakage Test	Piping and Components	Various	Pressure retaining piping and Components

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-409	
ISI	01-2001	Period 1 VT Examination

<b>CLASS: 1</b>	<b>CATEGORY: F-A</b>	<b>ITEM: F1.10</b>	<b>Required: 70</b>	<b>Complete: 64</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-RC-051-H004	RC-51-H4	Support	RC	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-038	Support Deleted

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-RC-051-H005	RC-51-H5	Support	RC	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-037	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-SI-240-H002	SI-240-H2	Support	SI	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-018	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-SI-240-H012	SI-240-H12	Support	SI	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-017	Support Deleted

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-SI-240-H822	SI-240-H822	Support	SI	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-016	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-SI-240-H823	SI-240-H823	Support	SI	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-039	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-021-SI-240-H824	SI-240-H824	Support	SI	Shutdown Cooling Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-040	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-022-SI-193-H008	SI-193-H8	Support	SI	Shutdown Cooling Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-012	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-022-SI-193-H009	SI-193-H9	Support	SI	Shutdown Cooling Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-014	

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.10      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-022-SI-193-H020	SI-193-H20	Support	SI	Shutdown Cooling Loop 2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-015			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-022-SI-193-H025	SI-193-H25	Support	SI	Shutdown Cooling Loop 2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-013	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-023-SI-207-H007	SI-207-H7	Support	SI	SI 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-243			
ISI	VT-02-244			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-023-SI-207-H011	SI-207-H11	Support	SI	SI 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-235			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-024-SI-223-H001	SI-223-H1	Support	SI	SI 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-241			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-024-SI-223-H002	SI-223-H2	Support	SI	SI 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-240	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-025-SI-160-H001	SI-160-H1	Support	SI	SI 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-238			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-026-SI-175-H021	SI-175-H21	Support	SI	SI 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-315			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-026-SI-175-H022	SI-175-H22	Support	SI	SI 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-317	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-027-RC-016-H005	RC-16-H5	Support	RC	Pressurizer Spray 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-344			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.10      (continued)**

Summary No. 2-027-RC-016-H006	<u>Component ID</u> RC-16-H6	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-345	<u>Examination Remarks</u>		
Summary No. 2-027-RC-016-H007	<u>Component ID</u> RC-16-H7	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-346	<u>Examination Remarks</u>		
Summary No. 2-027-RC-016-H015	<u>Component ID</u> RC-16-H15	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-347	<u>Examination Remarks</u> Support Deleted		
Summary No. 2-027-RC-062-H035	<u>Component ID</u> RC-62-H35	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-348	<u>Examination Remarks</u>		
Summary No. 2-027-RC-062-H036	<u>Component ID</u> RC-62-H36	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-349	<u>Examination Remarks</u> Support Deleted		
Summary No. 2-027-RC-062-H037	<u>Component ID</u> RC-62-H37	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-350	<u>Examination Remarks</u>		
Summary No. 2-027-RC-062-H038	<u>Component ID</u> RC-62-H38	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1A
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-351	<u>Examination Remarks</u>		
Summary No. 2-028-RC-017-H043	<u>Component ID</u> RC-17-H43	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1B
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-379	<u>Examination Remarks</u>		
Summary No. 2-028-RC-017-H044	<u>Component ID</u> RC-17-H44	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1B
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-381	<u>Examination Remarks</u> Support Deleted		
Summary No. 2-028-RC-017-H045	<u>Component ID</u> RC-17-H45	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Pressurizer Spray 1B
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-380	<u>Examination Remarks</u>		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.10      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-RC-017-H046	RC-17-H46	Support	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-382			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-RC-018-H009	RC-18-H9	Support	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-383			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-RC-018-H010	RC-18-H10	Support	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-384	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-RC-018-H011	RC-18-H11	Support	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-385	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-028-RC-018-H012	RC-18-H12	Support	RC	Pressurizer Spray 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-378			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-029-RC-018-H017	RC-18-H17	Support	RC	Combined Pressurizer Spray
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-411			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-033-RC-058-HA	RC-58-HA	Support	RC	Drain Line 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-309			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-033-RC-058-HB	RC-58-HB	Support	RC	Drain Line 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-310	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-034-RC-096-HA	RC-96-HA	Support	RC	Drain Line 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-318			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-034-RC-096-HB	RC-96-HB	Support	RC	Drain Line 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-319	Support Deleted		



**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.10      (continued)**

Summary No. 2-036-RC-091-H2	<u>Component ID</u> RC-91-H2	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-372	<u>Examination Remarks</u>		
Summary No. 2-036-RC-091-H6	<u>Component ID</u> RC-91-H6	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-019	<u>Examination Remarks</u>		
Summary No. 2-036-RC-091-HAJ	<u>Component ID</u> RC-91-HAJ	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-373	<u>Examination Remarks</u>		
Summary No. 2-036-RC-091-HAP	<u>Component ID</u> RC-91-HAP	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-374	<u>Examination Remarks</u>		
Summary No. 2-036-RC-091-HAQ	<u>Component ID</u> RC-91-HAQ	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-375	<u>Examination Remarks</u>		
Summary No. 2-036-RC-091-HP	<u>Component ID</u> RC-91-HP	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-376	<u>Examination Remarks</u>		
Summary No. 2-036-RC-091-HQ	<u>Component ID</u> RC-91-HQ	<u>Component Description</u> Support	<u>System</u> RC	<u>System Description</u> Letdown Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-377	<u>Examination Remarks</u>		
Summary No. 2-037-CH-005-H013	<u>Component ID</u> CH-5-H13	<u>Component Description</u> Support	<u>System</u> CH	<u>System Description</u> Charging Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-330	<u>Examination Remarks</u>		
Summary No. 2-037-CH-005-H017	<u>Component ID</u> CH-5-H17	<u>Component Description</u> Support	<u>System</u> CH	<u>System Description</u> Charging Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-332	<u>Examination Remarks</u>		
Summary No. 2-037-CH-005-H018	<u>Component ID</u> CH-5-H18	<u>Component Description</u> Support	<u>System</u> CH	<u>System Description</u> Charging Line
<u>Workscope</u> ISI	<u>Report No.</u> VT-02-333	<u>Examination Remarks</u>		

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.10      (continued)**

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-CH-005-H019	CH-5-H19	Support	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-329			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-CH-005-H020	CH-5-H20	Support	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-337			
ISI	VT-02-339			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-CH-005-H021	CH-5-H21	Support	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-334			
ISI	VT-02-338			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-CH-005-H022	CH-5-H22	Support	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-335			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-CH-005-H032	CH-5-H32	Support	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-336			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-037-CH-005-H037	CH-5-H37	Support	CH	Charging Line
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-331			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-SI-248-H017	SI-248-H17	Support	SI	HPSI Long Term Recirculation Loop 1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-304			
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-SI-248-H018	SI-248-H18	Support	SI	HPSI Long Term Recirculation Loop 1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-305	Support Deleted		
Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-SI-248-H019	SI-248-H19	Support	SI	HPSI Long Term Recirculation Loop 1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-307			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.10      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-SI-248-H020	SI-248-H20	Support	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-308	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-039-SI-248-H029	SI-248-H29	Support	SI	HPSI Long Term Recirculation Loop 1

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-306	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-SI-199-H015	SI-199-H15	Support	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-326	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-SI-199-H016	SI-199-H16	Support	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-327	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-SI-199-H017	SI-199-H17	Support	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-328	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-040-SI-199-H018	SI-199-H18	Support	SI	HPSI Long Term Recirculation Loop 2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-325	

**CLASS: 1      CATEGORY: F-A      ITEM: F1.40      Required: 13      Complete: 10**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-012	16-12	Pump Support # 1, Vertical Column Assembly	RC	Reactor Coolant Pump 1A

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-355	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-013	16-13	Pump Support # 2, Vertical Column Assembly	RC	Reactor Coolant Pump 1A

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-388	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-014	16-14	Pump Support # 3, Vertical Column Assembly	RC	Reactor Coolant Pump 1A

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-389	

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

**CLASS: 1      CATEGORY: F-A      ITEM: F1.40      (continued)**

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-015	16-15	Pump Support # 4, Vertical Column Assembly	RC	Reactor Coolant Pump 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-390			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-012	17-12	Pump Support # 1, Vertical Column Assembly	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-356			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-013	17-13	Pump Support # 2, Vertical Column Assembly	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-391			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-014	17-14	Pump Support # 3, Vertical Column Assembly	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-392			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-015	17-15	Pump Support # 4, Vertical Column Assembly	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-393			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-017	18-17	Pump Support # 5, Snubber	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-231			
ISI	VT-02-232			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-018	18-18	Pump Support # 6, Snubber	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-233			
ISI	VT-02-234			

**CLASS: 1      CATEGORY: N/A      ITEM: N/A (RCP FLYWHEEL - R.G. 1.14)      Required: 4      Complete: 4**

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-016-FLYWHEEL	16-Flywheel	Flywheel-RCP-1A (S\N #47429)	RC	Reactor Coolant Pump 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	UT-02-084			

Summary No.	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-017-FLYWHEEL	17-Flywheel	Flywheel-RCP 1B (S\N #47432)	RC	Reactor Coolant Pump 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	UT-02-085			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 1</b>	<b>CATEGORY: N/A</b>	<b>ITEM: N/A (RCP FLYWHEEL - R.G. 1.14)</b>	<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-018-FLYWHEEL	18-Flywheel	Flywheel-RCP-2A (S\N #47430)	RC	Reactor Coolant Pump 2A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	UT-02-082			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-019-FLYWHEEL	19-Flywheel	Flywheel-RCP-2B (S\N #47431)	RC	Reactor Coolant Pump 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	UT-02-081			
<b>CLASS: 2</b>	<b>CATEGORY: C-C</b>	<b>ITEM: C3.20</b>	<b>Required: 23</b>	<b>Complete: 11</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-043-SG-036-H012-S	SG-36-H12	Integral Attachment	SG	Main Steam (East) SG1-90
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-142			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-SG-033-H015-S	SG-33-H15	Integral Attachment	SG	Main Steam (West) SG1-270
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-141			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-SG-033-H016-S	SG-33-H16	Integral Attachment	SG	Main Steam (West) SG1-270
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-143			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-045-SG-042-H012-S	SG-42-H12	Integral Attachment	SG	Main Steam (East) SG2-270
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-144			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-046-SG-045-H012-S	SG-45-H12	Integral Attachment	SG	Main Steam (West) SG2-90
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-153			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-064-SG-039-H001-S	SG-39-H1	Integral Attachment	SG	Blowdown SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-004			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-064-SG-053-H005-S	SG-53-H5	Integral Attachment	SG	Blowdown SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-003			
ISI	PT-02-022	Supplemental to achieve 100% coverage		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 2      CATEGORY: C-C      ITEM: C3.20      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H016-S	SG-48-H16	Integral Attachment	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-005			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-099-SI-174-H013-S	SI-174-H13	Integral Attachment	SI	Cont. LPSI Header to Loop 2B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-046			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-103-CH-142-H020-S	CH-142-H20	Integral Attachment	CH	Refueling Water Suction A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-024			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-104-SI-308-H003-S	SI-308-H3	Integral Attachment	SI	SI Pump B Train Suction
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-076			

**CLASS: 2      CATEGORY: C-D      ITEM: C4.40      Required: 40**

**Complete: 40**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-056-UV132	UV132	Bonnet Bolting	SG	FW SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-107	20 Studs		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-056-UV174	UV174	Bonnet Bolting	SG	FW SG 1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	UT-02-108	20 Studs		

**CLASS: 2      CATEGORY: C-F-1      ITEM: C5.11 & C5.12      Required: 27**

**Complete: 8**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-059-016C	59-16C	Pipe to Tee	AF	Aux & Dwncmr FW SG #2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-043			
ISI	UT-02-075			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-059-034	59-34	Penetration to Pipe	AF	Aux & Dwncmr FW SG #2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-042			
ISI	UT-02-080			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 2      CATEGORY: C-F-1      ITEM: C5.11 & C5.12 (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-070-056	70-56	20" Sch 20 SS Pipe-to-Elbow	SI	LPSI Pump Room "A" Suction
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-036	Includes long seam		
ISI	UT-02-054	Includes long seam		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-094-074-037	74-37	20" XS Elbow-to-Pipe	SI	A Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-033	No credit for surface exam on long seam		
ISI	UT-02-055	Includes long seam		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-097-077-022	77-22	Cont. Penetration # 20-to-12" Sch 140 Pipe	SI	Cont. LPSI Header to Loop 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-047			
ISI	UT-02-103			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-097-077-027	77-27	Valve-to-12" Sch 140 Pipe	SI	Cont. LPSI Header to Loop 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-045			
ISI	UT-02-104	Limited UT examinations, see Appendix B		
ISI	UT-02-105			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-100-070-121	70-121	Valve to Pipe	SI	Cont. LPSI Train A Suction
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-063			
ISI	UT-02-127	Limited UT examinations, see Appendix B		
ISI	UT-02-128			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-102-084-026	84-26	24" Sch 30 Elbow-to-Pipe	SI	SI Pumps A Train Suction
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-032	No credit for surface exam on long seam		
ISI	UT-02-053	Includes long seam		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-103-086-003	86-3	20" Sch 20 Pipe-to-Elbow	CH	Refueling Water Suction A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-025	Includes long seam		
ISI	UT-02-024	Includes long seam		

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

**CLASS: 2      CATEGORY: C-F-1      ITEM: C5.11 & C5.12 (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-104-085-031	85-31	24" Sch 30 Elbow-to-Pipe	SI	SI Pumps B Train Suction
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-077	No credit for surface exam on long seam		
ISI	UT-02-101	Includes long seam		

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-105-087-037	87-37	Pipe to Elbow	CH	Refueling Water Suction B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-023	Includes long seam		
ISI	UT-02-023	Includes long seam		

**CLASS: 2      CATEGORY: C-F-1      ITEM: C5.21      Required: 17      Complete: 3**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-115-020	115-20	Pipe to valve	SI	Cont. HPSI Header Loop 2A & 2B

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-021			
ISI	UT-02-013	Limited UT examinations, see Appendix B		
ISI	UT-02-014			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-118-049	118-49	Pipe to valve	SI	HPSI "A" Long Term Recirculation

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-018			
ISI	UT-02-017	Limited UT examinations, see Appendix B		
ISI	UT-02-018			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-119-052	119-52	Pipe to valve	SI	HPSI "B" Long Term Recirculation

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-015			
ISI	UT-02-009	Limited UT examinations, see Appendix B		
ISI	UT-02-012			

**CLASS: 2      CATEGORY: C-F-1      ITEM: C5.30      Required: 1      Complete: 1**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-106-061	106-61	Orifice to Pipe	SI	HPSI Pump Room "A" Discharge

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-031			

**CLASS: 2      CATEGORY: C-F-1      ITEM: C5.41      Required: 2      Complete: 1**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-076-079	76-79	Pipe to sweeplet	SI	Cont. LPSI Header to Loop 1A

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	PT-02-075			



**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>	<b>CATEGORY: C-F-2</b>	<b>ITEM: C5.51 &amp; C5.52</b>	<b>Required: 10 (10)</b>	<b>Complete: 3 (8)</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-005	44-5	28" Carbon Steel Pipe-to-Elbow	SG	Main Steam (West) SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-140	No credit for surface exam on long seam		
ISI	UT-02-060	Includes long seam		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-030	44-30	28" Carbon Steel Pipe-to-Penetration # 1	SG	Main Steam (West) SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-015	No credit for long seam		
ISI	UT-02-043	No credit for long seam		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-054-011A	54-11A	Pipe to Reducer	SG	FW SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-001			
ISI	UT-02-042			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-055-026	55-26	Reducer to Pipe	SG	FW SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	MT-02-002			
ISI	UT-02-041			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-058-012	58-12	Pipe to Elbow	SG	Aux & Dwncmr FW SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-146			
AUG	UT-02-077	Augmented examination per IEB 79-13 & SER 83-07		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-058-013	58-13	Elbow to Pipe	SG	Aux & Dwncmr FW SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-134			
AUG	UT-02-069	Augmented examination per IEB 79-13 & SER 83-07		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-058-016	58-16	Pipe to Elbow	SG	Aux & Dwncmr FW SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-135			
AUG	UT-02-070	Augmented examination per IEB 79-13 & SER 83-07		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-058-016A	58-16A	Tee to Pipe	SG	Aux & Dwncmr FW SG #1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-136			
AUG	UT-02-071	Augmented examination per IEB 79-13 & SER 83-07		

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 2      CATEGORY: C-F-2      ITEM: C5.51 & C5.52 (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-059-012	59-12	Pipe to Elbow	SG	Aux & Dwncmr FW SG #2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-147	
AUG	UT-02-078	Augmented examination per IEB 79-13 & SER 83-07

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-059-013	59-13	Elbow to Pipe	SG	Aux & Dwncmr FW SG #2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-137	
AUG	UT-02-072	Augmented examination per IEB 79-13 & SER 83-07

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-059-016	59-16	Pipe to Elbow	SG	Aux & Dwncmr FW SG #2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-138	
AUG	UT-02-073	Augmented examination per IEB 79-13 & SER 83-07

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-059-016A	59-16A	Tee to Pipe	SG	Aux & Dwncmr FW SG #2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
AUG	MT-02-139	
AUG	UT-02-074	Augmented examination per IEB 79-13 & SER 83-07

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-052	65-52	6" Sch 120 Pipe-to Cont. Penetration	SG	Blowdown SG2

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	MT-02-145	
ISI	UT-02-102	

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

<b>CLASS: 2</b>	<b>CATEGORY: C-H</b>	<b>ITEM: C7.10, 30, 50, 70</b>	<b>Required: All</b>	<b>Complete: ~10%</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-Pres. Test	System Leakage Test	Piping and Components	Various	Pressure Retaining Piping and Components

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-409	
ISI	01-2037	Period 1 VT Examination
ISI	01-2050	Period 1 VT Examination
ISI	01-2038	Period 1 VT Examination
ISI	01-2036	Period 1 VT Examination
ISI	01-2032	Period 1 VT Examination
ISI	01-2022	Period 1 VT Examination
ISI	01-2021	Period 1 VT Examination
ISI	01-2020	Period 1 VT Examination
ISI	01-2019	Period 1 VT Examination
ISI	01-2018	Period 1 VT Examination
ISI	01-2017	Period 1 VT Examination
ISI	01-2016	Period 1 VT Examination
ISI	01-2012	Period 1 VT Examination
ISI	01-2003	Period 1 VT Examination
ISI	01-2002	Period 1 VT Examination
ISI	01-2001	Period 1 VT Examination

<b>CLASS: 2</b>	<b>CATEGORY: F-A</b>	<b>ITEM: F1.20 &amp; F1.40</b>	<b>Required: 248</b>	<b>Complete: 120</b>
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-043-SG-036-H012	SG-36-H12	Support	SG	Main Steam (East) SG1-90

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-395	Support Deleted

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-SG-033-H015	SG-33-H15	Support	SG	Main Steam (West) SG1-270

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-396	Support Deleted

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-SG-033-H016	SG-33-H16	Support	SG	Main Steam (West) SG1-270

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-397	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-SG-033-H881	SG-33-H881	Support	SG	Main Steam (West) SG1-270

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-275	

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-044-SG-033-H882	SG-33-H882	Support	SG	Main Steam (West) SG1-270

<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>
ISI	VT-02-274	

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-045-SG-042-H012	SG-42-H12	Support		SG	Main Steam (East) SG2-270		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-277	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-045-SG-042-H013	SG-42-H13	Support		SG	Main Steam (East) SG2-270		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-276	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-046-SG-045-H012	SG-45-H12	Support		SG	Main Steam (West) SG 2-90		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-354	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-046-SG-045-H887	SG-45-H887	Support		SG	Main Steam (West) SG2-90		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-259						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-046-SG-045-H888	SG-45-H888	Support		SG	Main Steam (West) SG2-90		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-256						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-053-SG-081-H004	SG-81-H4	Support		SG	Steam to Aux. FW System		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-089	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-053-SG-083-H004	SG-83-H4	Support		SG	Steam to Aux. FW System		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-090	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-054-SG-002-H011	SG-2-H11	Support		SG	FW SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-008						
ISI	VT-02-011						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H004	SG-5-H4	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-246						
ISI	VT-02-247						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H005	SG-5-H5	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-248						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H006	SG-5-H6	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-249						
ISI	VT-02-253						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H007	SG-5-H7	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-250						
ISI	VT-02-254						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H008	SG-5-H8	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-272						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H013	SG-5-H13	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-273						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-055-SG-005-H014	SG-5-H14	Support		SG	FW SG2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-251						
ISI	VT-02-255						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H006	SG-8-H6	Support		SG	Aux & Dwncmr FW SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-340						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H007	SG-8-H7	Support		SG	Aux & Downcomer Feedwater SG 1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-341						
ISI	VT-02-343						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H008	SG-8-H8	Support		SG	Aux & Dwncmr FW SG 1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-205						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H009	SG-8-H9	Support		SG	Aux & Dwncmr FW SG 1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-206						
ISI	VT-02-208						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H010	SG-8-H10	Support		SG	Aux & Dwncmr FW SG 1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-207						
ISI	VT-02-212						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H011	SG-8-H11	Support		SG	Aux & Dwncmr FW SG 1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-209						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-058-SG-008-H017	SG-8-H17	Support		SG	Aux & Dwncmr FW SG 1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-342						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-059-SG-011-H013	SG-11-H13	Support		SG	Aux & Dwncmr FW SG 2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-353						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-059-SG-011-H014	SG-11-H14	Support		SG	Aux & Dwncmr FW SG 2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-213						
ISI	VT-02-214						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-059-SG-011-H015	SG-11-H15	Support		SG	Aux & Dwncmr FW SG 2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-210						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-059-SG-011-H016	SG-11-H16	Support		SG	Aux & Dwncmr FW SG 2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-204						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-059-SG-011-H018	SG-11-H18	Support		SG	Aux & Dwncmr FW SG 2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-352						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-059-SG-011-H019	SG-11-H19	Support		SG	Aux & Dwncmr FW SG 2		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-211						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H001	SG-39-H1	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-003	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H002	SG-39-H2	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-002	Support deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H003	SG-39-H3	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-032	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H004	SG-39-H4	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-033						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H005	SG-39-H5	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-034						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H006	SG-39-H6	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-035	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-039-H027	SG-39-H27	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-036	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-053-H003	SG-53-H3	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-041	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-053-H004	SG-53-H4	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-042						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-064-SG-053-H005	SG-53-H5	Support		SG	Blowdown SG1		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-043						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>	<b>CATEGORY: F-A</b>	<b>ITEM: F1.20 &amp; F1.40</b>	<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-064-SG-053-H006	SG-53-H6	Support	SG	Blowdown SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-044	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-064-SG-053-H007	SG-53-H7	Support	SG	Blowdown SG1
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-045	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H013	SG-48-H13	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-025	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H014	SG-48-H14	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-024			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H015	SG-48-H15	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-023			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H016	SG-48-H16	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-026			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H017	SG-48-H17	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-027	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H018	SG-48-H18	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-022			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H022	SG-48-H22	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-021			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H023	SG-48-H23	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-028			



**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>	<b>CATEGORY: F-A</b>	<b>ITEM: F1.20 &amp; F1.40</b>	<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H024	SG-48-H24	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-031			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H025	SG-48-H25	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-030	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-065-SG-048-H026	SG-48-H26	Support	SG	Blowdown SG2
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-029	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-071-SI-078-H001	SI-78-H1	Support	SI	LPSI Pump Room "A" Discharge
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-053			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-071-SI-078-H002	SI-78-H2	Support	SI	LPSI Pump Room "A" Discharge
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-052			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-071-SI-087-H001	SI-87-H1	Support	SI	LPSI Pump Room "A" Discharge
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-051			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-071-SI-087-H002	SI-87-H2	Support	SI	LPSI Pump Room "A" Discharge
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-050			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-071-SI-087-H003	SI-87-H3	Support	SI	LPSI Pump Room "A" Discharge
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-049			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-073-SI-308-H014 Suction	SI-308-H14	Support	SI	LPSI Pump Room "B"
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-289			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>	<b>CATEGORY: F-A</b>	<b>ITEM: F1.20 &amp; F1.40</b>	<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-080-SI-119-H001	SI-119-H1	Support	SI	Containment Spray Pump Room "B" Discharge
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
PSE	01-2004			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-086-SI-129-H012	SI-129-H12	Support	SI	Shutdown Cooling Heat Exchanger Room B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
PSE	01-2005			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-094-SI-241-H006	SI-241-H6	Support	SI	A Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-062			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-094-SI-241-H007	SI-241-H7	Support	SI	A Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-061			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-094-SI-241-H008	SI-241-H8	Support	SI	A Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-088			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-094-SI-241-H017	SI-241-H17	Support	SI	A Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-075			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-095-SI-072-H007	SI-72-H7	Support	SI	B Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-047			
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-059			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-095-SI-072-H009	SI-72-H9	Support	SI	B Train Misc. Pipe Chases and 88' Pipe Tunnel
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-046			

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>	<b>CATEGORY: F-A</b>	<b>ITEM: F1.20 &amp; F1.40</b>	<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-SI-202-H003	SI-202-H3	Support	SI	Cont. LPSI Header to Loop 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-081			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-SI-202-H004	SI-202-H4	Support	SI	Cont. LPSI Header to Loop 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-080			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-SI-202-H006	SI-202-H6	Support	SI	Cont. LPSI Header to Loop 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-079			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-SI-202-H010	SI-202-H10	Support	SI	Cont. LPSI Header to Loop 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-077	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-SI-202-H011	SI-202-H11	Support	SI	Cont. LPSI Header to Loop 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-078	Support Deleted		
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-096-SI-202-H015	SI-202H15	Support	SI	Cont. LPSI Header to Loop 1A
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-082			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-097-SI-220-H001	SI-220-H1	Support	SI	Cont. LPSI Header to Loop 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-298			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-097-SI-220-H016	SI-220-H16	Support	SI	Cont. LPSI Header to Loop 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-299			
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-097-SI-220-H017	SI-220-H17	Support	SI	Cont. LPSI Header to Loop 1B
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
ISI	VT-02-300			

**Appendix 1  
Inservice Inspection Summary Report  
2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-097-SI-220-H018	SI-220-H18	Support		SI	Cont. LPSI Header to Loop 1B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-301						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-097-SI-220-H021	SI-220-H21	Support		SI	Cont. LPSI Header to Loop 1B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-302	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-097-SI-220-H028	SI-220-H28	Support		SI	Cont. LPSI Header to Loop 1B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-303	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-098-SI-155-H001	SI-155-H1	Support		SI	Cont. LPSI Header to Loop 2A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-087						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-098-SI-155-H002	SI-155-H2	Support		SI	Cont. LPSI Header to Loop 2A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-084						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-098-SI-155-H003	SI-155-H3	Support		SI	Cont. LPSI Header to Loop 2A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-085	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-098-SI-155-H004	SI-155-H4	Support		SI	Cont. LPSI Header to Loop 2A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-086	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-098-SI-155-H007	SI-155-H7	Support		SI	Cont. LPSI Header to Loop 2A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-083						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-099-SI-174-H007	SI-174-H7	Support		SI	Cont. LPSI Header to Loop 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-404	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-099-SI-174-H008	SI-174-H8	Support		SI	Cont. LPSI Header to Loop 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-405						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-099-SI-174-H009	SI-174-H9	Support		SI	Cont. LPSI Header to Loop 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-406	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-099-SI-174-H010	SI-174-H10	Support		SI	Cont. LPSI Header to Loop 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-407						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-099-SI-174-H013	SI-174-H13	Support		SI	Cont. LPSI Header to Loop 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-408						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-008-H001	SI-8-H1	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-055						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-008-H002	SI-8-H2	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-054						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-008-H003	SI-8-H3	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-056						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-008-H004	SI-8-H4	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-057						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-307-H006	SI-307-H6	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-060						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-307-H007	SI-307-H7	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-063						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-102-SI-307-H014	SI-307-H14	Support		SI	SI Pumps A Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-048						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-103-CH-142-H008	CH-142-H8	Support		CH	Refueling Water Suction A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-064						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-103-CH-142-H020	CH-142-H20	Support		CH	Refueling Water Suction A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-065						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-103-CH-142-H021	CH-142-H21	Support		CH	Refueling Water Suction A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-067						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-103-CH-424-H002	CH-424-H2	Support		CH	Refueling Water Suction A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-066						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-103-CH-424-H003	CH-424-H3	Support		CH	Refueling Water Suction A		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-068						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H001	SI-308-H1	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-284						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H002	SI-308-H2	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-285						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H003	SI-308-H3	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-297						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H004	SI-308-H4	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-296						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H006	SI-308-H6	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-286	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H007	SI-308-H7	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-287	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-104-SI-308-H015	SI-308-H15	Support		SI	SI Pumps B Train Suction		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-288						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H001	CH-149-H1	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-400	Expansion					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H002	CH-149-H2	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-401	Expansion					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H003	CH-149-H3	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-402	Expansion					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H004	CH-149-H4	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-283	Reject					
PSE	VT-02-387	Re-examination, PSE after replacement					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H005	CH-149-H5	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-294						

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

<b>CLASS: 2</b>		<b>CATEGORY: F-A</b>		<b>ITEM: F1.20 &amp; F1.40</b>		<b>(continued)</b>	
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H006	CH-149-H6	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-293						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H007	CH-149-H7	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-295						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H008	CH-149-H8	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-398	Expansion					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H021	CH-149-H21	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-399	Expansion					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H025	CH-149-H25	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-292						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H026	CH-149-H26	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-291						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-105-CH-149-H027	CH-149-H27	Support		CH	Refueling Water Suction B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-290						
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-115-SI-157-H010	SI-157-H10	Support		SI	Containment HPSI Header Loop 2A & 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-076	Support Deleted					
<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>		<u>System</u>	<u>System Description</u>		
2-115-SI-157-H011	SI-157-H11	Support		SI	Containment HPSI Header Loop 2A & 2B		
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>					
ISI	VT-02-074						



**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 2      CATEGORY: F-A      ITEM: F1.20 & F1.40      (continued)**  
Summary No.      Component ID      Component Description      System      System Description  
 2-115-SI-176-H004      SI-176-H4      Support      SI      Containment HPSI Header Loop 2A & 2B

Workscope      Report No.      Examination Remarks  
 ISI      VT-02-073

**CLASS: 2      CATEGORY: C-F-2      ITEM: AHE5.51      Required: 57      Complete: 8**  
Summary No.      Component ID      Component Description      System      System Description  
 2-053-001      53-1      Sweeplet-to-6" Sch 80 Pipe      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-013  
 AUG      UT-02-092      Supplemental Exam

Summary No.      Component ID      Component Description      System      System Description  
 2-053-002      53-2      6" Sch 80 Pipe-to-Elbow      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-012  
 AUG      UT-02-093

Summary No.      Component ID      Component Description      System      System Description  
 2-053-004      53-4      6" Sch 80 Elbow-to-Pipe      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-016  
 AUG      UT-02-094

Summary No.      Component ID      Component Description      System      System Description  
 2-053-005      53-5      6" Sch 80 Pipe-to-Elbow      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-011  
 AUG      UT-02-095

Summary No.      Component ID      Component Description      System      System Description  
 2-053-006      53-6      6" Sch 80 Elbow-to-Pipe      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-017  
 AUG      UT-02-096

Summary No.      Component ID      Component Description      System      System Description  
 2-053-007      53-7      6" Sch 80 Pipe-to-Elbow      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-010  
 AUG      UT-02-097

Summary No.      Component ID      Component Description      System      System Description  
 2-053-008      53-8      6" Sch 80 Elbow-to-Pipe      SG      Steam to Aux. FW System

Workscope      Report No.      Examination Remarks  
 AUG      MT-02-009  
 AUG      UT-02-098

**Appendix 1**  
**Inservice Inspection Summary Report**  
**2-2-1 (2R10)**

**CLASS: 2      CATEGORY: C-F-2      ITEM: AHE5.51      (continued)**

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-053-009	53-9	6" Sch 80 Pipe-to-Elbow	SG	Steam to Aux. FW System
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-014			
AUG	UT-02-099			

<u>Summary No.</u>	<u>Component ID</u>	<u>Component Description</u>	<u>System</u>	<u>System Description</u>
2-053-010	53-10	6" Sch 80 Elbow-to-Pipe	SG	Steam to Aux. FW System
<u>Workscope</u>	<u>Report No.</u>	<u>Examination Remarks</u>		
AUG	MT-02-008			
AUG	UT-02-100			

**APPENDIX B**

**INSERVICE INSPECTION  
CODE LIMITATIONS**

## UNIT 2 - REFUELING OUTAGE TEN

### CODE LIMITATIONS

<u>ASME Item</u>	<u>ITEM ID</u>	<u>Component</u>	<u>Report Number(s)</u>
B03.110	2-005-010	Pressurizer	UT-02-027, 033, 036, 039
B03.110	2-005-013	Pressurizer	UT-02-031, 034, 037, 040

Limitation Pressurizer head to nozzle weld examinations limited to an average of 83% coverage, due to geometrical configuration.

<u>ASME Item</u>	<u>ITEM ID</u>	<u>Component</u>	<u>Report Number(s)</u>
B08.20	2-005-001	Pressurizer	UT-02-056, 057, 058, 059

Limitation The Pressurizer skirt weld examinations limited to an average of 57.5% coverage, due to geometrical configuration.

<u>ASME Item</u>	<u>ITEM ID</u>	<u>Component</u>	<u>Report Number(s)</u>
B09.11	2-025-004	Safety Injection 2A	UT-02-110 & 113
B09.11	2-023-006	Safety Injection 1A	UT-02-090 & 091
B09.11	2-024-006	Safety Injection 1B	UT-02-001 & 003
B09.11	2-024-014	Safety Injection 1B	UT-02-045 & 050
B09.11	2-024-016	Safety Injection 1B	UT-02-046 & 048
B09.11	2-024-019	Safety Injection 1B	UT-02-047 & 051
B09.11	2-025-006	Safety Injection 2A	UT-02-111 & 114
B09.11	2-026-006	Safety Injection 2A	UT-02-002 & 004
B09.11	2-026-017	Safety Injection 2B	UT-02-044 & 049
B09.21	2-039-024	HPSI Long Term Recirc. Loop 1	UT-02-015 & 016
C05.11	2-097-077-027	Cont. LPSI Header to Loop 1B	UT-02-104 & 105
C05.11	2-100-070-121	Cont. LPSI Train A Suction	UT-02-127 & 128
C05.21	2-115-020	Cont. HPSI Header Loop 2A & 2B	UT-02-013 & 014
C05.21	2-118-049	HPSI "A" Long Term Recirc.	UT-02-017 & 018
C05.21	2-119-052	HPSI "B" Long Term Recirc.	UT-02-009 & 012

Limitation Single-sided Austenitic weld examinations estimated at 50% coverage, based on ASME Appendix VIII PDI demonstration.

**APPENDIX C**

**NIS-1 FORMS**

1. OWNER - *ARIZONA PUBLIC SERVICE COMPANY, et al*  
 ADDRESS - *P.O. BOX 52034, PHOENIX, ARIZONA 85072*
2. PLANT - *PALO VERDE NUCLEAR GENERATING STATION*  
 ADDRESS - *5801 SOUTH WINTERSBURG ROAD; TONOPAH, ARIZONA 85354-7529*
3. UNIT NUMBER - 2
4. OWNERS' CERTIFICATE OF AUTHORIZATION - *NONE*
5. COMMERCIAL SERVICE DATE - *September 19, 1986*
6. COMPONENTS INSPECTED:

COMPONENT OR APPURTENANCE	MANUFACTURER OR INSTALLER	SERIAL NUMBER	STATE OR PROVINCE	NATIONAL BOARD NO
---------------------------	---------------------------	---------------	-------------------	-------------------

This report is a summary of the second interval second period examinations performed to date for Unit 2. Selected examinations are being applied to Period 1, with no credit taken for Period 2. The items examined, along with the examination report numbers, are listed in Appendix A.

## OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

7. EXAM DATES 11-3-2001 TO 4-15-2002
8. INSPECTION INTERVAL FROM 3-18-1997 TO 3-17-2007
9. ABSTRACT OF EXAMINATIONS. INCLUDE A LIST OF EXAMINATIONS AND A STATEMENT CONCERNING STATUS OF WORK REQUIRED FOR CURRENT INTERVAL.

The items examined, along with the examination report numbers, are listed in Appendix A. The examinations are listed by ASME Category and Item Numbers with the corresponding examination report numbers.

10. ABSTRACT OF CONDITIONS NOTED

The three rejectable conditions documented during this outage were corrected or determined "use as is" in accordance with PVNGS work control practices and ASME Section XI. One support was damaged, the pressurizer skirt weld had an indication and boron was on instrumentation tubes. Section 2 - Examination Summary of the summary report addresses these conditions.

11. ABSTRACT OF CORRECTIVE MEASURES RECOMMENDED AND TAKEN

The rejectable portion of the support CH149H9 was replaced in accordance with ASME Section XI and APS Work Control procedures. The pressurizer skirt weld and instrumentation tubes were verified to remain essentially unchanged from the original evaluation.

Several repairs and replacements have been performed since the last summary report due to routine or corrective maintenance. The work was performed in accordance with ASME Section XI and APS Work Control procedures. Applicable NIS-2 forms are included in Appendix D and a copy maintained on file at Palo Verde Nuclear Generating Station by Arizona Public Service

WE CERTIFY THAT THE STATEMENTS MADE IN THIS REPORT ARE CORRECT AND THE EXAMINATIONS AND CORRECTIVE MEASURES TAKEN CONFORM TO THE RULES OF THE ASME CODE, SECTION XI.

DATE 7/11/02 SIGNED: ARIZONA PUBLIC SERVICE COMPANY BY Michael A. Meek

### CERTIFICATE OF INSERVICE INSPECTION

I, THE UNDERSIGNED, HOLDING A VALID COMMISSION ISSUED BY THE NATIONAL BOARD OF BOILER AND PRESSURE VESSEL INSPECTORS AND THE STATE OR PROVINCE OF ARIZONA EMPLOYED BY HSB-CT. OF HARTFORD, CONNECTICUT HAVE INSPECTED THE COMPONENTS DESCRIBED IN THIS OWNERS REPORT DURING THE PERIOD 11-3-01 TO 4-15-02, AND STATE THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF, THE OWNER HAS PERFORMED EXAMINATIONS AND TAKEN CORRECTIVE MEASURES DESCRIBED IN THIS OWNERS REPORT IN ACCORDANCE WITH THE REQUIREMENTS OF THE ASME CODE, SECTION XI. BY SIGNING THIS CERTIFICATE NEITHER THE INSPECTOR NOR HIS EMPLOYER MAKES ANY WARRANTY, EXPRESSED OR IMPLIED, CONCERNING THE EXAMINATIONS AND CORRECTIVE MEASURES DESCRIBED IN THIS OWNERS REPORT. FURTHERMORE, NEITHER THE INSPECTOR NOR HIS EMPLOYER SHALL BE LIABLE IN ANY MANNER FOR ANY PERSONAL INJURY OR PROPERTY DAMAGE OR A LOSS OF ANY KIND ARISING FROM OR CONNECTED WITH THIS INSPECTION.

INSPECTOR Ralph Egan COMMISSIONS NB10448, "BNIC", CA 1716  
 NAT'L BOARD, STATE, PROVINCE

DATE Jul. 11, 2002

**APPENDIX D**

**NIS-2 FORMS**



# ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JDGAHCV0009 2. Code Class 3
3. Item Description ISOLATION VALVE FOR 2MDGAX01B
4. N-5 Package Number 2DG01-2 5. W.O. Number 00919271
6. Original Construction Code Edition 1974 EDITION, SUMMER 1976 ADDENDA
7. Original Installation Code Edition 1974 EDITION, WINTER 1975 ADDENDA
8. Work Description REPLACE VALVE TO ALLOW INSTALLATION OF A SOFT SEAT AS REQUIRED TO CORRECT THE NOTED LEAKAGE BY THE SEAT.
9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_
10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
REF. ECE-DG-A062

11. Repair/Replacement Work Organization ARIZONA PUBLIC SERVICE
12. Replacement Item Construction or reconciled Code/Edition ASME III, CL3, 74 ED., S'76 ADDENDA
13. Repair/Replacement Activity Construction Code/Edition SECTION III, 74 EDITION, W'75 ADDENDA
14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
MB 03/14/00 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
MB 03/14/00 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- MB 03/14/00 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- MB 03/14/00 18. Include a step in the W.O. to record below all applicable numbers for repaired or replaced items.  
Initial Date

COMP I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
<u>2JDGAHCV0009</u>	<u>MPN 4500-3509</u>	<u>NA-523929-01A</u>	<u>N/A</u>	<u>357601-1</u>

19. Planner David L. Brunson 03/14/00 Print Name DAVID L. BRUNSON  
Signature Date
20. ISI Engineer Alan Morrow 3-14-00 Print Name Alan Morrow  
Signature Date
21. ANII R. G. Houston 3-14-00 Print Name R. G. Houston  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 01/17/01  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 230255  
Address Work Order Number

3. Work Performed by Arizona Public Service Co. Type Code Symbol Stamp None  
Name  
P.O. Box 53999, Phoenix, Az. 85072-2034 Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System Diesel Generator (DG), ASME Section III Class 3

5. (a) Applicable Construction Code Section III ND 19 74 Edition, W '75 Addenda, N/A Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Valve	Neles-Jamesbury	NO-S23921-01A	N/A	DGAHCV0009	1993	Replacement	Yes

7. Description of Work Replaced valve

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks Work Order 230255, originally prepared under "Legacy Work Order" number 00-919271.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI.  
repair or replacement

Type Code Symbol Stamp \_\_\_\_\_ N/A \_\_\_\_\_  
Certificate of Authorization No. \_\_\_\_\_ N/A \_\_\_\_\_ Expiration Date \_\_\_\_\_  
Signed *Willy [Signature]* ISI ENGINEER Date 1-17-01  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-14-00 to 1-17-01, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*[Signature]* \_\_\_\_\_ Commissions NB 9685 AZ 264 "N" "I"  
Inspector's Signature National Board, State, Province, and Endorsements  
Date 01/17/01

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2SI092H002 2. Code Class SECTION III Subsection NF Class 3  
 3. Item Description 1 KIP SNUBBER  
 4. N-5 Package Number 2CH08-1B 5. W.O. Number 234213  
 6. Original Construction Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 7. Original Installation Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 8. Work Description Replace Snubber

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Not a failure. Changed for precautionary measures. This is a like for like replacement

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 14. ASME Section XI Code/Edition 1992 Edition and 1992 Addenda

15. Preservice Inspection Required.  YES  NO  
Dmg 3-8-2001 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
Dmg 3-8-2001 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

R. P. Indap 3-8-2001 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date

R. P. Indap 3-8-2001 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2SI092H002	N/A	4200	N/A	N/A

19. Planner David Goodlet 3-8-2001 Print Name David Goodlet  
Signature Date  
 20. ISI Engineer R. P. Indap 3/23/01 Print Name R. P. INDAP  
Signature Date  
 21. ANII Robert Hogstram 3-23-01 Print Name Robert Hogstram  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/16/01  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 234213  
Address Work Order Number

3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
5801 S Wintersburg Road, Tonopah Arizona 85354-752 Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System "SI" Safety Injection

5. (a) Applicable Construction Code Subsect. NF Class 3 19 74 Edition, W'75 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
1 Kip Snubber	Pacific Scientific	4200	N/A	2SI092H002	1978	Replacement	Yes

7. Description of Work Snubber Replacement (No Welding)

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WO#234213 Removed snubber Serial number 9373 and replaced it with serial number 4200

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI.  
repair or replacement

Type Code Symbol Stamp N/A  
Certificate of Authorization No. N/A Expiration Date N/A  
Signed R. P. Indap, I. S. I. Engineer Date 6-05-2001  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-23-01 to 6-5-01, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. P. Indap Commissions NB 9685 "N" "I" Az. 264  
Inspector's Signature National Board, State, Province, and Endorsements  
Date 6-5-01

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2SI119H001      2. Code Class SECTION III Subsection NF Class 2  
 3. Item Description 3 KIP SNUBBER  
 4. N-5 Package Number 2SI06-4      5. W.O. Number 234291  
 6. Original Construction Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 7. Original Installation Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 8. Work Description Replace Snubber

9.  ISI Flaw      NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Not a failure. Changed for precautionary measures. This a like for like replacement

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 14. ASME Section XI Code/Edition 1992 Edition and 1992 Addenda

15. Preservice Inspection Required.       YES       NO  
DGH    3-8-2001    If required, include a step in the W.O. to perform Preservice Inspection.  
Initial      Date

16. ASME Section XI Pressure Test Required       YES       NO  
DGH    3-8-2001    If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial      Date

DGH    3-8-2001    17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial      Date

DGH    3-8-2001    18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial      Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2SI119H001	N/A	20221	N/A	N/A

19. Planner David Goodlet    3-8-2001    Print Name David Goodlet  
Signature      Date  
 20. ISI Engineer R.P. Indap    3/23/01    Print Name R.P. INDAP  
Signature      Date  
 21. ANII Robert Hogstrom    3-23-01    Print Name Robert Hogstrom  
Signature      Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/16/01  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 234291  
Address Work Order Number

3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
5801 S Wintersburg Road, Tonopah Arizona 85354-752 Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System "SI" Safety Injection

5. (a) Applicable Construction Code Subsect. NF Class 2 19 74 Edition, W'75 Addenda, \_\_\_\_\_ Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
3Kip Snubber	Pacific Scientific	20221	N/A	2SI119H001	1982	Replacement	Yes

7. Description of Work Snubber Replacement (No Welding)

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



# FORM NIS-2 (Back)

9. Remarks WO#234291 Removed snubber Serial number 7164 and replaced it with serial number 20221  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. P. Ordog, ISI Engineer Date 6-05-2001  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-23-01 to 6-5-01, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. P. Ordog  
Inspector's Signature

Commissions NB 9685 "N" "I" Az-264  
National Board, State, Province, and Endorsements

Date 6-5-01

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2SI129H012 2. Code Class SECTION III Subsection NF Class 2  
 3. Item Description 3 KIP SNUBBER  
 4. N-5 Package Number 2SI07-10 5. W.O. Number 234409  
 6. Original Construction Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 7. Original Installation Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 8. Work Description Replace Snubber

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Not a failure. Changed for precautionary measures. This is a like for like replacement

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 14. ASME Section XI Code/Edition 1992 Edition and 1992 Addenda

15. Preservice Inspection Required.  YES  NO  
DG 3-8-2001 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DG 3-8-2001 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

DG 3-8-2001 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DG 3-8-2001 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2SI129H012	N/A	25362	N/A	N/A

19. Planner David Goodlet 3-8-2001 Print Name David Goodlet  
Signature Date  
 20. ISI Engineer R.P. Indap 3/23/01 Print Name R.P. INDAP  
Signature Date  
 21. ANII Robert Hogstram 3-23-01 Print Name Robert Hogstram  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/16/01  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address
2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 234409  
Address Work Order Number
3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
5801 S Wintersburg Road, Tonopah Arizona 85354-752 Authorization No. N/A  
Address Expiration Date N/A
4. Identification of System "SI" Safety Injection
5. (a) Applicable Construction Code Subsect. NF Class 2 19 74 Edition, W'75 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
3 Kip Snubber	Pacific Scientific	25362	N/A	2SI129H012	1982	Replacement	Yes

7. Description of Work Snubber Replacement (No Welding)
8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1
- Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WO#234409 Removed snubber Serial number 7321 and replaced it with serial number 25362

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. Phordap, ISI Engineer Date 6-5-2001  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-23-01 to 6-5-01, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. S. Hyattson  
Inspector's Signature

Commissions NB 9685 "N" "I" AZ-264  
National Board, State, Province, and Endorsements

Date 6-5-01

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2SG203H004 TOP      2. Code Class SECTION III Subsection NF Class 2  
 3. Item Description 35 KIP SNUBBER  
 4. N-5 Package Number 2AF02-2      5. W.O. Number 235144  
 6. Original Construction Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 7. Original Installation Code Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 8. Work Description Replace Snubber

9.  ISI Flaw      NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Not a failure. Changed for precautionary measures. This is a like for like replacement

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition 1974 EDITION THRU WINTER 1975 ADDENDA  
 14. ASME Section XI Code/Edition 1992 Edition and 1992 Addenda

15. Preservice Inspection Required.       YES       NO  
Dmg 3-8-2001      If required, include a step in the W.O. to perform Preservice Inspection.  
Initial      Date

16. ASME Section XI Pressure Test Required       YES       NO  
Dmg 3-8-2001      If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial      Date

Dmg 3-8-2001      17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial      Date

Dmg 3-8-2001      18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial      Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2SG203H004 TOP	N/A	12932	N/A	N/A

19. Planner David Goodlet 3-8-2001      Print Name David Goodlet  
Signature      Date

20. ISI Engineer R. P. Indap 3/23/01      Print Name R. P. INDAP  
Signature      Date

21. ANII Robert Hogstram 3-23-01      Print Name Robert Hogstram  
Signature      Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/16/01  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 235144  
Address Work Order Number

3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
5801 S Wintersburg Road, Tonopah Arizona 85354-752 Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System "SG" Steam Generator

5. (a) Applicable Construction Code Subsect. NF Class 2 19 74 Edition, W'75 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
35 Kip Snubber	Pacific Scientific	12932	N/A	2SG203H004T	1983	Replacement	Yes

7. Description of Work Snubber Replacement (No Welding)

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WO#235144 Removed snubber Serial number 6306 and replaced it with serial number 12932

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], ISI Engineer Date 6-05-2001  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-23-01 to 6-5-01, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 9685 "N" "I" Az 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 6-5-01

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JSIBUV0659 2. Code Class ASME SECTION III CLASS 2  
 3. Item Description 4" SOV VALVE  
 4. N-5 Package Number 2SI09-3 5. W.O. Number 2333124  
 6. Original Construction Code Edition 1974 EDITION & 1976 SUMMER ADDENDA  
 7. Original Installation Code Edition 1974 EDITION & 1975 WINTER ADDENDA  
 8. Work Description REPLACE VALVE INTERNALS, (MAIN DISC) DUE TO VALVE HAVING UNACCEPTABLE SLOW STROKING TIMES. REMOVED INTERNALS FROM SPARE VALVE SER. 7 / PO 60181395, AND INSTALLED IN THIS VALVE, (MAIN DISC SER NO. 55)

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure of the pressure retaining part. Replacement is for improving operability R.P. Indap 1/24/02

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION & 1976 SUMMER ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition 1974 EDITION & 1975 WINTER ADDENDA  
 14. ASME Section XI Code/Edition 1992 EDITION & 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
HC 1/24/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
HC 1/24/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

HC 1/24/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date

HC 1/24/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
MAIN DISC	300328-1	55	1G7615	

19. Planner Gerald Osmundson 1/24/02 Print Name GERALD OSMUNDSON  
Signature Date  
 20. ISI Engineer R.P. Indap 1/24/02 Print Name R. P. INDAP  
Signature Date  
 21. ANII R.G. Hogstrom 1-24-02 Print Name R.G. HOGSTROM  
Signature Date



# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 12/17/01  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2333124  
Address Work Order Number

3. Work Performed by APS Type Code Symbol Stamp None  
Name  
5801S. WINTERSBURG RD, TONOPAH, ARIZONA Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System SI, ASME SECTION III, CLASS 2

5. (a) Applicable Construction Code SECTION III CL 2 19 74 Edition, S,76 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
MAIN DISC	TARGET ROCK	55	NA	2JSIBUV0659	1979	Replacement	NO

7. Description of Work REPLACE VALVE INTERNALS WITH SPARE VALVE INTERNALS

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks REPLACED VALVE INTRENALS (MAIN DISC) DUE TO UNACCEPTABLE VALVE  
STROKING TIMES

W.O. 2333124

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R.L. BROWNING RLB Date 4/9/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 1-24-02 to 4-9-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. L. Browning  
Inspector's Signature

Commissions NB 9685 "ANIC" AZ 264  
National Board, State, Province, and Endorsements

Date 4-9-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2PSGEV026      2. Code Class ASME III, CLASS 2  
 3. Item Description 2" KEROTEST GLOBE VALVE  
 4. N-5 Package Number 2SG01-1A      5. W.O. Number 2336022  
 6. Original Construction Code Edition 1974 EDITION, SUMMER 1976 ADDENDA  
 7. Original Installation Code Edition 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Weld replacement of valve.

9.  ISI Flaw      NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME Sec. III boundary. The valve replacement is to correct seat wear.

11. Repair/Replacement Work Organization PVNGS maintenance department.  
 12. Replacement Item Construction or reconciled Code/Edition ASME III, CLASS 2, 1974 ED., S'76 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA


15. Preservice Inspection Required.       YES       NO  
DMG      01/22/02      If required, include a step in the W.O. to perform Preservice Inspection.  
Initial      Date


16. ASME Section XI Pressure Test Required       YES       NO  
DMG      01/22/02      If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial      Date


DMG      01/22/02      17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial      Date

DMG      01/22/02      18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial      Date      replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2PSGEV026	ARZ-D-215166-(2)	E522R-1-2	NA	634930-001

19. Planner       2-1-02      Print Name David Goodlet  
Signature      Date

20. ISI Engineer       2-1-02      Print Name Ramakant Indap  
Signature      Date

21. ANII       2-1-02      Print Name Robert Hogstrom  
Signature      Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 04/08/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 WO# 2336022  
Address Work Order Number

3. Work Performed by Palo Verde Nuclear Generating Station Type Code Symbol Stamp None  
Name  
 Authorization No. N/A  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 Expiration Date N/A  
Address

4. Identification of System SG - Feedwater system, wet layup.

5. (a) Applicable Construction Code ASME Class 2 19 74 Edition, S'76 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Valve	Kerotest	E522R-1-2	N/A	2PSGEV026	'84	Replacement	Yes

7. Description of Work Replacement of valve.

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure NOP psi Test Temp. NOT °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WO# 2336022 for disassembly, inspection and rework of 2" Kerotest valve to correct seat leakage.  
Valve replacement due to seat wear.

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R.L. Browning RLB ISI ENG Date 4-15-02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 2-1-02 to 4-15-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NS 9685 "ASIC" Az 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-15-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2PSIAV450 2. Code Class 2
3. Item Description SHUTDOWN HEAT EXCHANGER "A" TO FUEL POOL ISOLATION VALVE
4. N-5 Package Number 2SI07-3 5. W.O. Number 2370758
6. Original Construction Code Edition ASME SECT. III, CL 2 1974 EDITION W'75 ADD
7. Original Installation Code Edition ASME SECT. III, CL ~~2~~ <sup>2 RPS 211362</sup> 1974 EDITION W'75 ADD
8. Work Description REPLACE THE BONNET STUDS AND NUTS PER THE DISPOSITION OF DFWO 2364311

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Nickel plated carbon steel studs & nuts are being replaced with corrosion resistant material studs & nuts as a precaution.

11. Repair/Replacement Work Organization ARIZONA PUBLIC SERVICE
12. Replacement Item Construction or reconciled Code/Edition ASME SECT. III, CL 2 1974 EDITION W'75 ADD
13. Repair/Replacement Activity Construction Code/Edition ASME SECT. III, CL 2 1974 EDITION W'75 ADD
14. ASME Section XI Code/Edition ASME SECT. III, CL 2 1992 EDITION 92 ADD

15. Preservice Inspection Required.  YES  NO  
JD 02/08/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
JD 02/08/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- JD 02/08/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- JD 02/08/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/RCS NO.
#1 STUDS	77203-17		CODE - JBW	618364
#3 NUTS	72184-16		CODE - KKB	618364

19. Planner J. I. Davis 2-8-02 Print Name JAMES I. DAVIS  
Signature Date
20. ISI Engineer R.P. Indap 2/13/02 Print Name R.P. INDAP  
Signature Date
21. ANII R.G. Hogstrom 2-13-02 Print Name R.G. HOGSTROM  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 3-27-02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2370758  
Address Work Order Number

3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
Authorization No. N/A  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 Expiration Date N/A  
Address

4. Identification of System Safety Injection

5. (a) Applicable Construction Code ASME Sec III, Cl 2 19 74 Edition, W75 Addenda,          Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Valve	Borg-Warner	44697	1296	2PSIAV450	1979	Repaired	Yes
Bonnet Studs	N/A	N/A	N/A	2PSIAV450	2002	Replacement	No
Bonnet Nuts	N/A	N/A	N/A	2PSIAV450	2002	Replacement	No

7. Description of Work Replace the bonnet studs and nuts per the disposition of DFWO 2364311.

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks Work Order 2370758 replaced the bonnet studs and nuts to a non-corrosive material per the disposition to DFWO 2364311. This work was performed because of leakage and the valve cannot be isolated for gasket or packing replacement.

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. Forden, Consulting Met. Engineer Date 3/27/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 2-13-02 to 3-28-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. A. Johnson Commissions NB 9685 'ASIC' AZ 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 3-28-02



## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2PSIBV454 2. Code Class 2
3. Item Description SHUTDOWN HEAT EXCHANGER "A" TO FUEL POOL ISOLATION VALVE
4. N-5 Package Number 2SI07-3 5. W.O. Number 2370759
6. Original Construction Code Edition ASME SECT. III, CL 2 1974 EDITION W'75 ADD
7. Original Installation Code Edition ASME SECT. III, CL ~~2~~ <sup>2 RPI 2/13/02</sup> 1974 EDITION W'75 ADD
8. Work Description REPLACE THE BONNET STUDS AND NUTS PER THE DISPOSITION OF DFWO 2364311

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Nickel plated carbon steel studs & nuts are being replaced with corrosion resistant studs & nuts as a precaution. RPI 2/13/02

11. Repair/Replacement Work Organization ARIZONA PUBLIC SERVICE
12. Replacement Item Construction or reconciled Code/Edition ASME SECT. III, CL 2 1974 EDITION W'75 ADD
13. Repair/Replacement Activity Construction Code/Edition ASME SECT. III, CL 2 1974 EDITION W'75 ADD
14. ASME Section XI Code/Edition ASME SECT. III, CL 2 1992 EDITION 92 ADD

15. Preservice Inspection Required.  YES  NO  
JD 02/08/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
JD 02/08/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

- JD 02/08/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date

- JD 02/08/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
<u>1 studs</u>	<u>77203-17</u>		<u>CODE-JBW</u>	<u>618366-0002</u>
<u>nuts 3(51EA)</u>	<u>72184-16</u>		<u>CODE-KKB</u>	<u>618366-0004</u>
<u>nuts 3(9EA)</u>	<u>72184-16</u>		<u>CODE-1YH</u>	<u>618366-0004</u>

19. Planner [Signature] 2-8-02 Print Name JAMES I. DAVIS  
Signature Date
20. ISI Engineer [Signature] 2/13/02 Print Name R.P. INDAP  
Signature Date
21. ANII [Signature] 2-13-02 Print Name R.G. HOGSTROM  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 4-5-02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2370759  
Address Work Order Number

3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
Authorization No. N/A  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 Expiration Date N/A  
Address

4. Identification of System Safety Injection

5. (a) Applicable Construction Code ASME Sec III, CI 2 19 74 Edition, W75 Addenda,          Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Valve	Borg-Warner	44698	1297	2PSIBV454	1979	Repaired	Yes
Bonnet Studs	N/A	N/A	N/A	2PSIBV454	2002	Replacement	No
Bonnet Nuts	N/A	N/A	N/A	2PSIBV454	2002	Replacement	No

7. Description of Work Replace the bonnet studs and nuts per the disposition of DFWO 2364311.

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

## FORM NIS-2 (Back)

9. Remarks Work Order 2370759 replaced the bonnet studs and nuts to a non-corrosive material per the disposition to DFWO 2364311. This work was performed because of leakage and the valve cannot be isolated for gasket or packing replacement.

### CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. P. Pindap, Consulting Metallurgical Engineer Date 4/5/02  
Owner or Owner's Designee, Title

### CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 2-13-02 to 4-5-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. P. Pindap Commissions NB 9685 ANIC AZ 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-5-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JSIAFE0338 2. Code Class ASME III CLASS 2 1974 w/W75  
 3. Item Description Containment Spray Pump "A" Discharge Flow Element  
 4. N-5 Package Number 2-SI08-03 5. W.O. Number 2384999  
 6. Original Construction Code Edition ASME Sect. III Class 2 1974 W/ Winter '75 Addenda  
 7. Original Installation Code Edition ASME Sect. III Class 2 1974 W/ Winter '75 Addenda  
 8. Work Description Remove flow element and approximately 2 foot of upstream piping, install new flange, spool, and annubar IAW DMWO 2316467

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Replacement is IAW DMWO 2316467. Mod. is to replace existing flow orifice and replace with annubar to minimize head loss. RPP 2/12/02

11. Repair/Replacement Work Organization Arizona Public Service Company  
 12. Replacement Item Construction or reconciled Code/Edition ASME Sect. III Class 2 1974 W/ Winter '75 Addenda  
 13. Repair/Replacement Activity Construction Code/Edition ASME Sect III Cl 2 1974 w/ W '75 Ad, Code Case N-416-1  
 14. ASME Section XI Code/Edition 1992 Edition and '92 Addenda

15. Preservice Inspection Required.  YES  NO  
ASW 2/12/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
ASW 2/12/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- ASW 2/12/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- ASW 2/12/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
Flanged Pipe Section		13689.2.1		00616995-0001
Annubar Flow Elemt		13689.1.1		00616995-0001
10" FLANGE			AZP	00616994-0001

19. Planner Glenn E. Moore 2/12/02 Print Name Glenn E. Moore  
Signature Date
20. ISI Engineer R.P. Indap 2/12/02 Print Name R.P. INDAP  
Signature Date
21. ANII Robert Hogstrom 2-12-02 Print Name Robert Hogstrom  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/08/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 1  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2384999  
Address Work Order Number

3. Work Performed by Arizona Public Service Company Type Code Symbol Stamp None  
Name  
P.O. Box 53999, Phoenix, Arizona 85354-7529 Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System Safety Injection System (SI) ASME Sect. III Class 2

5. (a) Applicable Construction Code ASME III CL2 19 74 Edition, W'75 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 74 Edition, W'75 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Flanged Pipe Section	Dietrich Standard	13689.2.1	N/A	2JSIAFE0338	2002	Replacement	Yes
Annubar Flow Elemt	Dietrich Standard	13689.1.1	N/A	2JSIAFE0338	2002	Replacement	Yes

7. Description of Work Remove flow element and section of pipe and install new spool and annubar element

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks Flow element 2JSIAFE0338 to be removed along with upstream flange and approximately 2 feet of piping. This will be replaced with a new flange and spool assembly containing an annubar element.

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *R. J. Foyt*, Consulting Metallurgical Engineer Date 4-5-02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 2-12-02 to 4-5-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*R. J. Foyt*  
Inspector's Signature

Commissions NB 9685 ANIC AZ 264  
National Board, State, Province, and Endorsements

Date 4-5-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2PSGEV642 2. Code Class ASME III Class 2

3. Item Description 8" Anchor Darling Check Valve

4. N-5 Package Number 2SG01-1A 5. W.O. Number wo# 2403895

6. Original Construction Code Edition ASME III Class 2, 1974 Ed., Summer 1975 Add.

7. Original Installation Code Edition ASME III Class 2, 1974 Ed., Winter 1975 Add.

8. Work Description Disassemble check valve for inspection. Weld build-up to the 8 mil deep scratch in pressure seal gasket sealing surface caused during disassembly. Repair of damage caused by debri (1/8" dia by 1/8" deep approx.) on bonnet.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Damage is during disassembly. <sup>(the scratch)</sup> No service induced damage. Repaired 4/5/02. The damage on the bonnet is due to debri caught between body & bonnet.

11. Repair/Replacement Work Organization APS site maintenance group

12. Replacement Item Construction or reconciled Code/Edition ASME III Class 2, 1974 Ed., S'75 Add.

13. Repair/Replacement Activity Construction Code/Edition ASME III Class 2, 1974 Ed., W'75 Add.

14. ASME Section XI Code/Edition 1992 Edition and 1992 Addenda

15. Preservice Inspection Required.  YES  NO  
DMG 04/05/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 04/05/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

DMG 04/05/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date

DMG 04/05/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2PSGEV642	N/A	2N1797	2176F SN12	N/A

19. Planner David Goodlet 4-5-02 Print Name David Goodlet  
Signature Date

20. ISI Engineer Ramakant Indap 4/5/02 Print Name Ramakant Indap  
Signature Date

21. ANII Robert Hogstrom 4-5-02 Print Name Robert Hogstrom  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 04/05/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 WO# 2403895  
Address Work Order Number

3. Work Performed by Palo Verde Nuclear Generating Station Type Code Symbol Stamp None  
Name  
 Authorization No. N/A  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 Expiration Date N/A  
Address

4. Identification of System SG - feedwater line

5. (a) Applicable Construction Code ASME Class 2 19 74 Edition, S'1975 Addenda,          Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Check Valve	Anchor/Darling	2N1797	N/A	2PSGEV642	'80	Repaired	Yes

7. Description of Work Weld build-up to scratch in valve body & bonnet caused during disassembly.

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure          psi Test Temp.          °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



# FORM NIS-2 (Back)

9. Remarks WO# 2403895 for check valve 2PSGEV642. Weld build-up to valve body & bonnet. Debris in valve caused damage during disassembly. Approx 8 mil deep scratch in gasket sealing surface and approx. 1/8" deep depression x 1/8" diameter in bonnet.

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. Phelan, Consulting Metallurgical Engineer Date 4/10/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 4-5-02 to 4-10-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. Phelan  
Inspector's Signature

Commissions NS 9685 "ANIC" Az 264  
National Board, State, Province, and Endorsements

Date 4-10-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2MDGAE05 2. Code Class ASME III, CLASS 3  
 3. Item Description DIESEL GENERATOR JACKET WATER COOLER  
 4. N-5 Package Number 2DG01-2 5. W.O. Number 2420356  
 6. Original Construction Code Edition ASME SECTION III, CLASS 3 1974, SUMMER 1976 ADDENDA  
 7. Original Installation Code Edition ASME SECTION III CLASS 3 1974, WINTER 1975 ADDENDA  
 8. Work Description Weld build up of corroded areas on the Jacket Water Cooler end cover.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Weld build up required due to exceeding the minimum wall thickness of cover due to corrosion caused by holiday in the coatings. Repaired areas to be coated with belzona, which has been proven to protect the surface of the coolers.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION SUMMER 1976 ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition SECTION III 1974 EDITION, WINTER 1975 ADDENDA  
 14. ASME Section XI Code/Edition 1992 EDITION, 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
APX 3/22/2002 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
APX 3/22/2002 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

APX 3/22/2002 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
APX 3/22/2002 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
CHANNEL COVER	4-500-19-515-002	N/A	N/A	N/A

19. Planner [Signature] 3/22/2002 Print Name Alana E. Moore  
Signature Date  
 20. ISI Engineer [Signature] 3/23/02 Print Name R. P. INDAP  
Signature Date  
 21. ANII [Signature] 3-22-02 Print Name R. G. HOGLSTROM  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 03/21/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address
2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2420356  
Address Work Order Number
3. Work Performed by ARIZONA PUBLIC SERVICE Type Code Symbol Stamp None  
Name  
5801 S. Wintersberg Rd, Tonopah, Az 85354-7529 Authorization No. N/A  
Address Expiration Date N/A
4. Identification of System Diesel Generator (DG)
5. (a) Applicable Construction Code ASME III CLASS 3 19 74 Edition, S'76 Addenda,        Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 92 Addenda
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
dg jacket water cooler	American Standard	9D702	33117	2MDGAE05	1979	Repaired	Yes

7. Description of Work Weld build up of corroded channel head.
8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1
- Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WORK ORDER # 2420356

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed PP Podap, Consulting Metallurgical Engineer Date 3/37/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-22-02 to 3-27-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bob L. Ferguson Commissions NB 9685 ANIC AZ 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 3-27-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2MDGAE04 2. Code Class ASME III, CLASS 3
3. Item Description DIESEL GENERATOR LUBE OIL COOLER
4. N-5 Package Number 2DG01-2 5. W.O. Number 2420360
6. Original Construction Code Edition ASME SECTION III, CLASS 3 1974, SUMMER 1976 ADDENDA
7. Original Installation Code Edition ASME SECTION III CLASS 3 1974, WINTER 1975 ADDENDA
8. Work Description Weld build up of corroded areas on the Lube Oil Cooler end cover.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Weld build up required due to exceeding the minimum wall thickness of cover due to corrosion caused by holiday in the coatings. Repaired areas to be coated with belzona, which has been proven to protect the surface of the coolers.

11. Repair/Replacement Work Organization APS

12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION SUMMER 1976 ADDENDA

13. Repair/Replacement Activity Construction Code/Edition SECTION III 1974 EDITION, WINTER 1975 ADDENDA

14. ASME Section XI Code/Edition 1992 EDITION, 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
If required, include a step in the W.O. to perform Preservice Inspection.

APD 3/22/02  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
If required, include a step in the W.O. for ISI & ANII Inspection.

APD 3/22/02  
Initial Date

APD 3/22/02  
Initial Date

17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.

18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
CHANNEL COVER	4-500-19-515-002	N/A	N/A	N/A

19. Planner [Signature] 3/22/02 Print Name Glenn E. [unclear]  
Signature Date

20. ISI Engineer [Signature] 3/22/02 Print Name R. P. Indap  
Signature Date

21. ANII [Signature] 3-22-02 Print Name R. G. HOGSTROM  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 03/21/02  
Name

P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name

5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2420360  
Address Work Order Number

3. Work Performed by ARIZONA PUBLIC SERVICE Type Code Symbol Stamp None  
Name

5801 S. Wintersberg Rd, Tonopah, Az 85354-7529 Authorization No. N/A  
Address

Expiration Date N/A

4. Identification of System Diesel Generator (DG)

5. (a) Applicable Construction Code ASME III CLASS 3 19 74 Edition, S'76 Addenda, \_\_\_\_\_ Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 92 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
dg lube oil cooler	American Standard	9D2704	33118	2MDGAE04	1979	Repaired	Yes

7. Description of Work Weld build up of corroded channel head

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1

Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WORK ORDER # 2420360

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. P. Indigo, (consulting) Metallurgical Eng. Date 3/27/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-22-02 to 3-27-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

R. P. Indigo Commissions NS 9685 ANIC AZ 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 3-27-02

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2MDGBE04 2. Code Class ASME SECTION III CLASS 3  
 3. Item Description DIESEL LUBE OIL COOLER  
 4. N-5 Package Number 2DG02-8 5. W.O. Number 2420361  
 6. Original Construction Code Edition ASME SECTION III, CLASS 3, 1974, SUMMER 1976 ADD  
 7. Original Installation Code Edition ASME III, CLASS 3, 1974 WINTER, 1975 ADD  
 8. Work Description Weld build up of corroded areas on the Lube Oil cooler inlet/outlet covers.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
Weld build up required due to exceeding minimum wall thickness of cover due to corrosion caused by holiday in coatings, repair areas to be coated with Belzona which has been proven to protect the surfaces of the coolers.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition 1974 EDITION SUMMER 1976 ADDENDA  
 13. Repair/Replacement Activity Construction Code/Edition 1974 EDITION WINTER 1975 ADDENDA  
 14. ASME Section XI Code/Edition 1992 EDITION 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
AS 3/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
AS 3/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

AS 3/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
AS 3/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
CHANNEL COVER	4-50019-515-002			

19. Planner Glenn E Moore 2/21/02 Print Name Glenn E Moore  
Signature Date  
 20. ISI Engineer R. P. Indap 3/29/02 Print Name R. P. INDAP  
Signature Date  
 21. ANII R.G. Houston 3-29-02 Print Name R.G. HOUSTON  
Signature Date



# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 03/29/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address
2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2420361  
Address Work Order Number
3. Work Performed by ARIZONA PUBLIC SERVICE Type Code Symbol Stamp None  
Name  
5801 S. Wintersberg Rd, Tonopah, Az 85354-7529 Authorization No. N/A  
Address Expiration Date N/A
4. Identification of System Diesel Generator (DG)
5. (a) Applicable Construction Code ASME III CLASS 3 19 74 Edition, W'75 Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 92 Addenda
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
dg lube oil cooler	American Standard	8C2804	31981	2MDGAE04	1978	Repaired	Yes

7. Description of Work WELD REPAIR OF THE CORRODED CHANNEL HEAD ( COVER).
8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks WORK ORDER #2420360 - 4 2420361  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.  
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Alan Morrow ISI Engineer Date 4/6/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 3-24-02 to 4-6-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 2685 ANIC Az 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-6-02

# ASME SECTION XI - REPAIR/REPLACEMENT

Page 1 of 14

1. Component ID 2JSGEPSV0694 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1315 PSIG  
 4. N-5 Package Number 2SG02-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date  
DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0694	N/A	BS-08609	N/A	00632383-17C1

19. Planner *David Goodlet* 1-29-02 Print Name DAVID GOODLET  
Signature Date  
 20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date  
 21. ANII *Robert Hogstrom* 1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JSGEPSV0559 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1315 PSIG  
 4. N-5 Package Number 2SG02-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.
9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_
10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA
15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0559	N/A	BS-08613	N/A	00632387-001




19. Planner  1-29-02 Print Name DAVID GOODLET  
Signature Date
20. ISI Engineer  1-31-02 Print Name RAMAKANT INDAP  
Signature Date
21. ANII  1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JSGEPSV0560 2. Code Class ASME III, CLASS 2
3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1290 PSIG
4. N-5 Package Number 2SG02-1A 5. W.O. Number 2420372
6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA
7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA
8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.
9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_
10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.
11. Repair/Replacement Work Organization APS
12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.
13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.
14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/RS NO.
2JSGEPSV0560	N/A	BS-08575	N/A	2420372-001

19. Planner  1-29-02 Print Name DAVID GOODLET  
Signature Date
20. ISI Engineer  1-31-02 Print Name RAMAKANT INDAP  
Signature Date
21. ANII  1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

Page 4 of 14

1. Component ID 2JSGEPSV0561 2. Code Class ASME III, CLASS 2
3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1250 PSIG
4. N-5 Package Number 2SG02-1A 5. W.O. Number 2420372
6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA
7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA
8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.
9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_
10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.
11. Repair/Replacement Work Organization APS
12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.
13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.
14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0561	N/A	BS-08569	N/A	BO 631950-0001

19. Planner *David Goodlet* 1-29-02 Print Name DAVID GOODLET  
Signature Date
20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date
21. ANII *Robert Hogstrom* 1-31-02 Print Name ROBERT HOGSTROM  
Signature Date




# ASME SECTION XI - REPAIR/REPLACEMENT

Page 5 of 14

1. Component ID 2JSGEPSV0555 2. Code Class ASME III, CLASS 2
3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1290 PSIG
4. N-5 Package Number 2SG02-1A 5. W.O. Number 2420372
6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA
7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA
8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.
9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_
10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.
11. Repair/Replacement Work Organization APS
12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.
13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.
14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0555	N/A	BT-01676	N/A	02632401-001

19. Planner  1-29-2002 Print Name DAVID GOODLET  
Signature Date
20. ISI Engineer  1-31-02 Print Name RAMAKANT INDAP  
Signature Date
21. ANII  1-31-02 Print Name ROBERT HOGSTROM  
Signature Date





# ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JSGEPSV0691 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1315 PSIG  
 4. N-5 Package Number 2SG01-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date  
DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0691	N/A	BS-08624	N/A	DC 632385-001

19. Planner *David M. Goodlet* 1-29-2002 Print Name DAVID GOODLET  
Signature Date  
 20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date  
 21. ANII *Robert Hogstrom* 1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JSGEPSV0576 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1315 PSIG  
 4. N-5 Package Number 2SG01-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date  
DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0576	N/A	BS-08627	N/A	02652397-001

19. Planner *David Goodlet* 1-29-2002 Print Name DAVID GOODLET  
Signature Date  
 20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date  
 21. ANII *Robert Hogstrom* 1-29-02 Print Name ROBERT HOGSTROM  
Signature Date

## ASME SECTION XI - REPAIR/REPLACEMENT

Page 9 of 14

1. Component ID 2JSGEPSV0578 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1290 PSIG  
 4. N-5 Package Number 2SG01-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS

12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.

13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.

14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date  
DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/RQS-NO.
2JSGEPSV0578	N/A	BS-08601	N/A	<u>20631944-DE 1</u>

19. Planner  1-29-2002 Print Name DAVID GOODLET  
Signature Date
20. ISI Engineer  1-31-02 Print Name RAMAKANT INDAP  
Signature Date
21. ANII  1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

Page 10 of 14

1. Component ID 2JSGEPSV0579      2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1250 PSIG  
 4. N-5 Package Number 2SG01-1A      5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw      NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.       YES       NO  
DMG      01/29/02      If required, include a step in the W.O. to perform Preservice Inspection.  
Initial      Date

16. ASME Section XI Pressure Test Required       YES       NO  
DMG      01/29/02      If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial      Date  
DMG      01/29/02      17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial      Date  
DMG      01/29/02      18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial      Date      replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0579	N/A	BS-08571	N/A	DLG 32407-001

19. Planner *David M Goodlet*      1-29-2002      Print Name DAVID GOODLET  
Signature      Date  
 20. ISI Engineer *Ramakant Indap*      1-31-02      Print Name RAMAKANT INDAP  
Signature      Date  
 21. ANII *Robert Hogstrom*      1-31-02      Print Name ROBERT HOGSTROM  
Signature      Date

## ASME SECTION XI - REPAIR/REPLACEMENT

Page 11 of 14

1. Component ID 2JSGEPSV0692 2. Code Class ASME III, CLASS 2
3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1315 PSIG
4. N-5 Package Number 2SG01-1A 5. W.O. Number 2420372
6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA
7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA
8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.
9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
Report Number \_\_\_\_\_
10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.
11. Repair/Replacement Work Organization APS
12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.
13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.
14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date
16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date
- DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date
- DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/RCS NO.
2JSGEPSV0692	N/A	BS-08578	N/A	00632381-0001

19. Planner *David M Goodlet* 1-29-2002 Print Name DAVID GOODLET  
Signature Date
20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date
21. ANII *Robert Hogstrom* 1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

Page 12 of 14

1. Component ID 2JSGEPSV0574      2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1290 PSIG <sup>1290</sup> <sub>2-1-02</sub>  
 4. N-5 Package Number 2SG01-1A      5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw      NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.       YES       NO  
DMG      01/29/02      If required, include a step in the W.O. to perform Preservice Inspection.  
Initial      Date

16. ASME Section XI Pressure Test Required       YES       NO  
DMG      01/29/02      If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial      Date  
DMG      01/29/02      17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial      Date  
DMG      01/29/02      18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial      Date      replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0574	N/A	BS-08582	N/A	02632383-1021

19. Planner David Goodlet 1-29-2002      Print Name DAVID GOODLET  
Signature      Date  
 20. ISI Engineer Ramakant Indap 1-31-02      Print Name RAMAKANT INDAP  
Signature      Date  
 21. ANII Robert Hogstrom 2-1-02      Print Name ROBERT HOGSTROM  
Signature      Date

# ASME SECTION XI - REPAIR/REPLACEMENT

Page 13 of 14

1. Component ID 2JSGEPSV0573 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1290 PSIG  
 4. N-5 Package Number 2SG01-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date

DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or replacement items.  
Initial Date

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0573	N/A	BS-08574	N/A	DEG 31948-0001

19. Planner *David Goodlet* 1-29-02 Print Name DAVID GOODLET  
Signature Date  
 20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date  
 21. ANII *Robert Hogstrom* 1-31-02 Print Name ROBERT HOGSTROM  
Signature Date

# ASME SECTION XI - REPAIR/REPLACEMENT

Page 14 of 14

1. Component ID 2JSGEPSV0572 2. Code Class ASME III, CLASS 2  
 3. Item Description MAIN STEAM SAFETY VALVE; DRESSER 3707RA-RT25; 1250 PSIG  
 4. N-5 Package Number 2SG01-1A 5. W.O. Number 2420372  
 6. Original Construction Code Edition ASME III CLASS 2, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 2, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description Replacement of main steam safety valve, with reconditioned spare, per Engineering direction following on-line pressure testing.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
No failure in the ASME III pressure boundary. Spare valve is a like-for-like replacement and is being replaced based upon pressure testing.

11. Repair/Replacement Work Organization APS  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 2, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 2, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
DMG 01/29/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date  
DMG 01/29/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
DMG 01/29/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JSGEPSV0572	N/A	BY-14539	N/A	00632404-0001

19. Planner *David Goodlet* 1-29-02 Print Name DAVID GOODLET  
Signature Date  
 20. ISI Engineer *Ramakant Indap* 1-31-02 Print Name RAMAKANT INDAP  
Signature Date  
 21. ANII *Robert Hogstrom* 1-31-02 Print Name ROBERT HOGSTROM  
Signature Date



# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 01/29/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 3  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2420372  
Address Work Order Number

3. Work Performed by PVNGS Maintenance Dept. Type Code Symbol Stamp None  
Name  
Authorization No. N/A  
5801 S. Wintersburg Rd., tONOPAH, Az. 85354-7529 Expiration Date N/A  
Address

4. Identification of System SG - Main Steam

5. (a) Applicable Construction Code ASME III Class 2 19 74 Edition, S'75 Addenda, 1711 Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Dresser	BY-14539	N/A	2JSGEPSV572	1991	Replacement	Yes
Safety Valve	Dresser	BS-08574	N/A	2JSGEPSV573	1978	Replacement	Yes
Safety Valve	Dresser	BS-08582	N/A	2JSGEPSV574	1978	Replacement	Yes
Safety Valve	Dresser	BS-08578	N/A	2JSGEPSV692	1978	Replacement	Yes
Safety Valve	Dresser	BS-08571	N/A	2JSGEPSV579	1978	Replacement	Yes
Safety Valve	Dresser	BS-08601	N/A	2JSGEPSV578	1980	Replacement	Yes
Safety Valve	Dresser	BS-08627	N/A	2JSGEPSV576	1981	Replacement	Yes

7. Description of Work Replace main steam safety valves with reconditioned spares.

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 01/29/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 2 of 3  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 2420372  
Address Work Order Number

3. Work Performed by PVNGS Maintenance Dept. Type Code Symbol Stamp None  
Name  
Authorization No. N/A  
5801 S. Wintersburg Rd., tONOPAH, Az. 85354-7529 Expiration Date N/A  
Address

4. Identification of System SG - Main Steam

5. (a) Applicable Construction Code ASME III Class 2 19 74 Edition, S'75 Addenda, 1711 Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Dresser	BS-08624	N/A	2JSGEPSV691	1981	Replacement	Yes
Safety Valve	Dresser	BS-08572	N/A	2JSGEPSV554	1978	Replacement	Yes
Safety Valve	Dresser	BT-01676	N/A	2JSGEPSV555	1979	Replacement	Yes
Safety Valve	Dresser	BS-08569	N/A	2JSGEPSV561	1978	Replacement	Yes
Safety Valve	Dresser	BS-08575	N/A	2JSGEPSV560	1978	Replacement	Yes
Safety Valve	Dresser	BS-08613	N/A	2JSGEPSV559	1980	Replacement	Yes
Safety Valve	Dresser	BS-08609	N/A	2JSGEPSV694	1980	Replacement	Yes

7. Description of Work Replace main steam safety valves with reconditioned spares.

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure \_\_\_\_\_ psi Test Temp. \_\_\_\_\_ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks Work Order #2420372 for the replacement of the main steam safety valves 2JSGEPSV0572, 573, 574, 692, 579, 578, 576, 691, 554, 555, 561, 560, 559 & 694. These 14 valves were selected by maintenance engineering following on-line set pressure testing.

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Alan Monow ISF Engineer Date 4/15/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSB CT of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 1-31-02 to 4-15-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NS 9685 "AWIC" Az 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date April 15, 2002

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JRCEPSV0200      2. Code Class ASME III, CLASS 1  
 3. Item Description PRESSURIZER SAFETY VALVE; DRESSER 31709N; 2460 PSIG  
 4. N-5 Package Number 2RC03-2      5. W.O. Number 2420482  
 6. Original Construction Code Edition ASME III CLASS 1, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 1, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description REPLACE VALVE PER W.O.2420482

9.  ISI Flaw      NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
THE VALVE BEING ROTATED TO FACILITATE VENDOR TESTING. THE REPLACEMENT VALVE IS PART OF ROUTINE MAINTENANCE SN#BS08614.

11. Repair/Replacement Work Organization ARIZONA PUBLIC SERVICE  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 1, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 1, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.       YES       NO  
MBN      01/30/02      If required, include a step in the W.O. to perform Preservice Inspection.  
Initial      Date

16. ASME Section XI Pressure Test Required       YES       NO  
MBN      01/30/02      If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial      Date  
MBN      01/30/02      17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial      Date  
MBN      01/30/02      18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial      Date      replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JRCEPSV0200	N/A	BS-08614	N/A	

19. Planner *Michael B. Newell*      2-1-02      Print Name MICHAEL B. NEWELL  
Signature      Date  
 20. ISI Engineer *Ramakant Indap*      2-1-02      Print Name RAMAKANT INDAP  
Signature      Date  
 21. ANII *Robert Hogstrom*      2-1-02      Print Name ROBERT HOGSTROM  
Signature      Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/01/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 W.O.2420482  
Address Work Order Number

3. Work Performed by ARIZONA PUBLIC SERVICE Type Code Symbol Stamp None  
Name  
Authorization No. N/A  
5801 S. WINTERSBURG RD TONOPAH AZ 85354 Expiration Date N/A  
Address

4. Identification of System RC ASME SECTION III CLASS 1

5. (a) Applicable Construction Code SEC III CLASS 1 19 74 Edition, 75'S Addenda,          Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
PSV-VALVE	DRESSER	BS08614	N/A	2JRCEPSV200	1979	Replacement	Yes

7. Description of Work VALVE BEING REPLACE/ROTATED AS PART OF ROUTINE MAINTENANCE

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure 2460 psi Test Temp. 653 °F  
4/13/02 4/13/02

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

# FORM NIS-2 (Back)

9. Remarks W.O. 2420482 VALVE BEING REPLACE AS PART OF ROUTINE MAINTENANCE  
(SN#BS08614)..  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan Mamon ISI Engineer* Date *4/13/02*  
Owner or Owner's Designee, Title

*RL BROWNING RLB ISI ENG* *4-15-02*

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 2-1-02 to 4-15-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Alan Mamon* Commissions *NB 9685 "AMIC" AZ 264*  
Inspector's Signature National Board, State, Province, and Endorsements

Date *4-15-02*

## ASME SECTION XI - REPAIR/REPLACEMENT

1. Component ID 2JRCEPSV0201 2. Code Class ASME III, CLASS 1  
 3. Item Description PRESSURIZER SAFETY VALVE; DRESSER 31709N; 2460 PSIG  
 4. N-5 Package Number 2RC03-2 5. W.O. Number 2420483  
 6. Original Construction Code Edition ASME III CLASS 1, 1974 EDITION, SUMMER 1975 ADDENDA  
 7. Original Installation Code Edition ASME III CLASS 1, 1974 EDITION, WINTER 1975 ADDENDA  
 8. Work Description REPLACE VALVE PER W.O.2420483.

9.  ISI Flaw NDE Method of Flaw Detection \_\_\_\_\_  
 Report Number \_\_\_\_\_

10. Evaluation of the suitability of this work as per the requirements of IAW-4150.  
THE VALVE BEING ROTATED TO FACILITATE VENDOR TESTING. THE REPLACEMENT VALVE IS PART OF ROUTINE MAINTENANCE SN#BS08565.

11. Repair/Replacement Work Organization ARIZONA PUBLIC SERVICE  
 12. Replacement Item Construction or reconciled Code/Edition ASME III CLASS 1, 1974 ED., S'75 ADD.  
 13. Repair/Replacement Activity Construction Code/Edition ASME III CLASS 1, 1974 ED., W'75 ADD.  
 14. ASME Section XI Code/Edition 1992 EDITION AND 1992 ADDENDA

15. Preservice Inspection Required.  YES  NO  
MBN 01/30/02 If required, include a step in the W.O. to perform Preservice Inspection.  
Initial Date

16. ASME Section XI Pressure Test Required  YES  NO  
MBN 01/30/02 If required, include a step in the W.O. for ISI & ANII Inspection.  
Initial Date  
MBN 01/30/02 17. Include a step in the W.O. to complete NIS-2 Form prior to releasing the component.  
Initial Date  
MBN 01/30/02 18. Include a step in the W.O. to record below all applicable numbers for repaired or  
Initial Date replacement items.

ITEM I.D.	PART NO.	SERIAL NO.	HEAT NO.	MR/ROS NO.
2JRCEPSV0201	N/A	BS-08614 <del>BS-08665</del> 08565 BV 4/12/02	N/A	

19. Planner Michael B. Newell 2-6-02 Print Name MICHAEL B. NEWELL  
Signature Date  
 20. ISI Engineer Ramakant Indap 2-1-02 Print Name RAMAKANT INDAP  
Signature Date  
 21. ANII Robert Hogstrom 2-1-02 Print Name ROBERT HOGSTROM  
Signature Date

# FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner Arizona Public Service Company, et. al. Date 02/01/02  
Name  
P.O. Box 53999, Phoenix, Arizona 85072-2034 Sheet 1 of 2  
Address

2. Plant Palo Verde Nuclear Generating Station Unit 2  
Name  
5801 S. Wintersburg Rd., Tonopah, Arizona 85354-7529 W.O. 2420483  
Address Work Order Number

3. Work Performed by Arizona Public Service Type Code Symbol Stamp None  
Name  
5801 S. Wintersburg Rd Tonopah AZ 85354 Authorization No. N/A  
Address Expiration Date N/A

4. Identification of System RC ASME Section III Class 1

5. (a) Applicable Construction Code Sec III Class 1 19 74 Edition, 75'S Addenda, \_\_\_\_\_ Code Case  
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 92 Edition, 1992 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Item	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired or Replacement	ASME Code Stamped (Yes or No)
PSV-Valve	Dresser	<del>BS-08665</del>	N/A	2JRCEPSV201	1978	Replacement	Yes
		<u>BS-08565</u>					
		<u>BSV 4/12/02</u>					

7. Description of Work \_\_\_\_\_

8. Test Conducted: Hydrostatic  Pneumatic  Nominal Operating Pressure  Exempt  N-416-1   
 Other  Pressure 2460 psi Test Temp. 653 °F  
4/13/02 4/13/02

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



# FORM NIS-2 (Back)

9. Remarks W.O. 2420483 VALVE BEING REPLACE AS PART OF ROUTINE MAINTENANCE  
(SN#BS08565).. BV 4/12/02

BS08665  
BS-08565

## CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI.  
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Alan Monow ISE Engineer Date 4/13/02  
RL Browning 151 ENR 4/15/02  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arizona and employed by HSBI & I CO. of Hartford, Connecticut, have inspected the components described in this Owner's Report during the period 2-1-02 to 4-15-02, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

RL Browning Commissions NS 9685 "AWIC" Az 264  
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-15-02