

April 5, 1988

Docket No. 50-397

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
P.O. Box 968
3000 George Washington Way
Richland, Washington 99352

DISTRIBUTION

Docket File
NRC LPDRs
GMHolahan
RSamworth
JBradfute
DHagan
EJordan
JPartlow
TBarnhart (4)
JLee

Wanda Jones
EButcher
ACRS (10)
GPA/PA
ARM/LFMB
Region V (4)
PD5 Plant File
Review Branch

Dear Mr. Sorensen:

SUBJECT: APPLICATION FOR AMENDMENT REGARDING SINGLE LOOP OPERATION
(GOL-88-053) (TAC NO. 67538)

Enclosed for your information is a Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing. The notice is related to your request dated March 7, 1988 to permit the operation of WNP-2 up to a power level of 75% with one recirculation loop operating, to the design burn-up of the reload fuel of 35,000 MWD/MT bundle average.

Sincerely,

original signed by Robert Samworth

Robert B. Samworth, Senior Project Manager
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosures:

1. Amendment No. to Facility
Operating License No. NPF-21
2. Safety Evaluation

cc w/enclosures:
See next page

*Form okay with
change on p. 1 of NPF-21
[Signature]
4/1/88*

DRSP/PDV
JLee
03/24/88

DRSP/PDV
RSamworth/rl
03/ /88

OGC
03/ /88

DRSP/PDV
GM Knighton
4/5/88

OFFICIAL RECORD COPY

8804130314 880405
PDR ADDCK 05000397
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

April 5, 1988

Docket No. 50-397

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
P.O. Box 968
3000 George Washington Way
Richland, Washington 99352

Dear Mr. Sorensen:

SUBJECT: APPLICATION FOR AMENDMENT REGARDING SINGLE LOOP OPERATION
(GOL-88-053) (TAC NO. 67538)

Enclosed for your information is a Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing. The notice is related to your request dated March 7, 1988 to permit the operation of WNP-2 up to a power level of 75% with one recirculation loop operating, to the design burn-up of the reload fuel of 35,000 MWD/MT bundle average.

Sincerely,

A handwritten signature in cursive script, appearing to read "Robert B. Samworth".

Robert B. Samworth, Senior Project Manager
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosures:

1. Amendment No. to Facility
Operating License No. NPF-21
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. G. C. Sorensen, Manager
Washington Public Power Supply System

WPPSS Nuclear Project No. 2
(WNP-2)

cc:

Nicholas S. Reynolds, Esq.
Bishop, Cook, Purcell
& Reynolds
1400 L Street NW
Washington, D.C. 20005-3502

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Mr. G. E. Doupe, Esquire
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99532

Chairman
Benton County Board of Commissioners
Prosser, Washington 99350

Mr. Curtis Eschels, Chairman
Energy Facility Site Evaluation Council
Mail Stop PY-11
Olympia, Washington 98504

Mr. P. L. Powell, Licensing Manager
Washington Public Power Supply System
P. O. Box 968, MD 956B
Richland, Washington 99352

Mr. A. Lee Oxsen
Assistant Managing Director for Operations
Washington Public Power Supply System
P. O. Box 968, MD 1023
Richland, WA 99352

Mr. R. B. Glasscock, Director
Licensing and Assurance
Washington Public Power Supply System
P. O. Box 968, MD 280
Richland, Washington 99352

Mr. C. M. Powers
WNP-2 Plant Manager
Washington Public Power Supply System
P. O. Box MD 927M
Richland, Washington 99352

UNITED STATES NUCLEAR REGULATORY COMMISSIONWASHINGTON PUBLIC POWER SUPPLY SYSTEMDOCKET NO. 50-397NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE AND OPPORTUNITY FOR HEARING

The United States Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-21, issued to Washington Public Power Supply System (the licensee), for operation of the Washington Nuclear Project 2 located in Benton County, Washington. The request for amendment was submitted by letter dated March 7, 1988 (Reference GOL-88-053).

The amendment would allow the operation of WNP-2 up to a power level of 75% with one recirculation loop operating to the design burnup of the reload fuel of 35,000 MWD/MT bundle average.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

By May , 1988, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for hearing and petition for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings"

in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition, without requesting leave of the Board, up to fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter and the bases for

each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 325-6000 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to George W. Knighton: (petitioner's name and telephone number); (date petition was mailed); (plant name); and (publication date and page number of this FEDERAL REGISTER notice). A copy of the petition should also be sent to the Office of General Counsel- Bethesda, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Mr. Nicholas S. Reynolds, Esq., Bishop, Cook, Purcell & Reynolds, 1400

L Street, N.W., Washington, D.C. 20005-3502 and Mr. G. E. Doupe, Esq., Washington Public Power Supply System, P.O. Box 968, 3000 George Washington Way, Richland, Washington 99532, attorneys for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated March 7, 1988, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Richland City Library, Swift and Northgate Streets, Richland, Washington 99352.

Dated at Rockville, Maryland this 5th day of April, 1988.

FOR THE NUCLEAR REGULATORY COMMISSION


George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation