



# International Agreement Report

---

---

## RELAP5/MOD3.2.2 Gamma Assessment For Down To Top Reflooding Process At VVER Like 37-Rod Bundle

Prepared by:  
A.S. Devkin

Russian Research Center "Kurchatov Institute"  
Kurchatov Square 1  
123182, Moscow, Russia

**Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001**

**July 2002**

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Code Application and Maintenance Program (CAMP)

**Published by  
U.S. Nuclear Regulatory Commission**

## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material	Non-NRC Reference Material
<p>As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <a href="http://www.nrc.gov/NRC/ADAMS/index.html">www.nrc.gov/NRC/ADAMS/index.html</a>. Publicly released records include, to name a few, NUREG-series publications; <i>Federal Register</i> notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.</p> <p>NRC publications in the NUREG series, NRC regulations, and <i>Title 10, Energy</i>, in the Code of <i>Federal Regulations</i> may also be purchased from one of these two sources.</p> <ol style="list-style-type: none"> <li>1. The Superintendent of Documents U.S. Government Printing Office Mail Stop SSOP Washington, DC 20402-0001 Internet: <a href="http://bookstore.gpo.gov">bookstore.gpo.gov</a> Telephone: 202-512-1800 Fax: 202-512-2250</li> <li>2. The National Technical Information Service Springfield, VA 22161-0002 <a href="http://www.ntis.gov">www.ntis.gov</a> 1-800-553-6847 or, locally, 703-605-6000</li> </ol> <p>A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:</p> <p>Address: Office of the Chief Information Officer, Reproduction and Distribution Services Section U.S. Nuclear Regulatory Commission Washington, DC 20555-0001 E-mail: <a href="mailto:DISTRIBUTION@nrc.gov">DISTRIBUTION@nrc.gov</a> Facsimile: 301-415-2289</p> <p>Some publications in the NUREG series that are posted at NRC's Web site address <a href="http://www.nrc.gov/NRC/NUREGS/indexnum.html">www.nrc.gov/NRC/NUREGS/indexnum.html</a> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.</p>	<p>Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, <i>Federal Register</i> notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.</p> <p>Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—</p> <p style="margin-left: 40px;">The NRC Technical Library Two White Flint North 11545 Rockville Pike Rockville, MD 20852-2738</p> <p>These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—</p> <p style="margin-left: 40px;">American National Standards Institute 11 West 42<sup>nd</sup> Street New York, NY 10036-8002 <a href="http://www.ansi.org">www.ansi.org</a> 212-642-4900</p> <div style="border: 1px solid black; padding: 10px; margin-top: 10px;"> <p>Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.</p> <p>The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).</p> </div>

**DISCLAIMER:** This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.



# **International Agreement Report**

---

---

## **RELAP5/MOD3.2.2 Gamma Assessment For Down To Top Reflooding Process At VVER Like 37-Rod Bundle**

Prepared by:  
A.S. Devkin

Russian Research Center "Kurchatov Institute"  
Kurchatov Square 1  
123182, Moscow, Russia

**Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001**

**July 2002**

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Code Application and Maintenance Program (CAMP)

**Published by  
U.S. Nuclear Regulatory Commission**

## **CONTENTS**

<b>LIST OF FIGURES</b>	II
<b>ABSTRACT</b>	III
<b>EXECUTIVE SUMMARY</b>	IV
<b>INTRODUCTION</b>	1
<b>2. TEST FACILITY DESCRIPTION</b>	1
<b>2.1 Circulation loop</b>	1
<b>2.2 Test section</b>	1
<b>2.3 Rod bundle</b>	2
<b>2.4 Measurement system</b>	3
<b>2.5 Test procedure</b>	3
<b>3. TEST SCENARIO AND INITIAL CONDITIONS</b>	3
<b>3.1 Test scenario</b>	3
<b>3.2 Starting values of main parameters</b>	4
<b>4. NODALIZATION SCHEME DESCRIPTION</b>	4
<b>5. RESULTS OF CALCULATIONS</b>	4
<b>6. SENSITIVITY ANALYSIS</b>	17
<b>6.1. Radiation heat transfer influence</b>	17
<b>6.2 Axial power distribution influence.</b>	19
<b>6.3 Radial power distribution influence</b>	21
<b>7. RUN STATISTICS</b>	29
<b>8. CONCLUSIONS</b>	31
<b>REFERENCES</b>	32
<b>Appendix A. TEST FACILITY SCHEMES.</b>	33
<b>Appendix B. INPUT DECK FOR BASE CASE</b>	46

## LIST OF FIGURES

Fig.1 Nodalization scheme of test section .....	5
Fig. 2 Rods cladding temperature behavior at H=1. Base case calculation and experimental data. ....	6
Fig. 3 Rods cladding temperature behavior at H=2. Base case calculation and experimental data. ....	6
Fig. 4 Rods cladding temperature behavior at H=3. Base case calculation and experimental data. ....	7
Fig. 5 Rods cladding temperature behavior at H=4. Base case calculation and experimental data. ....	8
Fig. 6 Rods cladding temperature behavior at H=5. Base case calculation and experimental data. ....	9
Fig. 7 Rods cladding temperature behavior at H=6. Base case calculation and experimental data. ....	10
Fig. 8 Cladding temperature of rod N19. Base case calculation and experimental data. ....	11
Fig. 9 Cladding temperature of rod N22. Base case calculation and experimental data. ....	12
Fig. 10 Cladding temperature of rod N27. Base case calculation and experimental data. ....	13
Fig. 11 Full pressure drop at heated zone. ....	14
Fig. 12 Pressure drop at upper part of the bundle.....	15
Fig. 13 Pressure drop at lower part of the bundle.....	16
Fig. 14. Quenching front position. Base case and experimental data. ....	17
Fig. 15. Radiation heat transfer between rod bundle and vessel wall influence for H=5.....	18
Fig. 16. Radiation heat transfer between rod bundle and vessel wall influence for H=6.....	19
Fig. 17. Axial distribution influence on cladding temperature behavior for H=4.....	20
Fig. 18. Axial distribution influence on cladding temperature behavior for H=6.....	21
Fig. 19. Rod of type "B" temperature behavior. Experimental data for H=4. ....	22
Fig. 20. Rod of type "B" temperature behavior. Experimental and calculated data for H=6. ....	23
Fig. 21. Rod of type "A" temperature behavior. Experimental and calculated data for H=6. ....	24
Fig. 22. Rod of type "B" temperature behavior. Experimental and calculated data for H=5. ....	25
Fig. 23. Rod of type "B" temperature behavior. Experimental and calculated data for H=4. ....	26
Fig. 24. Quenching front position. Two-channel model results and experimental data. ....	27
Fig. 25. Pressure drop at the heated zone. Experimental data and results of calculations with two-channel scheme. ....	28
Fig. 26. Pressure drop at lower part of heated zone. Experimental data and results of calculations with two-channel scheme. ....	29
Fig. 27 CPU time during the test calculation. ....	30
Fig. 28 Time step behavior during the test. ....	31
Fig. 1A. Loop scheme. ....	33
Fig. 2A. Test section scheme. ....	34
Fig 3A. Upper plenum with current lead plate (1) and perforated plate (2). ....	35
Fig. 4A. Rod imitator with indirect heating. 1, 8 – copper rods, 2 – thermocouples, 3 – cladding, 4 – NI, Cr heater, 5 – pinch barrel, 6 – pulling wire, 7 – MgO, 8 - 9 – cone current lead.....	36
Fig. 5A. Axial power profile and thermocouple arrangement along the height for the test section KB-37.1.....	37
Fig 6A. Transducer arrangement (a) and the power profile map (b) across the test section KB-37.1 (top view). ....	38
Fig. 7A. Instrumentation for the test section KB-37.1 .....	39
Fig 8A. Main parameters behavior during the experiment. ....	40
Table A-1 .....	41
Table A-2 .....	43
Table A-3 .....	45

## **ABSTRACT**

The assessment of RELAP5/MOD3.2.2 Gamma for down to top reflooding at VVER like 37-rod bundle is presented. The experiment have been performed at IPPE test facility at the following parameters: upper plenum pressure- 0,246 MPa, cooling water temperature- 51°C, water velocity- 4,91 sm/s, average linear heat flux density at maximal heat production zone before water supply-1,77 kWt/m. RELAP5/MOD3.2.2Gamma assessment showed that code gives satisfactory results for all parameters behavior. The main discrepancies were get for cladding temperature behavior at level H- 2,7m, where the calculated cladding temperatures exceed experimental data approximately on 75 K. Computed quenching time for this level are much higher experimental ones. For other levels accordance between experimental and RELAP data is rather good.

## **EXECUTIVE SUMMARY**

This report presents the of RELAP5/MOD3.2.2 Gamma assessment in the prediction of reflooding process in VVER like 37-rod assembly with bottom to top water supply. The results of base case calculations showed that code gives satisfactory results for all parameters behavior. The main discrepancies were get for cladding temperature behavior at elevation 2.7m, where the calculated value exceeded the measured datum by about 75K. Computed quenching time for this elevation is much higher than experimental ones. For other levels accordance between experimental and RELAP data is rather good. Sensitivity analysis of results of calculations to input data showed that radial bundle nodding was inexpedient and it leads to less realistic results than at modeling of the bundle by one channel.

## **1. INTRODUCTION**

One of the main processes determining the behavior of fuel element during the accidents is the reflooding process, at which one they are cooling at the expense of water supplied to reactor from emergency core cooling (ECC) system. VVER type reactors against PWR ones have ECC system, which supplies the water not only from the bottom of the core, but also from the upper plenum.

This process is very difficult for mathematical modeling, so it seems reasonable to investigate it by separate ways: firstly down-to-top reflooding, then top-to-down one and then combined process.

Such researches are carried out now in EPPE at assemblies modeling an active zone of VVER reactors. Results of these investigations could be used for thermohydraulic codes assessment. Presented work such assessment have been done for RELAP5/MOD3 (version 3.2.2 Gamma), which consist an improved reflooding process model developed at Paul Scherer Institute using the experiment carried out at 37-rod VVER like assembly with down-to-top reflooding at IPPE in 2000.

## **2. TEST FACILITY DESCRIPTION**

### **2.1 Circulation loop**

Principal scheme of experimental loop is shown at Fig. 1A of Appendix A, which contents all necessary data for carrying out the calculations.

Water from tank (1) is supplied by centrifugal pumps (2) through the block of regulate valves with electric drive (B4) and B4(r) into electric heater (19) where water heats until the given temperature. Flowrate value is measured by set of two orifices, which are established sequentially on line of water supply to the test section (10). In automatic monitoring mode the given water flowrate is supported with the help of a valve electric drive B4(r). Distribution valves (4) established after a preheater (19) allows at an opened valve A and closed valves B and C and ball plug to route the flow to the test section (10), or to return into the tank (1) through the bypass line, which has the cooler (11) and stop valves (B6). Before the inlet of test section (10) is placed the throttle flowmeter (6), which is the indicator of switching of bang-bang valve (4) and beginning of water supply into the test section.

Separated in the upper plenum of the test section liquid collects in the tank of entrained water (7), connected by pipe with the bottom of the upper plenum. Vapor from the upper plenum passes through the special device with a developed surface, electric heater (15) where the remained non separated water evaporates, flowmeter orifice (6) and trough the vapor pressurizer (13) goes to condenser (16) and tank (1). The pressure in a system is established with the help of a steam compensator (13). Its regulation implements with the help of a valve (B9) and (B9r). If pressure exceeds given value, relief valve at compensator (13) opens.

### **2.2 Test section**

Test section (TS) scheme is shown at Fig. 2A. It consists of vessel, upper and lower plenum. Vessel is made of hexahedral tube with inner described diameter equal 91.4 mm and wall thickness 3.3 mm.

Vessel wall temperature is measured by 12 thermocouples at outer surface in four levels (692, 2038, 2732, 3500 mm from heater zone beginning) three thermocouples in level. There are three rings along the vessel for pressure tapoff.

Upper plenum intended for inertial phase separation of two phase flow coming out from the test section represents the cylindrical vessel ( $V=30000\text{sm}^3$ ). Gills arranged at the top of the plenum before an assigning nipple serve for additional phase separation. Separated water collects in the circular slot at the bottom of upper plenum and through the inclined opening flow off into the tank of entrained liquid. The bottom of upper plenum consists of two flanges lower of which serves for electric current supply to rod bundle and simultaneously for upper rod bundle grid modeling. Thickness of this grid is 20mm and

cross section area is near the grid area value. The nipple by an altitude of 100 mms and inner diameter 84-87mm fastens to the same flange. It models an upper part of reference VVER assembly. At the outlet of this nipple arranged the perforated plate 20mm thickness with 121 holes (109 and 12 hole 5.5mm and 3.5 mm diameter accordingly), which models the plate arranged at the outlet of the core of reference reactor. Cross section area of plate holes per one rod is near the reference reactor one. There are pipe connections in upper plenum and outlet nipple (fairlead) for thermocouples lead-in and pressure measurement.

Lower plenum represents a cylindrical vessel by inner diameter of 120 mm and altitude of 185 mm. For heat losses reducing vessel and plenums are isolated 20mm thickness high-temperature isolator (heat conduction coefficient equals to 0.05 Wt/(m K), heat capacity - 992 Kj/(kg K), density – 144 kg/m<sup>3</sup> at temperatures 123÷1523 K). There are four thermocouples at the outer surface of the isolator at different locations along the vessel for heat losses control.

### 2.3 Rod bundle

Rod bundle models the VVER assembly and consists of rod bundle of 37 rod imitators with indirect heating with heated zone length 3530mm.

Rod imitator (Fig. 4A) consists of stainless steel cladding with outer diameter 9.1mm and inner diameter 7.9mm inside, which are placed nichrome heater and six chromel-alumel thermocouples with isolated junction.

There are three types of rod imitators: in imitators of A type thermocouples placed at six locations along the length (one thermocouple for one level), in imitators of B and C type they are located in pairs at three locations (Fig.5A). Electric isolation used in all imitators is oxide magnium.

Heater is made from nichchrome rod of variable cross section at the ends of that are welded copper current supplyes. Average along al 37 rods length axial nonuniformity is equal Kz=1.60.

Main characteristics of imitator are presented at tables A1, A2, A3 of Appendix A. Rod bundle was maked up from imitators, which has identical characteristics. Relative scatter of rod power for 37 rods is less than 10%.

Besides upper grid there are 15 grids along the rod bundle, distance between which is 225mm. The rods in bundle replaced at triangular spasing with pitch equal to 12.75mm.

Cross sectional area in the narrowest part is 3328 mm<sup>2</sup>. There are thermocouples in the cells and at the grids .

Table 1 shows the main geometrical characteristics of the test section

The initial geometrical conditions for the test are the following:

inner circumscribed diameter of the vessel – 91.4mm,

inner vessel width across fields – 81.8mm,

average for 37 rods rod diameter – 9.14mm.

**Table 1**

Cross section area					D hydraulics	D heated
Support grid A-A	Rod bundle B-B	Grid C-C	Grid-current supply Д-Д	Perforated plate E-E	B-B	B-B
mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm	mm
2719	3328	2719	2438	2695 (121 holes)	9,95	12,53

## **2.3 Measurement system**

Test loop and assembly model are arranged by necessary amount of sensors and control system to measure the following parameters: inlet and outlet test section pressures and temperatures, water temperature and massflow at test section inlet, vapor temperature and massflow at its outlet, rod cladding and vessel wall temperatures, pressure drops at heated part of test section and tank of entrained liquid. Measurement scheme is presented at Fig.7A of Appendix A.

The Total parameters measurement error in the test was compounded as: pressure - 0,5 %; flowrate - 2,0 %; pressure drop - 1,0 %; power - 1,0 %; temperature - 1,0 %.

## **2.5 Test procedure**

- Loop for reflooding investigation is filled with water from tank (1) with use of centrifugal pumps (2) and blowed out to reduce air.
- Using block of regulation valves (12) necessary flowrate through the test section established. Water heating at the inlet of test section realized by switching on electrical heater (19). Nominal pressure in the loop is supported by valve B9(r). Then power stepwise increased. At different power levels parameters required for pressure drop measurement and verifying mass and energy balance were registered.
- Electrical power reduced to zero. With using bang-bang valve water flow trough the test section stopped and water flow directs to tank (1).
- Drainage valves opened and water flows out from the test section, tang of entrained liquid and vapor compensator (13). The remained liquid level was near the beginning of heater zone of rod bundle.
- Heater (15) switched on for heating-up pipeline before vapor flowmeters.
- Temperature at the inlet of test section checked.
- Information gathering computer system and power control system switched on.
- Test section power increased until ~40÷50% of nominal value.
- Test section power increased until nominal value in automatic mode.
- After reaching of specified temperature (any rod cladding temperature) began water supply to the test section and power decreased according to specified curve. Valve B14 closed.
- Switching on of water flowrate trough the test section (beginning of reflooding process) is controlled by flowmeter indication at line of water supply.
- Parameters supporting during the process in given limits carried out in automatic (power) and manual mode (flowrate, pressure, inlet temperature).
- Test stopped when all thermocouples fixed the rewetting of all rods and power switched out.

## **3. TEST SCENARIO AND INITIAL CONDITIONS**

Second Russian Standart Reflooding Problem is the reflooding experiment from down to top of 37-rods bundle of full length scale VVER like rod assembly with fixed cooling water supply.

### **3.1 Test scenario**

The initial conditions of test section was the following: lower plenum and lower rods (unheated part) part were filled with water 50°C and other part and upper plenum - with saturated vapor.

- Power increasing for given value and rods heating to start temperature.

- After reaching of starting temperature power decreasing began and switched on water supply to the test section.
- Test stopped at rod temperatures reached saturation temperature.

### 3.2 Starting values of main parameters

- Upper plenum pressure - 0,246 MPa;
- Cooling water temperature - 51°C;
- Water velocity - 4.91 sm/s;
- Average linear heat flux density at maximal heat production zone before water supply -1,77 kWt/m.

Reproducibility of such characteristics as maximal cladding temperature and quenching time in identical tests was near 1%.

Heat losses defined in special steady-state tests describes by formula:  $Q_{loss}=4,7 \cdot 10^3 (\bar{T}_k - T_o) \text{ kWt}$ , where  $(\bar{T}_k - T_o)$  – difference between average along the vessel length temperature and air one.

## 4. NODALIZATION SCHEME DESCRIPTION

Heat production in different rod simulators reviewing (Table A1) allows to come to conclusion, that despite of some scatter of axial distribution for different rods it seems quite reasonable to model all 37-rod bundle as the set of identical rods with average on all 37 rods axial heat distribution. Thus test section was modeled as one channel of "pipe" type devided into 15 parts along the length. Two heat structures connected with this channel modeled 37 heated rods (heat production equals zero at upper subvolume) and vessel wall. Upper plenum was modeled by two volumes "branch" type, which modeled upper perforated plate and upper volume where phase separation occurred. Down volume was connected with heat structure, modeled perforated plate. Inlet water temperature and its flowrate were set in the elements "tmddpjun" and "tmddpvol", connected with lower plenum modeled with element "branch" type.


## 5. Results of calculations

Calculations have been performed by RELAP5/MOD3.2 Gamma, which contents PSI reflooding model. At initial conditions there were established fixed distribution of vapor and heat structures temperatures – 2.46Mpa and 400K. The power bringed to test section began to increase and at time 139s inlet flowrate increased from zero up to 0.16kg/s. Power was changed according to experimental curve. Figs. 2-7 shows the results of calculations for three "A" type rods : №№ 19,22 and 27, for which were made the detailed cladding temperature measurements along the length .Table 2 shows the coordinates of thermocouples location.

**Table 2**

Section/ Rod	Thermocouple location, mm		
	19	22	27
H=1	57	117	184
H=2	513	690	698
H=3	1100	1215	1222
H=4	-	2212	2203
H=5	2704	2734	2722
H=6	3505	3501	3477

It is clear that the coordinates of thermocouples location some differed for on section and naturally their indications would be different too. But this difference is too small, as thermocouples locates near the end of plate zone of heat distribution. For more larger difference could play role their radial position. So the rod 19 is placed in the middle of bundle, rod 22 in the outer row near the vessel wall and rod 27 is placed in the second row from the center.



**Fig.1 Nodalization scheme of test section**




Fig. 2 Rods cladding temperature behavior at H=1. Base case calculation and experimental data




Fig. 3 Rods cladding temperature behavior at H=2. Base case calculation and experimental data




Fig. 4 Rods cladding temperature behavior at  $H=3$ . Base case calculation and experimental data




Fig. 5 Rods cladding temperature behavior at  $H=4$ . Base case calculation and experimental data





Fig. 6 Rods cladding temperature behavior at H=5. Base case calculation and experimental data



**Fig. 7 Rods cladding temperature behavior at H=6. Base case calculation and experimental data**

Fig. 8-11 shows the same data but separately for each rod. The analysis of these data shows that accordance between them is rather good especially for down and middle part of rod bundle (until H=4). For upper section especially for H=5 code gives lower temperatures, but more longer duration of reflooding process. Specially clear it is visible at Fig. 11, at which quenching front position during the test is presented. It is clear that front velocity propagation is very well predicted for lower part of the bundle, but for upper part the discrepancies between calculated and experimental values becomes larger. It must be noted that the experimental data for this part have significant scatter from 30s to 150s.

Fig. 11-13 shows pressure drop data along the test section: for down part of heated zone, upper part and total pressure drop for heated zone. One can see that total pressure drop predicted well enough, and for lower part calculated values are some lower experimental ones after 180s. Upper part pressure drops at first 300 s have different signs with closed rates of pressure drop increasing. Apparently the experimental data for this parameter is not correct and it is lowered approximately at 4kPa.




Fig. 8 Cladding temperature of rod N19. Base case calculation and experimental data




Fig. 9 Cladding temperature of rod N22. Base case calculation and experimental data




Fig. 10 Cladding temperature of rod N27. Base case calculation and experimental data.




Fig. 11 Full pressure drop at heated zone




Fig. 12 Pressure drop at upper part of the bundle




Fig. 13 Pressure drop at lower part of the bundle





Fig. 14. Quenching front position. Base case and experimental data


## 6. SENSITIVITY ANALYSIS

### 6.1. Radiation heat transfer influence

It seems reasonable that radiation heat transfer between different rod is inessential, as their temperatures differ from each other too small during the process. However radiation could play role in outer rods row and vessel wall. For checking such influence the calculations have been performed with taking into consideration the radiation heat transfer. Rod bundle in this calculation was modeled as for base case by one channel multiplicity 37 and heat structure, which changed with radiation heat with vessel wall. The results of this calculations are presented at Fig. 15-16.



**Fig. 15. Radiation heat transfer between rod bundle and vessel wall influence for  $H=5$ .**



**Fig. 16. Radiation heat transfer between rod bundle and vessel wall influence for H=6**

## 6.2 Axial power distribution influence

Fig. 17-18 show the results of calculations, performed with different variation factor along the bundle for H=4 and H=6. For these calculations were chosen such variations factors, which corresponded to rods with its maximal and minimal values of all bundle rods. Maximal difference was got for H=4, but as one could see from Fig. 17-18 this difference is too small and discrepancies between experimental data and computed couldn't be explained by this factor.




Fig. 17. Axial distribution influence on cladding temperature behavior for H=4





Fig. 18. Axial distribution influence on cladding temperature behavior for  $H=6$


### 6.3 Radial power distribution influence

Analysis of experimental data presented for example at fig. 7, shows that for upper bundle part radial position of the rod plays significant role. For example the earliest quenching takes place at the rods placed at the outer rod row. Quenching of the rods placed in the second from the vessel wall row occurred some later. The analogous results for type "B" rod presented at fig. 19.



**Fig. 19. Rod of type "B" temperature behavior. Experimental data for H=4**

For taking into account radial parameter the calculations have been performed with using modified nodalization scheme, in which whole rod bundle was divided into two parts: zone with all rods of outer row and the zone with the rest rods. Radiation heat transfer was taken into account for transfer between outer rods row and vessel wall, and radiation between outer rods and inner was neglected. Fig. 20 shows the results of these calculations for upper section type "B" rods.



**Fig. 20. Rod of type "B" temperature behavior. Experimental and calculated data for H=6**

Fig. 21 shows the analogous data for type "A" rods. One can see that though two groups cladding behavior are practically coincided, in a general way their behavior some change and quenching of upper part of the rods occurs some earlier than for case of bundle modeling with one channel. Fig. 22-23 shows the results for "A" group rods at H=5 and H=4.




Fig. 21. Rod of type "A" temperature behavior. Experimental and calculated data for H=6




Fig. 22. Rod of type "B" temperature behavior. Experimental and calculated data for  $H=5$




Fig. 23. Rod of type "B" temperature behavior. Experimental and calculated data for H=4

One can see from Fig. 21 radial dividing reduces quenching time for upper section (H=6), difference between temperatures behavior being practically neglecting. Difference from experimental and calculated data remained essential.

For section H=5 was obtained qualitatively incorrect behavior cladding temperature for both rod rows: more earlier quenching of inner rods. For both rows was obtained earlier quenching than for base case calculation. And for this case quenching times were obtained larger than experimental ones also.

For H=4 (Fig. 23) using two-channel model changed the results insignificant.

Fig. 24 shows the results of quenching front propagation with two-channel model using. Apparently from this figure quenching of bundle lower part occurred some later, than in experiment and in base case calculation. For upper part calculations with two-channel model gave earlier quenching, than for base case and as a rule inner part quenching occurred earlier than quenching of outer part.




Fig. 24. Quenching front position. Two-channel model results and experimental data

Fig. 25-26 shows the results of calculations of pressure drop on the bundle for base case and two-channel model. One can see pressure drop behavior for two-channel model characterized considerable oscillations not fixed in the experiment and accordance between calculated results and experimental data are less than for base case.





Fig. 25. Pressure drop at the heated zone. Experimental data and results of calculations with two-channel scheme




**Fig. 26. Pressure drop at lower part of heated zone. Experimental data and results of calculations with two-channel scheme**

## 7. RUN STATISTICS


Fig. 27-28 illustrate code efficiency where time step variation and CPU time during the calculation are presented. Grind time is evaluated as

$$\text{CPU}/(C \cdot DT) = 0,000228, \text{ where}$$

C = 18 – volumes number,  
 DT = 95992 – time steps number,  
 CPU = 395 s – CPU time.



**Fig. 27** CPU time during the test calculation



**Fig. 28 Time step behavior during the test**

## 8. CONCLUSIONS


The calculations down to top reflooding process at 37-rod bundle with code RELAP5/MOD3 (version 3.2.2 Gamma) showed that code gives satisfactory results for all parameters behavior. The main discrepancies were get for cladding temperature behavior at elevation 2.7m, where the calculated value exceeded the measured datum by about 75K. Computed quenching time for this elevation is much higher than experimental ones. For other levels accordance between experimental and RELAP data is rather good.

Sensitivity analysis of results of calculations to input data showed that radial bundle nodding was inexpedient and it leads to less realistic results than at modeling of the bundle by one channel.

## **REFERENCES**


1. Lozhkin V.V., Sudnitzyn O.A., Kulikov B.I., etc. Experimental and Theoretical Investigation of heat transfer at simulating of loss of coolant accidents with bottom-up reflooding on 37-rod assembly model of VVER. IPPE Report / N 9648, 1998.

## **Appendix A. TEST FACILITY SCHEMES**



**Fig. 1A. Loop scheme**

1- tank, 2 – pumps, 3,9 –steam generators , 4 –toggle valve, 5 - connectors, 6 – flowmeter orifices, 7 – entrained liquid tank, 10 – test section, 11- cooler, 13 – steam pressurizer, 15 – electric heater, 18 – downcomer model, 19 - preheater.



**Fig. 2A. Test section scheme**

1 - vessel; 2 - lower plenum; 3 - upper plenum; 4 - separator; 5 - louver; 6 - plate connected with current lead.; 5 - louver; 6 - plate connected with current lead.






Fig 3A. Upper plenum with current lead plate (1) and perforated plate (2)



**Fig. 4A. Rod imitator with indirect heating.** 1, 8 – copper rods, 2 – thermocouples, 3 – cladding, 4 – Ni, Cr heater, 5 – pinch barrel, 6 – pulling wire, 7 – MgO, 8 - 9 – cone current lead.



**Fig. 5A. Axial power profile and thermocouple arrangement along the height for the test section KB-37.1**

A, B, C, - imitator types; K - vessel; И - insulation;

● - wall mounting thermocouples;


○ - fluid thermocouples;

— a distance from the bottom of the heated zone\*(rough values);


232 — a distance from the bottom of the heated zone to the bottom of a grid spacer (measured before the tests).

\* - the correct values specified in Table A-2.

a)



b)



**Fig 6A. Transducer arrangement (a) and the power profile map (b) across the test section KB-37.1 (top view)**



- rod number,
- type and identification of a rod;



- rod number,
- relative power;



- hydraulic cell number;



- wall thermocouple, thermocouple number in the rod;



- fluid thermocouple, number of thermocouples in a cell along the height;



- grid thermocouple;



- vessel and insulation thermocouples;



- conductive probe.





Fig. 7A. Instrumentation for the test section KB-37.1



**Fig 8A. Main parameters behavior during the experiment**

**Table A-1 Bundle KB 37.1. Imitator test results**

Rod	Number of Tc	Inactive Tc	Identification	d <sup>max</sup>	$\bar{d}$	R <sub>passp.</sub>	R <sub>meas.</sub>	K <sub>Zi</sub>	K <sub>Ni</sub>	K <sub>ZH</sub> =K <sub>Z</sub> *K <sub>N</sub>	
1	6		<b>B-38</b>	9.16	9.12	0.569	0.567	1.592	0.986	1.57	0.98
16	6		<b>A-40</b>	9.12	9.11	0.566	0.561	1.589	0.996	1.58	0.99
34	5	5	<b>C-12</b>	9.13	9.12	0.575	0.575	1.620	0.972	1.57	0.98
2	4	1,3	<b>A-49</b>	9.13	9.11	0.552	0.552	1.570	1.012	1.59	0.99
5	6		<b>B-35</b>	9.14	9.11	0.560	0.559	1.572	1.000	1.57	0.98
10	6		<b>C-30</b>	9.25	9.23	0.564	0.564	1.660	0.991	1.64	1.03
23	6		<b>B-29</b>	9.15	9.14	0.569	0.568	1.676	0.984	1.65	1.03
29	6		<b>A-31</b>	9.16	9.14	0.562	0.558	1.684	1.001	1.69	1.05
35	6		<b>C-33</b>	9.16	9.14	0.563	0.560	1.593	0.998	1.59	0.99
6	6		<b>C-48</b>	9.11	9.10	0.575	0.572	1.585	0.977	1.55	0.97
17	6		<b>C-6</b>	9.19	9.19	0.580	0.573	1.521	0.975	1.48	0.93
30	5	6	<b>B-14</b>	9.16	9.12	0.561	0.560	1.597	0.998	1.59	1.00
7	6		<b>C-45</b>	9.13	9.12	0.562	0.557	1.596	1.003	1.60	1.00
11	6		<b>B-47</b>	9.14	9.12	0.558	0.554	1.569	1.009	1.58	0.99
24	6		<b>B-32</b>	9.18	9.16	0.569	0.558	1.689	1.001	1.69	1.06
12	6		<b>A-19</b>	9.14	9.13	0.575	0.576	1.522	0.970	1.48	0.92
18	6		<b>A-7</b>	9.15	9.13	0.573	0.573	1.655	0.975	1.61	1.01
25	6		<b>C-18</b>	9.14	9.13	0.598	0.589	1.578	0.949	1.50	0.94
19	6		<b>A-1</b>	9.13	9.12	0.560	0.560	1.571	0.998	1.57	0.98
26	6		<b>B- 2</b>	9.15	9.14	0.573.	0.527	1.565	1.060	1.66	1.04

20	6		<b>C-3</b>	9.14	9.1 3	0.512	0.506	1.582	1.104	1.75	1.09
13	6		<b>B-17</b>	9.15	9.1 2	0.592	0.590	1.586	0.947	1.50	0.94
31	6		<b>C-21</b>	9.17	9.1 4	0.574	0.567	1.509	0.986	1.49	0.93
27	6		<b>A-34</b>	9.15	9.1 4	0.534	0.527	1.573	1.060	1.67	1.04
14	3	2,3, 4	<b>C-24</b>	9.20	9.1 8	0.574	0.570	1.667	0.980	1.63	1.02
32	6		<b>C-27</b>	9.17	9.1 7	0.569	0.570	1.645	0.980	1.61	1.01
21	6		<b>B-23</b>	9.18	9.1 7	0.566	0.562	1.530	0.994	1.52	0.95
8	6		<b>A-46</b>	9.14	9.1 2	0.558	0.552	1.584	1.012	1.60	1.00
36	6		<b>A-25</b>	9.33	9.1 9	0.562	0.557	1.662	1.003	1.67	1.04
33	6		<b>C-36</b>	9.15	9.1 4	0.555	0.551	1.690	1.014	1.71	1.07
28	5	2	<b>B-20</b>	9.12	9.1 7	0.551	0.548	1.665	1.020	1.70	1.06
15	6		<b>C-39</b>	9.12	9.1 1	0.568	0.561	1.599	0.996	1.59	1.00
9	4	3,4	<b>B-44</b>	9.20	9.1 7	0.562	0.558	1.584	1.001	1.59	0.99
3	3	2,3, 5	<b>C-9</b>	9.13	9.1 2	0.568	0.565	1.614	0.989	1.60	1.00
37	6		<b>B-26</b>	9.14	9.1 3	0.549	0.545	1.501	1.025	1.54	0.96
22	6		<b>A-22</b>	9.15	9.1 2	0.557	0.55	1.638	1.003	1.64	1.03
4	4	1,3	<b>C-42</b>	9.17	9.1 5	0.549	0.544	1.594	1.027	1.64	1.02
<b>Average values</b>				<b>9.14</b>		<b>0.559</b>	<b>1.601</b>		<b>1.60</b>		

**Table A-2 Thermocouple arrangement in Bundle KB-37/1**

Rod Type	Rod	Thermocouple											
		1		2		3		4		5		6	
		l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°
A-1	19	57	186	513	225	1110	184	----	-----	2704	300	3505	0
A-7	18	180	298	----	-----	1194	182	2226	120	2725	46	----	-----
A-19	12	197	267	688	222	1215	196	2207	128	2727	108	3486	0
A-22	22	117	240	690	103	1215	20	2212	200	2734	164	3501	0
A-25	36	193	280	704	330	1233	120	2226	90	2741	70	3500	0
A-31	29	188	140	694	65	1217	290	2207	160	2725	25	3483	0
A-34	27	184	290	698	200	1222	115	2203	306	2722	142	3477	0
A-40	16	150	110	659	350	1187	273	2195	164	2721	70	3490	0
A-46	8	154	260	666	90	1190	356	2184	220	2706	108	3468	0
A-49	2	----	-----	682	110	-----	-----	2192	208	2710	120	3467	0

Rod Type	Rod	Thermocouple											
		1		2		3		4		5		6	
		l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°
B-2	26	942	68	945	230	2063	194	2067	48	3362	197	3365	0
B-14	30	774	296	775	102	2048	242	2048	68	3313	195	----	-----
B-17	13	773	184	773	342	1998	268	1997	103	3306	170	3306	0
B-20	28	793	350	----	-----	2026	40	2027	230	3349	183	3348	0
B-23	21	779	247	779	62	2013	15	2014	197	3334	179	3333	0
B-26	37	820	252	819	60	2022	86	2023	275	3323	188	3325	0
B-29	23	779	338	780	140	2012	185	2010	10	3326	188	3326	0
B-32	24	792	62	790	238	2021	178	2022	8	3341	180	3341	0
B-35	5	----	-----	764	125	1993	138	1991	325	3317	183	3316	0
B-38	1	756	334	757	138	2010	286	2010	100	3326	195	3325	0
B-44	9	756	290	756	95	----	-----	1965	6	3306	0	----	-----
B-47	11	741	125	741	304	2024	276	2024	98	3335	175	3335	0

Rod Type	Rod	Thermocouple											
		1		2		3		4		5		6	
		l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°	l,mm	φ°
C-3	20	1435	330	1437	150	2001	80	2000	250	2748	186	2746	0
C-6	17	1513	250	1514	78	2023	270	2023	70	2736	180	2737	0
C-9	3	1487	85	----	-----	1990	335	1987	170	----	-----	2692	0
C-12	34	1517	210	1518	22	2027	330	2026	165	----	-----	2729	0
C-18	25	1414	184	1414	338	1971	218	1971	32	2731	178	2730	0
C-21	31	1488	245	1491	64	2000	248	2001	80	2718	162	2718	0
C-24	14	1232	248	----	-----	----	----	----	----	2461	50	2461	-10
C-27	32	1505	298	1505	132	2014	280	2015	113	2733	220	2732	0
C-30	10	1527	290	1524	95	2039	214	2038	46	2759	200	2760	0
C-33	35	1495	130	1493	307	2012	224	2012	46	2736	168	2736	0
C-36	33	1511	160	1510	348	----	-----	2018	55	2737	175	2739	0
C-39	15	1488	82	1487	254	2004	285	2003	115	2729	170	2730	0
C-42	4	----	-----	1517	232	2020	235	2022	75	2737	185	----	-----
C-45	7	1476	105	1476	275	1987	20	1987	205	2715	176	2715	0
C-48	6	1487	85	1484	270	2004	12	2003	190	2728	170	2727	0



**Таблица А-3. Bundle 37.1. Axial power profile**

N	Rod	Type	Zone Number			1			2			3			4			5		
			L	Ø	Kz	L	Ø	Kz	L	Ø	Kz	L	Ø	Kz	L	Ø	Kz	L	Ø	Kz
1	19	A-1	695	3.85	0.657	525	3.23	0.934	1056	2.49	1.571	524	3.3	0.894	730	3.95	0.624			
2	18	A-7	785	3.9	0.576	501	3.00	0.973	1011	2.30	1.655	496	3.00	0.973	740	3.85	0.591			
3	12	A-19	774	3.58	0.642	494	3.05	1.022	997	2.50	1.522	494	3.05	1.022	776	3.80	0.659			
4	22	A-22	768	3.80	0.626	492	3.10	0.941	1005	2.35	1.638	508	3.10	0.941	757	3.85	0.61			
5	36	A-25	768	3.80	0.609	494	3.00	0.977	1003	2.30	1.662	507	3.10	0.915	759	3.85	0.593			
6	29	A-31	751	3.80	0.617	501	3.20	0.87	1013	2.30	1.684	503	3.10	0.927	762	3.85	0.601			
7	27	A-34	835	3.75	0.671	487	3.05	1.015	952	2.45	1.573	487	3.10	0.982	777	3.80	0.654			
8	16	A-40	747	3.75	0.635	495	3.00	0.992	1023	2.37	1.589	505	3.10	0.929	760	3.80	0.618			
9	8	A-46	757	3.75	0.633	485	3.00	0.989	1023	2.37	1.584	504	3.05	0.956	761	3.80	0.616			
10	2	A-49	769	3.75	0.643	493	3.00	1.005	1003	2.40	1.570	500	3.05	0.972	765	3.80	0.626			
11	26	B-2	770	3.8	0.667	499	3.2	0.940	1043	2.48	1.565	516	3.3	0.884	702	3.84	0.653			
12	30	B-14	763	3.75	0.638	494	3.00	0.997	1008	2.37	1.597	498	3.10	0.933	767	3.80	0.621			
13	13	B-17	765	3.85	0.616	499	3.00	1.015	1019	2.40	1.586	501	3.10	0.95	745	3.85	0.616			
14	28	B-20	786	3.85	0.620	484	3.20	0.898	995	2.35	1.665	502	3.15	0.927	764	3.80	0.637			
15	21	B-23	747	3.85	0.645	498	3.10	0.995	1020	2.50	1.530	501	3.10	0.995	764	3.85	0.645			
16	37	B-26	802	3.90	0.642	475	3.10	1.016	998	2.55	1.501	482	3.05	1.049	783	3.80	0.676			
17	23	B-29	741	3.90	0.583	498	3.15	0.893	1026	2.30	1.676	510	3.10	0.923	756	3.80	0.614			
18	24	B-32	760	3.85	0.603	485	3.20	0.873	1020	2.30	1.689	501	3.10	0.93	765	3.85	0.603			
19	5	B-35	736	3.75	0.644	503	3.05	0.974	1026	2.40	1.572	507	3.10	0.942	758	3.80	0.627			
20	1	B-38	733	3.75	0.625	495	3.05	0.945	1037	2.35	1.592	504	3.05	0.945	761	3.75	0.625			
21	9	B-44	732	3.75	0.633	501	3.00	0.989	1032	2.37	1.584	504	3.10	0.926	760	3.80	0.616			
22	11	B-47	759	3.70	0.660	493	3.05	0.971	1013	2.40	1.569	498	3.10	0.940	767	3.75	0.643			
23	20	C-3	765	3.9	0.676	520	3.35	0.917	1037	2.55	1.582	538	3.45	0.864	670	4	0.643			
24	17	C-6	749	3.90	0.625	495	3.10	0.989	1022	2.50	1.521	510	3.05	1.022	754	3.80	0.658			
25	3	C-9	770	3.82	0.611	495	3.05	0.958	1000	2.35	1.614	510	3.00	0.99	755	3.80	0.617			
26	34	C-12	757	3.7	0.626	499	2.95	0.985	1009	2.3	1.620	500	3.00	0.952	765	3.8	0.593			
27	25	C-18	692	3.70	0.61	517	2.90	0.992	1056	2.30	1.578	536	3.00	0.927	730	3.75	0.593			
28	31	C-21	762	3.80	0.653	495	3.10	0.982	1008	2.50	1.509	503	3.00	1.048	762	3.80	0.653			
29	14	C-24	750	3.80	0.611	514	3.10	0.918	1001	2.30	1.667	515	3.10	0.918	748	3.80	0.611			
30	32	C-27	754	3.8	0.618	499	3.1	0.929	1011	2.33	1.645	497	3.1	0.927	762	3.8	0.618			
31	10	C-30	754	3.80	0.608	503	3.10	0.914	1010	2.30	1.660	497	3.05	0.944	766	3.80	0.608			
32	35	C-33	738	3.80	0.609	500	3.00	0.978	1027	2.35	1.593	502	3.00	0.978	763	3.80	0.609			
33	33	C-36	745	3.9	0.588	495	3.2	0.873	1025	2.3	1.69	504	3.1	0.93	761	3.85	0.603			
34	15	C-39	758	3.75	0.639	486	3.05	0.996	1021	2.37	1.599	502	3.10	0.935	763	3.80	0.622			
35	4	C-42	775	3.80	0.636	480	3.05	0.987	1010	2.40	1.594	505	3.10	0.956	762	3.85	0.620			
36	6	C-48	748	3.75	0.623	500	3.0	0.973	1017	2.35	1.585	508	3.0	0.973	756	3.75	0.623			
37	7	C-45	747	3.75	0.638	495	3.05	0.964	1023	2.37	1.596	508	3.10	0.933	758	3.80	0.621			

## Appendix B. INPUT DECK FOR BASE CASE

```
= Reflooding for 37 rod assembly
* Q=48 KWT
0000100 new transnt
0000105 1. 2.
*
0000201 0.5 1.0e-08 0.001 0003 500 500 10000
0000202 50.0 1.0e-08 0.20 0003 50 5000 1000
0000203 130.0 1.0e-09 0.005 0003 200 5000 1000
0000204 200.0 1.0e-09 0.005 0003 2000 5000 1000
0000205 270.0 1.0e-09 0.005 0003 2000 5000 1000
0000206 280.0 1.0e-09 0.002 0003 2000 5000 1000
0000207 400.0 1.0e-08 0.005 0003 2000 5000 1000
*
20800001 cputime 0
20800002 dt 0
*
0000401 time 0 ge null 0 0.0 1
0000402 time 0 ge null 0 130.0 1
*
*****
*          volume data cards          *
*          *
*****
*          *
*          *
* water tank
*
0020000 "tank" tmdpvol
0020101 1.0 1.0 0.0 0.0 90.0 1. 0. 0.10
0020200 103
0020200 103
0020201 0.00 2.46000e5 324.15  *
*
* junction no. 4 (lower plenum to core)
*=====
* V inlet =4.91 sm/c, G= 580 kg/h =0.16 kg/s
0010000 "jun 1" tmdpjun
0010101 002000000 006000000 0.0113
0010200 1 402
0010201 0.0 0.0 0.0 0.0 *
0010203 1000.0 0.16 0.0 0.0 *
*=====
*
*crdno name type
0060000 in branch
*
*crdno jun.no ctrlw
0060001 1 1
*
*crdno area length volume h.ang v.ang elev rgh dhyd tlpvbfe
0060101 0.0113 0.185 0.0 0.0 90. 0.185 4.0-5 0.0 0010000
```

```

*
*crdno ebt pressure quale
0060200 002 2.460e5 0.0
*
*crdno from to area floss rloss efvcahs
* Area for 37 rod
0061101 006010000 004000000 0.003328 0.0 0.0 0001100
*
*
*crdno flowf flowg in.vel
0061201 0.0 0.0 0.0
*-----
*
* core *
0040000 "core" pipe
0040001 15
* vol area
0040101 0.003328 1
0040102 0.003328 2
0040103 0.003328 3
0040104 0.003328 4
0040105 0.003328 5
0040106 0.003328 6
0040107 0.003328 7
0040108 0.003328 8
0040109 0.003328 9
0040110 0.003328 10
0040111 0.003328 11
0040112 0.003328 12
0040113 0.003328 13
0040114 0.003328 14
0040115 0.003328 15
* junctions areas
0040201 0.0027187 1 *
0040202 0.0027187 2 *
0040203 0.0027187 3 *
0040204 0.0027187 4 *
0040205 0.0027187 5 *
0040206 0.0027187 6 *
0040207 0.0027187 7 *
0040208 0.0027187 8 *
0040209 0.0027187 9 *
0040210 0.0027187 10 *
0040211 0.0027187 11 *
0040212 0.0027187 12 *
0040213 0.0027187 13 *
0040214 0.0027187 14 *
*
*
* L total =3.53m =====
0040301 0.255 1 *
0040302 0.255 2 *
0040303 0.255 3 *
0040304 0.25 4 *
0040305 0.25 5 *
0040306 0.25 6 *
0040307 0.25 7 *
0040308 0.25 8 *
0040309 0.25 9 *
0040310 0.25 10 *

```

```

0040311 0.25 11 *
0040312 0.255 12 *
0040313 0.255 13 *
0040314 0.255 14 *
0040315 0.237 15 *
*
0040601 90.0 15
*
0040801 0.0 9.07e-3 15
0040901 0.1 0.1 14
*      pvbfe
0041001 01100 15
*      fvcahs
0041101 001000 14
*
*
0041201 102 2.46000e5 1.0 0.0 0.0 0 1
0041202 102 2.46000e5 1.0 0.0 0.0 0 2
0041203 102 2.46000e5 1.0 0.0 0.0 0 3
0041204 102 2.46000e5 1.0 0.0 0.0 0 4
0041205 102 2.46000e5 1.0 0.0 0.0 0 5
0041206 102 2.46000e5 1.0 0.0 0.0 0 6
0041207 102 2.46000e5 1.0 0.0 0.0 0 7
0041208 102 2.46000e5 1.0 0.0 0.0 0 8
0041209 102 2.46000e5 1.0 0.0 0.0 0 9
0041210 102 2.46000e5 1.0 0.0 0.0 0 10
0041211 102 2.46000e5 1.0 0.0 0.0 0 11
0041212 102 2.46000e5 1.0 0.0 0.0 0 12
0041213 102 2.46000e5 1.0 0.0 0.0 0 13
0041214 102 2.46000e5 1.0 0.0 0.0 0 14
0041215 102 2.46000e5 1.0 0.0 0.0 0 15
*
0041300 0
0041301 0.0 0.0 0.0 14
*
*
**+++++*****+
*      upper plenum
*
*crdno name type
2040000 out branch
*
*crdno jun.no ctrlw
2040001 1 1
*
*crdno area length volume h.ang v.ang elev rgh dhyd tlpvbf
2040101 2438.0e-6 0.1 0.0 0.0 90. 0.1 0.0 0.0 0010000
*      section D-D/37
*2040101 65.89e-6 0.225 0.0 0.0 90. 0.225 0.0 0.0 0010000
*
*crdno ebt pressure tempf
2040200 002 2.46000e5 1.0
*
*crdno from to area floss rloss efvcahs
2041101 004010000 204000000 2826.0e-6 0.1 0.1 0101000
*
*crdno flowf flowg in.vel
2041201 0.0 0.0 0.0

```

```

*
*-----
**+++++-----+
*
** upper plenum
*

*crdno name type
2060000 in branch
*
*crdno jun.no ctrlw
2060001 2 1
*
*crdno area length volume h.ang v.ang elev rgh dhyd tlpvbfe
2060101 0.0 0.460 30.0e-3 0.0 90. 0.460 0.0 0.0 0010000
* Total volume/37
*2060101 0.0 0.460 0.8108e-3 0.0 90. 0.460 0.0 0.0 0010000
*
*crdno ebt pressure tempf
2060200 002 2.46000e5 1.0
* 109 holes D=5.3mm + 12 holes D=3.5 mm
* =2403.5 mm2+ 115.4mm2 = 2519mm2,

2061101 204010000 206000000 2519.00e-6 0.1 0.1 0100000
* Outlet pipe D=60 mm, A= 2826mm2
2062101 206010000 010000000 2826.0e-6 0.1 0.1 0100000
*
*crdno flowf flowg in.vel
2061201 0.0 0.0 0.0
2062201 0.0 0.0 0.0
*-----
*
0100000 "u p" tmddpvol
0100101 1.0e6 1. 0. 0. 90. 1. 0. 0. 10
*
0100200 102
0100201 0.0 2.46000e5 1.0
*=====
*
*****-----+
*
*      heat slab structure      *
*
*****-----+
*
*
*
*
*crdno no.h.s no.m.p geo s.s.flg left reffl bvi no.ax.p
10016000 15 6 2 1 0. 402 1 8
*
10016100 0 1
*
*crdno intvl rt.cor intvl rt.cor
*      ****?
10016101 1 1.25e-3 1 3.85e-3 1 3.95e-3 2 4.55e-3
*
*crdno comp intvl comp intvl
* NIHROM MGO INCONEL
*10011201 2 2 3 4 4 5

```

	mgo	nihrom	mgo	s-steel	
10016201	3 1	2 2	3 3	4 5	
*					
*					
10016301	0.0	1			
10016302	1.0	2			
10016303	0.0	5			
*					
10016400	-1				
*					
10016401	373.00	373.00	373.00	373.00	
10016402	373.00	373.00	373.00	373.00	
10016403	373.00	373.00	373.00	373.00	
10016404	373.00	373.00	373.00	373.00	
10016405	373.00	373.00	373.00	373.00	
10016406	373.00	373.00	373.00	373.00	
10016407	373.00	373.00	373.00	373.00	
10016408	373.00	373.00	373.00	373.00	
10016409	373.00	373.00	373.00	373.00	
10016410	373.00	373.00	373.00	373.00	
10016411	373.00	373.00	373.00	373.00	
10016412	373.00	373.00	373.00	373.00	
10016413	373.00	373.00	373.00	373.00	
10016414	373.00	373.00	373.00	373.00	
10016415	373.00	373.00	373.00	373.00	
*					
10016501	0 0	0 1 9.435	1		
10016502	0 0	0 1 9.435	02		
10016503	0 0	0 1 9.435	03		
10016504	0 0	0 1 9.25	04		
10016505	0 0	0 1 9.25	05		
10016506	0 0	0 1 9.25	06		
10016507	0 0	0 1 9.25	07		
10016508	0 0	0 1 9.25	08		
10016509	0 0	0 1 9.25	09		
10016510	0 0	0 1 9.25	10		
10016511	0 0	0 1 9.25	11		
10016512	0 0	0 1 9.25	12		
10016513	0 0	0 1 9.435	13		
10016514	0 0	0 1 9.435	14		
10016515	0 0	0 1 9.435	15		
*					
10016601	004010000	0	1 1	9.287 1	
10016602	004020000	0	1 1	9.287 2	
10016603	004030000	0	1 1	9.287 3	
10016604	004040000	0	1 1	9.2685 4	
10016605	004050000	0	1 1	9.2685 5	
10016606	004060000	0	1 1	9.361 6	
10016607	004070000	0	1 1	9.361 07	
10016608	004080000	0	1 1	9.361 08	
10016609	004090000	0	1 1	9.361 09	
10016610	004100000	0	1 1	9.3684 10	
10016611	004110000	0	1 1	9.3684 11	
10016612	004120000	0	1 1	9.3277 12	
10016613	004130000	0	1 1	9.3277 13	
10016614	004140000	0	1 1	9.3277 14	
10016615	004150000	0	1 1	8.769 15	
*					
10016701	10002 0.044	0 0	1		
10016702	10004 0.044	0 0	2		

```

10016703 10006 0.044    0 0 3
10016704 10008 0.0744   0 0 4
10016705 10010 0.0744   0 0 5
10016706 10012 0.11467  0 0 6
10016707 10014 0.11467  0 0 7
10016708 10016 0.11467  0 0 8
10016709 10018 0.11467  0 0 9
10016710 10020 0.07388  0 0 10
10016711 10022 0.07388  0 0 11
10016712 10024 0.0442   0 0 12
10016713 10026 0.0442   0 0 13
10016714 10028 0.0442   0 0 14
10016715 10030 0.00     0 0 15
*
10016901 12.53e-3 20. 20. 0 0 0 0 1.0 15
*
=====
*
*
*
* shroud
*crdno no.h.s no.m.p geo s.s.flg left reffl bvi no.ax.p
10121000 15 6 2 1 45.0-3 * 402 0 8
*
10121100 0 1
*
*crdno intvl rt.cor
10121102 3 68.3e-3
*
*
*crdno comp intvl comp intvl
* Ssteel
10121201 11 2
10121202 12 5 * isolator
*
*
10121301 0.0 2
10121302 0.0 5
*
10121400 -1
*
10121401 373.00 373.00 373.00 373.00 373.00 373.00
10121402 373.00 373.00 373.00 373.00 373.00 373.00
10121403 373.00 373.00 373.00 373.00 373.00 373.00
10121404 373.00 373.00 373.00 373.00 373.00 373.00
10121405 373.00 373.00 373.00 373.00 373.00 373.00
10121406 373.00 373.00 373.00 373.00 373.00 373.00
10121407 373.00 373.00 373.00 373.00 373.00 373.00
10121408 373.00 373.00 373.00 373.00 373.00 373.00
10121409 373.00 373.00 373.00 373.00 373.00 373.00
10121410 373.00 373.00 373.00 373.00 373.00 373.00
10121411 373.00 373.00 373.00 373.00 373.00 373.00
10121412 373.00 373.00 373.00 373.00 373.00 373.00
10121413 373.00 373.00 373.00 373.00 373.00 373.00
10121414 373.00 373.00 373.00 373.00 373.00 373.00
10121415 373.00 373.00 373.00 373.00 373.00 373.00
*
10121501 004010000 0 1 1 0.251 1
10121502 004020000 0 1 1 0.251 2
10121503 004030000 0 1 1 0.251 3

```

10121504	004040000	0	1	1	0.2505	4
10121505	004050000	0	1	1	0.2505	5
10121506	004060000	0	1	1	0.253	6
10121507	004070000	0	1	1	0.253	7
10121508	004080000	0	1	1	0.253	8
10121509	004090000	0	1	1	0.253	9
10121510	004100000	0	1	1	0.2532	10
10121511	004110000	0	1	1	0.2532	11
10121512	004120000	0	1	1	0.2521	12
10121513	004130000	0	1	1	0.2521	13
10121514	004140000	0	1	1	0.2521	14
10121515	004150000	0	1	1	0.237	15

\*

10121601	-700	0	3701	1	0.251	1
10121602	-700	0	3701	1	0.251	2
10121603	-700	0	3701	1	0.251	3
10121604	-700	0	3701	1	0.2505	4
10121605	-700	0	3701	1	0.2505	5
10121606	-700	0	3701	1	0.253	6
10121607	-700	0	3701	1	0.253	7
10121608	-700	0	3701	1	0.253	8
10121609	-700	0	3701	1	0.253	9
10121610	-700	0	3701	1	0.2532	10
10121611	-700	0	3701	1	0.2532	11
10121612	-700	0	3701	1	0.2521	12
10121613	-700	0	3701	1	0.2521	13
10121614	-700	0	3701	1	0.2521	14
10121615	-700	0	3701	1	0.237	15

\*

10121701	100	0.0	0	0	1
10121702	100	0.0	0	0	2
10121703	100	0.0	0	0	3
10121704	100	0.0	0	0	4
10121705	100	0.0	0	0	5
10121706	100	0.0	0	0	6
10121707	100	0.0	0	0	7
10121708	100	0.0	0	0	8
10121709	100	0.0	0	0	9
10121710	100	0.0	0	0	10
10121711	100	0.0	0	0	11
10121712	100	0.0	0	0	12
10121713	100	0.0	0	0	13
10121714	100	0.0	0	0	14
10121715	100	0.0	0	0	15

\*

10121801	3.4e-3	20.	20.	0	0	0	0	1.0	15
10121901	3.4e-3	20.	20.	0	0	0	0	1.0	15

\*

\* 109 holes

\* upper plate

\*crdno no.h.s no.m.p geo s.s.flg left reffl bvi no.ax.p

10122000	1	3	2	1	2.65-3	*	402	0	8
----------	---	---	---	---	--------	---	-----	---	---

\*

```

10122100 0      1
*
*crdno intvl rt.cor
10122101 2      5.29e-3 * var11 * to obtain need mass of metal
*10122101 2      3.65e-3 * var10
*
*
*crdno comp intvl comp intvl
*Ssteel
10122201 11    2
*
*
10122301 0.0    2
*
10122400 -1
*
10122401 373.00 373.00 373.00
*
10122501 204010000 0     1 1 10.9 1 * 0.1*109
*
10122601 0 0     0 1 10.9 1
*
10122701 0 0.0   0 0 1
*
10122801 3.4e-3 20. 20. 0 0 0 0 1.0 1
10122901 3.4e-3 20. 20. 0 0 0 0 1.0 1
*
*
*****
*   heat structure thermal property data      *
*****
*
20100200 tbl/fctn 1 1 * nihrom
20100300 tbl/fctn 1 1 * MG-O
20100400 tbl/fctn 1 1 * Steel
20101200 tbl/fctn 1 1 * Isolator
*
*
*   thermal conductivity tables
*
*-----1-----1-----1-----1-----1-----1
* ISOLATOR
*-----1-----1-----1-----1-----1-----1
20101201 293.0 0.05
20101202 2700.0 0.05
*-----1-----1-----1-----1-----1-----1
* ISOLATOR
*-----1-----1-----1-----1-----1-----1
20101251 300. 1.428e5
20101252 2700. 5.50e6
*-----1-----1-----1-----1-----1-----1
*
*-----1-----1-----1-----1-----1-----1
* NICHROME 5 THERMAL CONDUCTIVITY (W/M-K) (004) [HEATERS]
*-----1-----1-----1-----1-----1-----1

```

20100201	293.0	12.5
20100202	373.0	13.8
20100203	473.0	15.6
20100204	573.0	17.2
20100205	673.0	19.0
20100206	873.0	22.6
20100212	2700.0	25.0
*-----1-----1-----1-----1-----1-----1		
* NICHROME 5 HEAT CAPACITY (J/M3-K)		
*-----1-----1-----1-----1-----1-----1		
20100251	300.	3.66e6
20100252	400.	3.96e6
20100253	500.	4.16e6
20100254	600.	4.34e6
20100255	700.	4.46e6
20100256	800.	4.68e6
20100257	900.	4.83e6
20100258	1000.	5.04e6
20100259	1100.	5.18e6
20100260	1200.	5.30e6
20100261	1700.	5.50e6
20100262	2700.	5.50e6
*-----1-----1-----1-----1-----1-----1		
*-----1-----1-----1-----1-----1-----1		
* MAGN. OXIDE THERMAL CONDUCTIVITY (W/M-K) (005) [INSULATOR]		
*-----1-----1-----1-----1-----1-----1		
20100301	293.0	1.7
20100302	473.0	2.75
20100303	573.0	2.6
20100304	673.0	2.5
20100305	873.0	2.52
20100306	1073.0	2.90
20100307	1173.0	3.20
20100308	2573.0	3.2
*-----1-----1-----1-----1-----1-----1		
* MAGN. OXIDE HEAT CAPACITY (J/M3-K)		
*-----1-----1-----1-----1-----1-----1		
20100351	293.	2.87e6
20100352	373.	3.04e6
20100353	473.	3.15e6
20100354	573.	3.20e6
20100355	673.	3.24e6
20100356	773.	3.29e6
20100357	873.	3.34e6
20100358	973.	3.44e6
20100359	1073.	3.53e6
20100360	1173.	3.63e6
20100361	1573.	3.63e6
20100362	2573.	3.63e6
*-----1-----1-----1-----1-----1-----1		
*=====		
*- - - - S-steel- - - - -		
* thermal conductiviti (w/m*k) (004)		
20100401	323.0	14.9
20100402	373.0	15.6
20100403	473.0	17.2
20100404	673.0	20.4
20100405	873.0	23.7
20100406	1073.0	27.4
20100407	1273.0	31.0

```

20100408 1573.0 31.0
20100409 2573.0 31.0
*-----*
*          heat capacity (j / m**3 * k) (004)
20100451 323.0 3.763e6
20100452 373.0 3.855e6
20100453 473.0 4.029e6
20100454 673.0 4.264e6
20100455 873.0 4.680e6
20100456 1073.0 4.985e6
20100457 1273.0 5.340e6
20100458 1573.0 5.340e6
20100459 2573.0 5.340e6
*-----*
* s-steel
*-----*
20101100 tbl/fctn, 1, 1
*---- thermal conductivity table
20101101 2.731500e+02 1.298051e+01
20101102 1.199817e+03 2.510604e+01
*---- volumetric heat capacity table
20101151 2.850000e+02 3.453703e+06, 3.350000e+02 3.769201e+06
20101152 3.664833e+02 3.830413e+06, 4.220389e+02 3.964814e+06
20101153 4.775944e+02 4.099214e+06, 5.331500e+02 4.233615e+06
20101154 5.887056e+02 4.334415e+06, 6.442611e+02 4.435081e+06
20101155 6.998167e+02 4.502416e+06, 8.109278e+02 4.636816e+06
20101156 1.366483e+03 5.376019e+06

*
*****power table 100 *****
*      power table 100  *
*****power table 100 *****
*
20210000 power 0 1.0 1.0e3 * Total power
20210001 0.0 0.00 * 0.
20210002 1.0 0.13 *
20210004 3.0 0.38 *
20210005 4.0 0.55 *
20210006 5.0 0.79 *
20210007 7.0 1.27 *
20210008 8.0 1.59 *
20210009 9.0 1.95 *
20210010 11.0 2.77 *
20210011 13.0 3.81 *
20210012 14.0 4.37 *
20210013 16.0 5.63 *
20210014 21.0 9.68 *
20210015 22.0 10.66 *
20210016 24.0 12.76 *
20210017 25.0 13.85 *
20210018 26.0 15.05 *
20210019 27.0 16.27 *
20210020 29.0 19.03 *
20210021 30.0 20.25 *
20210022 31.0 21.65 *
20210023 32.0 23.2 *
20210024 34.0 26.64 *
20210025 35.0 27.99 *
20210026 37.0 31.59 *
20210027 38.0 33.44 *

```

20210028	41.0	39.44	*
20210029	42.0	41.87	*
20210030	45.0	48.38	*
20210031	54.0	66.83	*
20210032	60.0	75.21	*
20210033	66.0	84.00	*
20210034	67.0	85.38	*
20210035	69.0	88.50	*
20210036	71.0	91.85	*
20210037	72.0	93.55	*
20210038	74.0	97.08	*
20210039	75.0	98.99	*
20210040	77.0	102.99	*
20210041	82.0	114.31	*
20210042	83.0	116.92	*
20210043	84.0	119.56	*
20210044	88.0	131.4	*
20210045	89.0	134.58	*
20210046	90.0	137.22	*
20210047	94.0	148.15	*
20210048	95.0	148.16	*
20210049	98.0	148.08	*
20210050	99.0	148.07	*
20210051	100.0	147.9	*
20210052	101.0	148.	*
20210053	102.0	147.8	*
20210054	124.0	147.85	*
20210055	125.0	147.64	*
20210056	126.0	147.80	*
20210057	129.0	147.91	*
20210058	130.0	147.72	*
20210059	131.0	146.48	*
20210060	132.0	143.31	*
20210061	133.0	141.95	*
20210062	134.0	141.37	*
20210063	135.0	140.56	*
20210064	142.0	135.15	*
20210065	143.0	134.60	*
20210066	144.0	133.56	*
20210067	145.0	133.74	*
20210068	150.0	130.56	*
20210069	151.0	130.68	*
20210070	157.0	127.97	*
20210071	170.0	122.89	*
20210072	180.0	119.68	*
20210073	251.0	105.9	*
20210074	270.0	103.61	*
20210075	290.0	101.32	*
20210076	320.0	98.01	*
20210077	340.0	96.68	*
20210078	350.0	95.72	*

\*

#### \* CONTROL VARIABLES

20507100	lev4	sum	1.0	0.0	0
20507101	0.0	0.243	voidf	004010000	
20507102		0.255	voidf	004020000	
20507103		0.278	voidf	004030000	
20507104		0.232	voidf	004040000	
20507105		0.268	voidf	004050000	
20507106		0.254	voidf	004060000	

```

20507107      0.255 voidf  004070000
20507108      0.255 voidf  004080000
20507109      0.248 voidf  004090000
20507110      0.322 voidf  004100000
20507111      0.182 voidf  004110000
20507112      0.272 voidf  004120000
20507113      0.255 voidf  004130000
20507114      0.231 voidf  004140000
20507115      0.237 voidf  004150000
*
*
20507200 flf1 mult 2438.0e-6   0.0 0
20507201 rhofj   204010000
20507202 velfj   204010000
20507203 voidfj   204010000
*
20507300 flfi mult 3328.0e-6   0.0 0
20507301 rhofj   006010000
20507302 velfj   006010000
20507303 voidfj   006010000
*-----1-----2-----3-----4-----5-----6-----7
*
20507400 flg mult 2438.0e-6   0.0 0
20507401 rhogi   204010000
20507402 velgj   204010000
20507403 voidgj   204010000
*-----1-----2-----3-----4-----5-----6-----7
*
20507500 dp1 sum 1.0e-3  0.0 0
20507501 0.0  1.    p  004010000
20507502     -1.0   p  004150000
*
20507600 dp2 sum 1.0e-3  0.0 0
20507601 0.0  1.    p  004080000
20507602     -1.0   p  04150000
*
*
20507700 dp3 sum 1.0e-3  0.0 0
20507701 0.0  1.    p  004010000
20507702     -1.0   p  004080000
*
20507800 dp4 sum 1.0e-3  0.0 0
20507801 0.0  1.    p  006010000
20507802     -1.0   p  004010000
*
20507900 dp5 sum 1.0e-3  0.0 0
20507901 0.0  1.    p  204010000
20507902     -1.0   p  206010000
*
20508000 inflow integral 1.0  0.0 0
20508001 cntrlvar 73
*
20508100 oflowf integral 1.0  0.0 0
20508101 cntrlvar 72
*
20508200 oflowg integral 1.0  0.0 0
20508201 cntrlvar 74
*
```

```

*      Core heat
*-----
*crd no    name   type  scale  init   flag
20508300  h_core sum   1.0    0.0    1
*crd no    a0     a1   var    code
20508301  0.0    1.0   q     004010000
20508302  1.0    q     004020000
20508303  1.0    q     004030000
20508304  1.0    q     004040000
20508305  1.0    q     004050000
20508306  1.0    q     004060000
20508307  1.0    q     004070000
20508308  1.0    q     004080000
20508309  1.0    q     004090000
20508310  1.0    q     004100000
20508311  1.0    q     004110000
20508312  1.0    q     004120000
20508313  1.0    q     004130000
20508314  1.0    q     004140000
20508315  1.0    q     004150000
*-----
*
*      Core heat calculated from cntrlvar
*-----
*crd no    name   type  scale  init   flag
20508400  h_core sum   1.0    0.0    1
*crd no    a0     a1   var    code
20508401  0.0    0.04433 cntrlvar 2
20508402  0.04433 cntrlvar 4
20508403  0.04433 cntrlvar 6
20508404  0.1065  cntrlvar 8
20508405  0.1065  cntrlvar 10
20508406  0.07975 cntrlvar 12
20508407  0.07975 cntrlvar 14
20508408  0.07975 cntrlvar 16
20508409  0.07975 cntrlvar 18
20508410  0.103   cntrlvar 20
20508411  0.103   cntrlvar 22
20508412  0.043   cntrlvar 24
20508413  0.043   cntrlvar 26
20508414  0.043   cntrlvar 28
*-----
*
20505700  mass4 sum  2438.0e-6 0.0  1  0
20505701  0.0    0.251   rho   004010000
20505702  0.251   rho   004020000
20505703  0.251   rho   004030000
20505704  0.2505  rho   004040000
20505705  0.2505  rho   004050000
20505706  0.253   rho   004060000
20505707  0.253   rho   004070000
20505708  0.253   rho   004080000
20505709  0.253   rho   004090000
20505710  0.2532  rho   004100000
20505711  0.2532  rho   004110000
20505712  0.2521  rho   004120000
20505713  0.2521  rho   004130000
20505714  0.2521  rho   004140000
20505715  0.237   rho   004150000
*=====

```

```

*----1----2----3----4----5----6----7
*-----
20500100 heat1 function 1.0 1.0 1
*
*      cccg0nn no table
20500101 htvat 0016001    036
*
*-----
20500200 heat2 mult 1.0 1.0     1
*
*      no table
20500201 cntrlvar 1      cntrlvar 41
*
*-----
20500300 heat1 function 1.0 1.0 1
*
*      cccg0nn no table
20500301 htvat 0016002    036
*
*-----
20500400 heat2 mult 1.0 1.0     1
*
*      no table
20500401 cntrlvar 003    cntrlvar 41
*      *
*
*-----
20500500 heat1 function 1.0 1.0 1
*
*      cccg0nn no table
20500501 htvat 0016003    036
*
*-----
20500600 heat2 mult 1.0 1.0     1
*
*      no table
20500601 cntrlvar 005    cntrlvar 41
*      *
*
*-----
20500700 heat1 function 1.0 1.0 1
*
*      cccg0nn no table
20500701 htvat 0016004    036
*
*-----
20500800 heat2 mult 1.0 1.0     1
*
*      no table
20500801 cntrlvar 007    cntrlvar 41
*      *
*
*-----
20500900 heat1 function 1.0 1.0 1
*
*      cccg0nn no table
20500901 htvat 0016005    036
*
*-----
20501000 heat2 mult 1.0 1.0     1

```

```

*
*          no table
20501001  cntrlvar 009  cntrlvar 41
*          *
*-----*
*-----*
20501100  heat1  function  1.0  1.0  1
*
*          cccg0nn  no table
20501101  htvat  0016006    036
*
*-----*
*-----*
20501200  heat2  mult   1.0 1.0  1
*
*          no table
20501201  cntrlvar 011  cntrlvar 41
*          *
*-----*
*-----*
20501300  heat1  function  1.0  1.0  1
*
*          cccg0nn  no table
20501301  htvat  0016007    036
*
*-----*
*-----*
20501400  heat2  mult   1.0 1.0  1
*
*          no table
20501401  cntrlvar 013  cntrlvar 41
*          *
*-----*
*-----*
20501500  heat1  function  1.0  1.0  1
*
*          cccg0nn  no table
20501501  htvat  0016008    036
*
*-----*
*-----*
20501600  heat2  mult   1.0 1.0  1
*
*          no table
20501601  cntrlvar 015  cntrlvar 41
*          *
*-----*
*-----*
20501700  heat1  function  1.0  1.0  1
*
*          cccg0nn  no table
20501701  htvat  0016009    036
*
*-----*
*-----*
20501800  heat2  mult   1.0 1.0  1
*
*          no table
20501801  cntrlvar 017  cntrlvar 41
*          *
*-----*
*-----*
20501900  heat1  function  1.0  1.0  1
*

```

```

*      cccg0nn  no table
20501901 htvat 0016010    036
*
*-----
20502000 heat2 mult 1.0 1.0   1
*
*      no table
20502001 cntrlvar 019  cntrlvar 41
*          *
*-----
*-----
20502100 heat1 function 1.0 1.0  1
*
*      cccg0nn  no table
20502101 htvat 0016011    036
*
*-----
20502200 heat2 mult 1.0 1.0   1
*
*      no table
20502201 cntrlvar 21   cntrlvar 41
*
*-----
20502300 heat1 function 1.0 1.0  1
*
*      cccg0nn  no table
20502301 htvat 0016012    036
*
*-----
20502400 heat2 mult 1.0 1.0   1
*
*      no table
20502401 cntrlvar 023  cntrlvar 41
*          *
*-----
*-----
20502500 heat1 function 1.0 1.0  1
*
*      cccg0nn  no table
20502501 htvat 0016013    036
*
*-----
20502600 heat2 mult 1.0 1.0   1
*
*      no table
20502601 cntrlvar 025  cntrlvar 41
*          *
*-----
*-----
20502700 heat1 function 1.0 1.0  1
*
*      cccg0nn  no table
20502701 htvat 0016014    036
*
*-----
20502800 heat2 mult 1.0 1.0   1
*
*      no table
20502801 cntrlvar 027  cntrlvar 41
*          *

```

```

*-----
*-----  

20502900 heat1 function 1.0 1.0 1  

*  

*      cccg0nn no table  

20502901 htvat 0016015    036  

*  

*-----  

20503000 heat2 mult 1.0 1.0 1  

*  

*          no table  

20503001 cntrlvar 029 cntrlvar 41  

*          *  

*-----  

*-----  

20504100 heat function 1.0 1297.3 1  

*          scale ini value flag  

20504100 heat function 1.0 3.902e3 1 * Qmax/Kz*l=1.77/1.601*3.53  

*  

*          no table  

20504101 time 00      100  

*  

*-----  

*          *  

20203600 reac-t  

*  

20203601 293.0 1.0  

20203602 373.0 1.0088  

20203603 473.0 1.0177  

20203604 573.0 1.0177  

20203605 673.0 1.035  

20203606 773.0 1.035  

20203607 873.0 1.035  

20203608 973.0 1.027  

20203609 1073.0 1.0177  

20203610 1273.0 1.0177  

20203611 1473.0 1.035  

*  

*-----  

20504200 heat function 1.0 6.739e2 1  

20504200 heat function 1.0 3.902e3 1  

*  

*          no table  

20504201 time 0      100  

*  

*-----  

20504300 R   function 0.1407 0.1407 1  

20504301 time 0      36  

*  

*-----  

*-----  

20504400 R2  mult 1.0  0.00648 1  

20504401 cntrlvar 43 cntrlvar 43  

*  

*-----  

20504500 heatt function 1.0 1297.3 1  

20504501 time 0      100  

*  

*-----  

*
```

```

20530100 T1 sum 1.0 0.0 0
20530101 0.0 1. httemp 001600106
20530102 -1.0 cntrlvar 233
*
*
20530200 T2 sum 1.0 0.0 0
20530201 0.0 1. httemp 001600206
20530202 -1.0 cntrlvar 233
*
*
20530300 T3 sum 1.0 0.0 0
20530301 0.0 1. httemp 001600306
20530302 -1.0 cntrlvar 233
*
*
20530400 T4 sum 1.0 0.0 0
20530401 0.0 1. httemp 001600406
20530402 -1.0 cntrlvar 233
*
*
20530500 T5 sum 1.0 0.0 0
20530501 0.0 1. httemp 001600506
20530502 -1.0 cntrlvar 233
*
*
20530600 T6 sum 1.0 0.0 0
20530601 0.0 1. httemp 001600606
20530602 -1.0 cntrlvar 233
*
*
20530700 T7 sum 1.0 0.0 0
20530701 0.0 1. httemp 001600706
20530702 -1.0 cntrlvar 233
*
*
20530800 T8 sum 1.0 0.0 0
20530801 0.0 1. httemp 001600806
20530802 -1.0 cntrlvar 233
*
*
20530900 T9 sum 1.0 0.0 0
20530901 0.0 1. httemp 001600906
20530902 -1.0 cntrlvar 233
*
*
20531000 T10 sum 1.0 0.0 0
20531001 0.0 1. httemp 001601006
20531002 -1.0 cntrlvar 233
*
*
20531100 T11 sum 1.0 0.0 0
20531101 0.0 1. httemp 001601106
20531102 -1.0 cntrlvar 233
*
*
20531200 T12 sum 1.0 0.0 0
20531201 0.0 1. httemp 001601206
20531202 -1.0 cntrlvar 233
*
*

```

```

20531300 T13 sum 1.0 0.0 0
20531301 0.0 1. httemp 001601306
20531302 -1.0 cntrlvar 233
*
*
20531400 T14 sum 1.0 0.0 0
20531401 0.0 1. httemp 001601406
20531402 -1.0 cntrlvar 233
*
*
20531500 T15 sum 1.0 0.0 0
20531501 0.0 1. httemp 001601506
20531502 -1.0 cntrlvar 233
*
*****
***** Vessel wall*****
20520100 TK1 sum 1.0 0.0 0
20520101 0.0 1. httemp 012100402 * zone 1
20520102 -1.0 cntrlvar 233
*
*
20520200 TK2 sum 1.0 0.0 0
20520201 0.0 1. httemp 012100402 *zone 1
20520202 -1.0 cntrlvar 233
*
*
20520300 TK3 sum 1.0 0.0 0
20520301 0.0 1. httemp 012100402 * zone 1
20520302 -1.0 cntrlvar 233
*
*
20520400 TK4 sum 1.0 0.0 0
20520401 0.0 1. httemp 012100902 * zone 2
20520402 -1.0 cntrlvar 233
*
*
20520500 TK5 sum 1.0 0.0 0
20520501 0.0 1. httemp 012100902 * zone 2
20520502 -1.0 cntrlvar 233
*
*
20520600 TK6 sum 1.0 0.0 0
20520601 0.0 1. httemp 012100902 *zone 2
20520602 -1.0 cntrlvar 233
*
*
20520700 TK7 sum 1.0 0.0 0
20520701 0.0 1. httemp 012101102 * zone 3
20520702 -1.0 cntrlvar 233
*
*
20520800 TK8 sum 1.0 0.0 0
20520801 0.0 1. httemp 012101102 * zone 3
20520802 -1.0 cntrlvar 233
*
*
20520900 TK9 sum 1.0 0.0 0
20520901 0.0 1. httemp 012101102 * zone 3
20520902 -1.0 cntrlvar 233
*
*

```

```

20521000 TK10 sum 1.0 0.0 0
20521001 0.0 1. htemp 012101402 *zone 4
20521002 -1.0 cntrlvar 233
*
*
20521100 TK11 sum 1.0 0.0 0
20521101 0.0 1. htemp 012101402 * zone 4
20521102 -1.0 cntrlvar 233
*
*
20521200 TK12 sum 1.0 0.0 0
20521201 0.0 1. htemp 012101402 * zone 4
20521202 -1.0 cntrlvar 233
*
*-----
*           Isolation
20521300 Tiz1 sum 1.0 0.0 0
20521301 0.0 1. htemp 012100406
20521302 -1.0 cntrlvar 233
*
20521400 Tiz2 sum 1.0 0.0 0
20521401 0.0 1. htemp 012100906
20521402 -1.0 cntrlvar 233
*
20521500 Tiz3 sum 1.0 0.0 0
20521501 0.0 1. htemp 012101106
20521502 -1.0 cntrlvar 233
*
20521600 Tiz4 sum 1.0 0.0 0
20521601 0.0 1. htemp 012101506
20521602 -1.0 cntrlvar 233
*
*
20522000 Tin sum 1.0 0.0 0
20522001 0.0 1. tempf 006010000
20522002 -1.0 cntrlvar 233
*
*
20522100 Tout sum 1.0 0.0 0
20522101 0.0 1. tempg 206010000
20522102 -1.0 cntrlvar 233
*
*
20522200 Gin sum 133200. 0.0 0 **37
20522201 0.0 1. mflowj 006010000
*
*
20522300 G_gout sum 133200. 0.0 0
20522301 0.0 1. cntrlvar 74
*
*
20522400 POWER sum 0.037 0.0 0 ** 37 rod,KWT
20522401 0.0 1. cntrlvar 41
*
*
20522500 PIN sum 1.0e-3 0.0 0
20522501 0.0 1. p 006010000

```

```

*
*
20522600 Pout sum 1.0e-3 0.0 0
20522601 0.0 1. p 206010000
*
*
20522700 mmmm sum 1.0 0.0 0
20522701 0.0 1. mflowj 006010000
*
*
20522800 Tg1 sum 1.0 0.0 0 *H=762
20522801 0.0 1. tempg 004040000
20522802 -1.0 cntrlvar 233
*
*
20522900 Tg2 sum 1.0 0.0 0 * H=1527
20522901 0.0 1. tempg 004070000
20522902 -1.0 cntrlvar 233
*
*
20523000 Tg3 sum 1.0 0.0 0 *H= 2037
20523001 0.0 1. tempg 004090000
20523002 -1.0 cntrlvar 233
*
*
20523100 Tg4 sum 1.0 0.0 0 *H= 2802
20523101 0.0 1. tempg 004120000
20523102 -1.0 cntrlvar 233
*
*
20523200 Tg5 sum 1.0 0.0 0 *H= 3567
20523201 0.0 1. tempg 004150000
20523202 -1.0 cntrlvar 233
*
*
* temperature in containment
20270000 temp
*
20270001 0.0 310.0
20270002 1.0e6 310.0
*-----
20270100 htc-t 0 1.0 1.0
20270101 -1.0 300.0
20270102 10000.0 300.0

*crdno name c.c.typ s.fac in.v. in.flag
20523300 T_CEL function 1.0 1.0 0
*
*crdno var code table
20523301 time 0 584
*
* *
20258400 reac-t
*
20258401 0.0 273.0

. end of problem

```

NRC FORM 335  
(2-89)  
NRCM 1102,  
3201, 3202

U.S. NUCLEAR REGULATORY COMMISSION

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

2. TITLE AND SUBTITLE

RELAP5/MOD3.2.2 GAMMA ASSESSMENT FOR DOWN TO TOP REFLOODING PROCESS  
AT VVER LIKE 37-ROD BUNDLE

5. AUTHOR(S)

A.S. Devkin

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Nuclear Safety Institute  
Russian Research Center  
"Kurchatov Institute"  
123182, Moscow ,Russia

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Division of System Analysis and Regulatory Effectiveness  
Office of Nuclear Regulatory Research  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

This is a Russian CAMP in-kind contribution

11. ABSTRACT (200 words or less)

The assessment of RELAP5/MOD3.2.2 Gamma for down to top reflooding at VVER like 37-rod bundle is presented. The experiment have been performed at IPPE test facility at the following parameter s: upper plenum pressure- 0,246 MPa, cooling water temperature- 51N, water velocity- 4.91 sm/s, average linear heat flux density at maximal heat p roduction zone before water supply-1,77 kWt/m. RELAP5/MOD3.2.2Gamma assessment showed that code gives satisfactory results for all parameters behavior. The main discrepancies were get for cladding temperature b ehavior at level H-2.7m, where the calculated cladding temperatures exceed experimental data approximately on 75 K . Computed quenching time for this level are much higher experimental ones. For other levels accordance between experime ntal and RELAP data is rather good.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

reflood, RELAP5, VVER

1. REPORT NUMBER  
(Assigned by NRC, Add Vol., Supp., Rev.,  
and Addendum Numbers, if any.)

NUREG/IA-0207

3. DATE REPORT PUBLISHED

MONTH	YEAR
July	2002

4. FIN OR GRANT NUMBER

6. TYPE OF REPORT

technical

7. PERIOD COVERED (Inclusive Dates)


13. AVAILABILITY STATEMENT  
unlimited

14. SECURITY CLASSIFICATION  
(This Page)  
unclassified

(This Report)  
unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, DC 20555-0001

---

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300