

Marc P. Pearson Director, Services & Projects Beaver Valley Power Station Route 168 P.O. Box 4 Shippingport, PA 15077-0004

> 724-682-5234 Fax: 724-643-8069

> > ADOI

July 19, 2002 L-02-075

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555-0001

Subject: Beaver Valley Power Station, Unit No. 1 Docket No. 50-334, License No. DPR-66 License Amendment Request No. 301, Supplement No. 1 Positive Moderator Temperature Coefficient

FirstEnergy Nuclear Operating Company (FENOC) requested an amendment to the above license for a Technical Specification change regarding positive moderator temperature coefficient by letter L-02-065, dated May 31, 2002. This letter corrects the following two errors that were inadvertently contained in the previous submittal.

- 1. The cover letter should have requested approval of License Amendment Request (LAR) No. 301 by February 1, 2003 (instead of April 1, 2003) to support operation following the Beaver Valley Power Station, Unit No. 1 refueling outage 1R15.
- 2. Attachment A of LAR No. 301 shows the proposed wording changes being requested by the LAR. Marked-up Technical Specification page 3/4 1-5 had inadvertently included a typographical error in a Note. The Note designated as # listed near the bottom of page 3/4 1-5 incorrectly referenced Special Test Exception 3.10.3 and should have referenced Special Test Exception 3.10.4. Attached is a new marked-up Technical Specification page 3/4 1-5 which correctly shows the proposed wording for Technical Specification page 3/4 1-5.

The above two changes do not alter the evaluations, justifications, conclusions, commitments, or the no significant hazards evaluation previously submitted for LAR No. 301.

If there are any questions concerning this matter, please contact Mr. Larry R. Freeland, Manager, Regulatory Affairs/Corrective Action at 724-682-5284.

Beaver Valley Power Station, Unit No. 1 License Amendment Request No. 301, Supplement No. 1 L-02-075 Page 2

I declare under penalty of perjury that the foregoing is true and correct. Executed on July 19, 2002.

Sincerely,

euro _____

Marc P. Pearson

Attachment

c: Mr. D. S. Collins, NRR Project Manager Mr. D. M. Kern, NRC Sr. Resident Inspector Mr. H. J. Miller, NRC Region I Administrator Mr. D. A. Allard, Director BRP/DEP Mr. L. E. Ryan (BRP/DEP)

REACTIVITY CONTROL SYSTEMS

MODERATOR TEMPERATURE COEFFICIENT (MTC)

LIMITING CONDITION FOR OPERATION

- 3.1.1.4 The moderator temperature coefficient (MTC) shall be:
 - a. Less positive than 0×10^{-4} $-\Delta k/k/^{\circ}F$, \leftarrow INSERT 1
 - b. Less negative than $-5.0 \times 10^{-4} \Delta k/k/^{\circ}F$ at RATED THERMAL POWER.

<u>APPLICABILITY</u>: MODES 1 and 2^{*#}

ACTION:

With the Moderator Temperature Coefficient outside any one of the above limits, be in HOT STANDBY within 6 hours.

SURVEILLANCE REQUIREMENTS

4.1.1.4.1 The MTC shall be determined to be within its limits by confirmatory measurements. MTC measured values shall be extrapolated and/or compensated to permit direct comparison with the above limits.

4.1.1.4.2 The MTC shall be determined at the following frequencies and THERMAL POWER conditions during each fuel cycle:

- a. Prior to initial operation above 5% of RATED THERMAL POWER, after each fuel loading.
- b. At any THERMAL POWER, within 7 EFPD after reaching a RATED THERMAL POWER equilibrium boron concentration of 300 ppm.

BEAVER VALLEY - UNIT 1

Amendment No.

^{*}With $K_{eff} \ge 1.0$. #See Special Test Exception 3.10.4.