

April 17, 1998

Mr. J. V. Parrish
Chief Executive Officer
Washington Public Power Supply System
P.O. Box 968 (Mail Drop 1023)
Richland, Washington 99352-0968

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND OPPORTUNITY FOR HEARING - WASHINGTON
PUBLIC POWER SUPPLY SYSTEM - NUCLEAR PROJECT NO. 2 (WNP-2)

Dear Mr. Parrish:

Enclosed is a copy of the subject notice that relates to your application for amendment dated April 16, 1998. The proposed amendment would change the maximum yield strength for emergency core cooling system suction strainer materials listed in the WNP-2 Final Safety Analysis Report. This change was identified as an unreviewed safety question.

The Notice has been forwarded to the Office of the Federal Register for publication.

Sincerely,
Original Signed By

Chester Poslusny, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Notice

cc w/encl: See next page

DISTRIBUTION:

Docket
PUBLIC
PDIV-2 Reading
EAdensam
WBateman
CPoslusny
EPeyton
KPerkins, Region IV WCFO
PGwynn, Region IV
ACRS
OGC

DOCUMENT NAME: WNPPR3.NOT

OFC	PDIV-2/PM	PDIV-2/LA
NAME	CPoslusny	EPeyton
DATE	4/16/98	4/16/98

OFFICIAL RECORD COPY

9804240362 980417
PDR ADOCK 05000397
P PDR

NUC FILE CENTER COPY

1/1
DFOI

Mr. J. V. Parrish

- 2 -

April 17, 1998

cc w/encl:

Mr. Greg O. Smith (Mail Drop 927M)
WNP-2 Plant General Manager
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0968

Mr. Rodney L. Webring (Mail Drop PE08)
Vice President, Operations Support/PIO
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352

Mr. Albert E. Mouncer (Mail Drop 1396)
Chief Counsel
Washington Public Power Supply System
P.O. Box 968
Richland, Washington 99352-0968

Ms. Deborah J. Ross, Chairman
Energy Facility Site Evaluation Council
P. O. Box 43172
Olympia, Washington 98504-3172

Mr. D. W. Coleman (Mail Drop PE20)
Acting Manager, Regulatory Affairs
Washington Public Power Supply System
P.O. Box 968
Richland, Washington 99352-0968

Mr. Paul Inserra (Mail Drop PE20)
Manager, Licensing
Washington Public Power Supply System
P.O. Box 968
Richland, Washington 99352

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Chairman
Benton County Board of Commissioners
P.O. Box 69
Prosser, Washington 99350-0190

Mr. Scott Boynton, Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 69
Richland, Washington 99352-0968

Mr. Perry D. Robinson, Esq.
Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. 50-397

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-21, issued to Washington Public Power Supply System, (the licensee), for operation of the Nuclear Project No. 2 (WNP-2) located in Benton County, Washington.

The proposed amendment would revise the maximum yield strength for emergency core cooling system suction strainer materials listed in the WNP-2 Final Safety Analysis Report (FSAR). The licensee identified this change as an unreviewed safety question and accordingly, the NRC staff is reviewing this FSAR change.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By May 21, 1998, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the

Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Richland Public Library, 955 Northgate Street, Richland, Washington 99352. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In

addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Perry D. Robinson, Esq., Winston & Strawn, 1400 L Street NW, Washington, DC 20005-3502, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated April 16, 1998, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Richland Public Library, 955 Northgate Street, Richland, Washington 99352.

Dated at Rockville, Maryland, this 17th day of April 1998.

FOR THE NUCLEAR REGULATORY COMMISSION



Chester Poslusny, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation