VIRGINIA ELECTRIC AND POWER COMPANY

RICHMOND, VIRGINIA 23261 July 26, 2002

United States Nuclear Regulatory Commission

Attention: Document Control Desk

Washington, DC 20555-0001

02-360A Serial No.:

I R/DFA: R0

Docket Nos.: 50-280/281

50-338/339

License Nos.: DPR-32/37

NPF-4/7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION) SURRY AND NORTH ANNA POWER STATIONS UNITS 1 AND 2 LICENSE RENEWAL - COMMENTS ON DRAFT SER

In a letter dated June 6, 2002, the NRC provided Virginia Electric and Power Company (Dominion) the draft Safety Evaluation Report (SER) for license renewal of North Anna Power Station, Units 1 and 2, and Surry Power Station, Units 1 and 2. The draft SER was provided for comment and response to the open items and confirmatory actions. The NRC staff identified eight open items and fifteen confirmatory actions associated that require resolution. Dominion provided the requested response to the open items and a disposition of the confirmatory actions identified in the draft SER in a letter dated July 25, 2002 (Serial No. 02-360).

As requested, the draft SER has been reviewed for accuracy and consistency against the License Renewal Applications submitted for Surry and North Anna Power Stations and subsequent information provided by Request for Additional Information responses. Dominion's comments are attached. In the transmittal letter with the draft SER, the NRC staff described their plans to review the format of the SER to further improve the content while incorporating comments and responses. Accordingly. Dominion's comments are limited to items that might be considered to have implications on the bases of the conclusions presented in the SER if not resolved for consistency with the License Renewal Application.

Should you have any questions regarding this submittal, please contact Mr. J. E. Wroniewicz at (804) 273-2186.

Very truly yours,

Leslie N. Hartz

Vice President – Nuclear Engineering

Attachment

Commitments made in this letter: None

100l

SPS/NAPS

LR - Comments on Draft SER

cc page 1 of 4

CC:

U. S. Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center 61 Forsyth Street, SW Suite 23T85 Atlanta, GA 30303-8931

Mr. M. J. Morgan NRC Senior Resident Inspector North Anna Power Station

Mr. R. A. Musser NRC Senior Resident Inspector Surry Power Station

Mr. J. E. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center
4201 Dominion Blvd.
Suite 300
Glen Allen, VA 23060

Ms. Ellie Irons, EIR Program Manager Virginia Dept. of Environmental Quality 629 East Main St., 6th FI Richmond, VA 23219

Mr. David Paylor, Program Coordinator Virginia Dept. of Environmental Quality P.O. Box 10009 Richmond, VA 23240-0009

Mr. Joe Hassell, Environmental Manager Virginia Dept. of Environmental Quality Water Division P.O. Box 10009 Richmond, VA 23240-0009

SPS/NAPS

LR - Comments on Draft SER

cc page 2 of 4

Mr. Frank Daniel, Regional Director Virginia Dept. of Environmental Quality Tidewater Regional Office 5636 Southern Blvd. Virginia Beach, VA 23462

Mr. Gregory Clayton, Regional Director Virginia Dept. of Environmental Quality Northern Virginia Regional Office 13901 Crown Ct. Woodbridge, VA 22193

Mr. Frank Fulgham, Program Manager Virginia Dept. of Agriculture & Consumer Services Office of Plant & Pest Services 1100 Bank St. Richmond, VA 23219

Mr. David Brickley, Agency Director Virginia Dept. of Conservation & Recreation 203 Governor St. Richmond, VA 23219

Mr. William Woodfin, Director Virginia Dept. of Game & Inland Fisheries 4010 West Broad St. Richmond, VA 23230

Mr. Robert Hicks, Director Virginia Dept. of Health Office of Environmental Health Services 1500 East Main St., Room 115 Richmond, VA 23219

Ms. Kathleen S. Kilpatrick, Director Virginia Dept. of Historic Resources State Historic Preservation Office 2801 Kensington Ave. Richmond, VA 23221

SPS/NAPS

LR - Comments on Draft SER

cc page 3 of 4

Dr. Ethel Eaton, Archeologist Senior Virginia Dept. of Historic Resources State Historic Preservation Office 2801 Kensington Ave. Richmond, VA 23221

Mr. Robert W. Grabb, Assistant Commissioner Virginia Marine Resources Commission 2600 Washington Ave.
Newport News, VA 23607

Dr. John Olney, Associate Professor Virginia Institute of Marine Science School of Marine Science Gloucester Point, VA 23062

Mr. John Simkins Virginia Dept. of Transportation Environmental Division 1401 East Broad St. Richmond, VA 23219

Mr. Robert Burnley Virginia Economic Development Partnership 901 East Byrd St. Richmond, VA 23219

Mr. William F. Stephens, Director Virginia State Corporation Commission Division of Energy Regulation 1300 East Main St., 4th Fl., Tyler Bldg. Richmond, VA 23219

Mr. Michael Cline, State Coordinator Commonwealth of Virginia Department of Emergency Management 10501 Trade Rd. Richmond, VA 23236-3713

Mr. Terry Lewis, County Administrator P.O. Box 65 Surry, VA 23883

SPS/NAPS

LR - Comments on Draft SER

cc page 4 of 4

Mr. Lee Lintecum Louisa County Administrator P.O. Box 160 Louisa, VA 23093

Mr. Douglas C. Walker Acting Spotsylvania County Administrator P.O. Box 99 Spotsylvania, VA 22553

Ms. Brenda G. Bailey, County Administrator P.O. Box 11 Orange, VA 22960

Chairman Reeva Tilley Virginia Council on Indians P.O. Box 1475 Richmond, VA 23218

Mr. Don Lillywhite, Director Economics Information Services Virginia Employment Commission State Data Center 703 East Main St., Room 213 Richmond, VA 23219

Mr. Alan Zoellner Government Information Department Swem Library College of William and Mary Landrum Dr. P.O. Box 8794 Williamsburg, VA 23187-8794

Mr. Walter Newsome Government Information Resources Alderman Library University of Virginia 160 McCormick Rd. P.O. Box 400154 Charlottesville, VA 22904-4154

50-38/339

Serial No.: 02-360A

Attachment Page 1 of 5

Attachment

License Renewal – Comments on Draft SER Serial No. 02-360A

Comments on Draft Safety Evaluation Report

Dated June 6, 2002

Surry and North Anna Power Station, Units 1 and 2

License Renewal

Virginia Electric and Power Company (Dominion)

50-38/339

Serial No.: 02-360A

Attachment Page 2 of 5

Comments on Draft SER for Surry and North Anna Power Station License Renewal Applications

Comment #1:

General comment.
Various sections and pages

Request for Additional Information (RAI) 2.1-3 caused Dominion to re-assess the license renewal scope for components and systems with regard to 10CFR54.4(a)(2). As a result, additional systems, or portions of systems, were added to the scope of license renewal for each station because of their spatial orientation in and around safety related systems. The draft SER (Section 3) does not accurately reflect the inclusion of these systems in the Aging Management Review Results. It is recommended that the NRC staff consider addressing these systems in a global manner by inclusion of a specific discussion in Section 2.3, *Scoping and Screening Results: Mechanical Systems*.

Comment #2:

Section 2.1.3.1 Page 2-10 3rd paragraph, next to last sentence:

Delete this sentence beginning with "The SDBD..." in its entirety. The System Design Basis Documents (SDBDs) have a controlling procedure but they do not fall under the cognizance of the Nuclear Quality Assurance Program. The referenced LR guideline (LRPG-501) provides the requirements for preparing, reviewing, and approving License Renewal technical reports, but does not control any part of the process to develop or maintain the SDBDs.

50-38/339

Serial No.: 02-360A Attachment

Page 3 of 5

Comment #3:

Section 2.1.3.2
Page 2-17
<u>Electrical Components</u>, 2nd, 3rd, and 4th sentences:

This paragraph needs to be revised to clarify that those electrical/I&C components, that are included in the license renewal scope only because they performed a pressure boundary function, were treated as mechanical components in the system screening process. The remaining electrical/I&C components were categorized into component groups regardless of whether or not they had mark numbers. Therefore, delete the 2nd and 3rd sentences and replace them with the following:

"The electrical/I&C components that are in scope because they perform a pressure boundary function are shown on system drawings. The applicant has treated these electrical/I&C components as mechanical components and identified them during system screening."

At the beginning of the 4th sentence replace "For the non-mark-numbered components" with "For the remaining electrical/I&C components."

Comment #4:

Section 2.4.1 Page 2-165 1st paragraph, 3rd sentence:

The statement "The NAS UFSAR does not address the containment structure for the North Anna plant." is not correct. It should be replaced with the following statement: "The design of the NAS 1/2 containment structures is described in NAS UFSAR Sections 3.7 and 3.8.2."

Docket Nos. 50-280/281 50-38/339

Serial No.: 02-360A Attachment Page 4 of 5

Comment #5:

Section 3.4.3.1.1 Page 3-127 4th paragraph, starting with 3rd sentence:

The information in the following sentences is not correct as stated. "For the individual subcomponents, the design loadings fit into the normal, upset, or faulted conditions as defined in the ASME Boiler and Pressure Vessel Code, Section III. The allowable stress limits during the design basis accident (DBA) used for the core support structures are based on the January 1971 draft of the ASME Code for Core Support Structures, Subsection NG, and the Criteria for Faulted Conditions."

To be consistent with SER Section 4.3.2, page 4-13, this paragraph should be revised to state: "The SPS and NAS reactor internals were designed to Westinghouse criteria, which were established prior to the issuance of the ASME Code Section III Subsection NG. The Westinghouse criteria contained no TLAAs and used pressure load calculations instead of fatigue calculations."

The Westinghouse design of the reactor vessel internals is similar for both the three-loop plants designed with the Westinghouse criteria and the three-loop plants designed with ASME Section III Subsection NG criteria. In addition, the design transients for the reactor coolant system (RCS), including the reactor vessel internals, are similar.

50-38/339

Serial No.: 02-360A Attachment

Page 5 of 5

Comment #6:

Section 3.4.3.1.2 Page 3-128 3rd paragraph, last sentence:

The statement that the applicant identifies "Metal Fatigue" as an applicable TLAA associated with the RV internals is incorrect. The sentence should either be deleted or replaced with the statement "In addition, the applicant does not identify any TLAAs associated with the RV internals."