

Dockets Nos. 50-282
and 50-306

OCT 25 1984

Distribution:	Docket File
Reading File	Gray File
NRC & L PDRs	PMcKee
EJordan	PKreutzer
DDiIanni	TBarnhart 8
CMiles	WJones
DBrinkman	ACRS 10
LHarmon	DEisenhut
RDiggs	JPartlow

Mr. D. M. Musolf
Nuclear Support Services Department
Northern States Power Company
414 Nicollet Mall - 8th Floor
Minneapolis, Minnesota 55401

Dear Mr. Musolf:


On September 12, 1984, the Commission issued Amendment Nos. 70 and 64 to Facility Operating License Nos. DPR-42 and DPR-60 for the Prairie Island Nuclear Generating Plant, Unit Nos. 1 and 2, in response to your application dated April 10, 1984, as supplemented.

Among other changes, the amendment corrected typographical errors and misspelled words in the existing Technical Specifications and changed wording involving operator action related to the number of operable instrumentation channels associated with containment ventilation isolation system in Table TS 3.5-4.

Page TS.3.14-4, which contained only a typographical error correction, was inadvertently omitted from the amendments. On Table 3.5-4, Column 4 - Operator Action..., the words "above Cold Shutdown" were inadvertently omitted, though discussed in the Safety Evaluation and approved for issuance. Copies of the two pages are enclosed.

Please accept our apologies for the inconvenience that this administrative error caused you.

Sincerely,



Dominic DiIanni, Project Manager
Operating Reactors Branch No. 4
Division of Licensing

Enclosures:

Ts pages TS.3.14-4 and
Table TS.3.5-4

cc w/enclosures:

See next page

ORB#3:DL
PKreutzer:ef
10/25/84

ORB#3:DL
DDiIanni
10/25/84

ORB#3:DL
JMiller
10/26/84

8411150327 841025
PDR ADDCK 05000282
P PDR

TABLE TS.3.5-4

INSTRUMENT OPERATING CONDITIONS FOR ISOLATION FUNCTIONS

<u>FUNCTIONAL UNIT</u>	<u>1</u> MINIMUM OPERABLE CHANNELS	<u>2</u> MINIMUM DEGREE OF REDUNDANCY	<u>3</u> PERMISSIBLE BYPASS CONDITIONS	<u>4</u> OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. CONTAINMENT ISOLATION				
a. Safety Injection			(See Item No. 1 of Table TS.3.5-3)	Hot shutdown**
b. Manual	2	1		Hot shutdown
2. CONTAINMENT VENTILATION ISOLATION				
a. Safety Injection			(See Item No. 1 of Table TS.3.5-3)	Maintain Purge and Inservice Purge Valves closed if (1) conditions of a, b, or c cannot be met above Cold Shutdown or (2) if conditions of b or c cannot be met during fuel handling in containment.
b. High Radiation in Exhaust Air	2	1		
c. Manual	2	1		
3. STEAM LINE ISOLATION				
a. Hi-Hi Steam Flow with Safety Injection	2	1		Hot shutdown**
b. Hi Steam Flow and 2 of 4 Low T _{avg} with Safety Injection	2	1		Hot shutdown**
c. Hi Containment Pressure	1/loop	1		Hot shutdown**
d. Manual	1/loop	-		Hot shutdown**
4. EMERGENCY COOLDOWN EQUIPMENT ROOM ISOLATION				
a. High temperature in ventilation system ducts	2	1		Hot shutdown**

**If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in cold shutdown conditions.

Unit 1 - Amendment No. 46, 70
Unit 2 - Amendment No. 40, 64

8411150332 841025
PDR ADDCK 05000282
PDR

F. Yard Hydrant Hose Houses

1. Whenever equipment in the following buildings is required to be operable, the yard hydrant hose houses in the main yard loop adjacent to each building shall be operable:
 - a. Unit No. 1 Reactor Building
 - b. Unit No. 2 Reactor Building
 - c. Turbine Building
 - d. Auxiliary Building
 - e. Screen House
2. If Specification 3.14.F.1 cannot be met, within one hour have sufficient additional lengths of 2-1/2 inch diameter hose located in adjacent operable yard hydrant hose house(s) to provide service to the unprotected area(s).

Restore the yard hydrant hose house(s) to Operable status within 14 days or submit a 30-day written report outlining the cause of the inoperability and the plans and schedule for restoring the houses to Operable status.

G. Penetration Fire Barriers

1. All penetration fire barriers in fire area boundaries protecting equipment required to be operable shall be operable.
2. If Specification 3.14.G.1 cannot be met, a continuous fire watch shall be established on at least one side of the affected penetration(s) within one hour.

Restore the inoperable penetration fire barriers to Operable status within 14 days or submit a 30-day written report outlining the cause of the inoperability and the plans and schedule for restoring the barriers to Operable status.