



Kewaunee Nuclear Power Plant
N490 Highway 42
Kewaunee, WI 54216-9511
920.388.2560

Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, WI 54241
920.755.2321

Kewaunee / Point Beach Nuclear
Operated by Nuclear Management Company, LLC

NRC 2002-0045

10 CFR 50.55a

May 15, 2002

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Docket 50-301
Point Beach Nuclear Plant, Unit 2
Reactor Vessel Closure Head Inspection
Request for Withdrawal of Relief Requests MR 02-004-1 and MR 02-004-2

Ladies/Gentlemen:

In accordance with 10 CFR 50.55a(a)(3)(i) and 10 CFR 50.55a(g)(5)(iii), Nuclear Management Company, LLC (NMC), licensee for the Point Beach Nuclear Plant (PBNP) Unit 2, submitted Relief Requests MR 02-004-1 and MR 02-004-2 on April 17, 2002. This action is related to NMC's response dated April 2, 2002, to NRC Bulletin 2002-001, "Reactor Pressure Vessel Head Degradation and Reactor Coolant Pressure Boundary Integrity."

The associated inspection of the Unit 2 reactor vessel head commenced on April 21, 2002. The visual inspection showed that the head is in very good condition, with no evidence of leakage. As a result, PBNP will not be performing any reactor vessel head repairs. Therefore, Relief Requests MR 02-004-1 and MR 02-004-2 are no longer required and their withdrawal is hereby requested.

Sincerely,

Thomas J. Webb
Regulatory Affairs Manager

LAS/kmd

cc: NRC Regional Administrator
NRC Resident Inspector

NRC Project Manager
PSCW