



>>> "Robert L Gill Jr" <rlgill@duke-energy.com> 06/06/02 01:40PM >>>

Rani,

Debbie and I have your request of earlier today and propose that we can add the following to the UFSAR Supplement summary description of the Crane Inspection Program for each station:

Add the following sentence to Acceptance Criteria -

"The acceptance criterion is in accordance with the criterion identified in ASME/ANSI requirements and OSHA regulations."

Please advise if this is acceptable. Bob

CC: "Debra V Keiser" <dvkeiser@duke-energy.com>