



- NOTES:
1. FOR GENERAL NOTES REFER TO DRAWING 33013-2241
 2. VALVE POSITIONS AT THIS TIME DO NOT REFLECT ALIGNMENT FOR ANY MODE OF OPERATION; THEY ARE SHOWN ONLY TO REPRESENT THE SYSTEM AS-BUILT CONFIGURATION.
 3. SEE DRAWING 33013-482, 0838 & 0839 FOR DETAILS OF THE ELECTRICAL INTERFERENCE TO THE FIRE PROTECTION SYSTEMS DEPICTED ON THIS DRAWING.
 4. ALL PIPING IS SCHEDULE 40, ASTM A-53 OR A-106.
 5. FIRE SYSTEM S07 AND S08 WERE COMBINED INTO A SINGLE SYSTEM SUCH THAT ANY DETECTOR FROM EITHER OF THE SYSTEMS WOULD PUT THE SYSTEM INTO ALARM.

THOSE PORTIONS OF THIS DRAWING WHICH ARE COLORED CYAN INDICATE THAT THE COLORED ITEM IS SUBJECT TO AGING MANAGEMENT REVIEW

| | | | | |
|--|-------------------------------|---------|---------|---------|
| REVISED PER | ANG | RMS | OW | JEP |
| DATE | 2/21/00 | 2/23/00 | 2/24/00 | 2/24/00 |
| CD FILE NAME | 3P124301 | | | |
| CONSTRUCTION | LIMITED CONSTRUCTION AS NOTED | | | |
| PRELIMINARY NOT FOR CONSTRUCTION | BIDDING PURPOSES | | | |
| DATE | 3/24/00 | | | |
| DATE | RELEASED FOR | | | |
| SCALE | NONE | | | |
| FIRE PROTECTION RELAY AND MULTIPLEXOR ROOMS (FP) | | | | |
| JOB NO. | DRAWING NO. | | | REV. |
| EWR 10113 | 33013-1242-LR | | | 1 |
| CCD 01 | CONTROL COPY # | | | |