THOSE PORTIONS OF THIS DRAWING WHICH ARE COLORED CYAN INDICATE THAT THE COLORED ITEM IS SUBJECT TO AGING MANAGEMENT REVIEW

D-17

NOTES:

1. FOR GENERAL NOTES REFER TO DRAWING 33013-2241.
2. REV.0 OF THIS DRAWING SUPERSEDES PORTIONS OF DRAWING 33013-1250, REV. 8.
3. EXCEPT WHERE OTHERWISE INDICATED, SAFETY CLASS BREAKS FOR ALL VENT, DRAIN & TEST CONNECTIONS SHALL BE AT THE ROOT VALVE IN ACCORDANCE WITH DETAIL "A".
4. THE PIPING DESIGNATED BY LINE SPECIFICATION 125-1-SFP WAS INSTALLED UNDER EWR 15948, WHICH HAD A SEPERATE LINE SPECIFICATION FROM SPS291, 151.
5. THE SHELL SIDE OF THE SPENT FUEL POOL STANDBY HEAT EXCHANGER CONNECTS TO SERVICE WATER AT VALVES 8687 (F-2) AND 8686 (G-8) WHEN IN USE.
6. THE MOTOR OPERATOR ON VALVE 4620B IS NOT ELECTRICALLY CONNECTED. THE VALVE MUST BE OPERATED USING THE MANUAL HANDWHEEL.
7. THE ACCEPTABILITY OF VALVES 3142C AND 3142E BEING NORMALLY OPEN HAS BEEN EVALUATED UNDER EWR 5168.

REV.	REVISED PER	AJG	RMS	RMS	PS
2	SCR 2001-0078				
1	SCR 2001-0005	4/11/01	4/27/01	4/27/01	5/7/01
0	SCR 2001-0005				

CAD FILE NAME: 3P125002

CONSTRUCTION	
LIMITED CONSTRUCTION AS NOTED	
PRELIMINARY NOT FOR CONSTRUCTION	
BIDDING PURPOSES	
5/7/01 AS BUILT	PS
DATE RELEASED FOR	ENGR.

DRAWN: GINNA STA. — ROCHESTER GAS & ELECTRIC CORP. ROCHESTER, NEW YORK

SCALE: NONE

STATION SERVICE COOLING WATER
SAFETY RELATED
(SW)
P&ID

JOB NO.	DRAWING NO.	REV.
EWR 3391E	33013-1250 SHEET 2 OF 3-LR	2
CCD 01	CONTROL COPY #	